



STANTON ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	STANTON ELEMENTARY SCHOOL	WS- 002535	8/17/2016	1	Health Suite	In health suite 101	FT-82016-002535-A	< 1	FT-82016-002535-B	< 1
2	STANTON ELEMENTARY SCHOOL	WS- 009848	8/17/2016	Basement	Cooler	In hallway adjacent to cafeteria High Left	FT-82016-009848-A	< 1	FT-82016-009848-B	< 1
3	STANTON ELEMENTARY SCHOOL	WS- 009849	8/17/2016	Basement	Cooler	In hallway adjacent to cafeteria Low Right	FT-82016-009849-A	< 1	FT-82016-009849-B	< 1
4	STANTON ELEMENTARY SCHOOL	WS- 009850	8/17/2016	Basement	Cooler	In cafeteria	FT-82016-009850-A	< 1	FT-82016-009850-B	< 1
5	STANTON ELEMENTARY SCHOOL	WS- 009851	8/17/2016	Basement	Food Prep Sink	In kitchen first clockwise from entry door	FT-82016-009851-A	< 1	FT-82016-009851-B	< 1
6	STANTON ELEMENTARY SCHOOL	WS- 009857	8/17/2016	1	Cooler	In hallway adjacent to room 117 High Left	FT-82016-009857-A	< 1	FT-82016-009857-B	< 1
7	STANTON ELEMENTARY SCHOOL	WS- 009858	8/17/2016	1	Cooler	In hallway adjacent to room 117 Low Right	FT-82016-009858-A	< 1	FT-82016-009858-B	< 1
8	STANTON ELEMENTARY SCHOOL	WS- 009859	8/17/2016	1	Cooler	In hallway across from room 106 High Left	FT-82016-009859-A	< 1	FT-82016-009859-B	< 1
9	STANTON ELEMENTARY SCHOOL	WS- 009860	8/17/2016	1	Cooler	In hallway across from room 106 Low Right	FT-82016-009860-A	< 1	FT-82016-009860-B	< 1
10	STANTON ELEMENTARY SCHOOL	WS- 009876	8/17/2016	2	Cooler	In hallway across from room 207 High Left	FT-82016-009876-A	< 1	FT-82016-009876-B	< 1
11	STANTON ELEMENTARY SCHOOL	WS- 009877	8/17/2016	2	Cooler	In hallway across from room 207 Low Right	FT-82016-009877-A	< 1	FT-82016-009877-B	< 1
12	STANTON ELEMENTARY SCHOOL	WS- 009878	8/17/2016	2	Cooler	In hallway across from room 214 High Left	FT-82016-009878-A	< 1	FT-82016-009878-B	< 1
13	STANTON ELEMENTARY SCHOOL	WS- 009879	8/17/2016	2	Cooler	In hallway across from room 214 Low Right	FT-82016-009879-A	< 1	FT-82016-009879-B	< 1
14	STANTON ELEMENTARY SCHOOL	WS- 009880	8/17/2016	3	Cooler	In hallway across from room 307 High Left	FT-82016-009880-A	< 1	FT-82016-009880-B	< 1
15	STANTON ELEMENTARY SCHOOL	WS- 009881	8/17/2016	3	Cooler	In hallway across from room 307 Low Right	FT-82016-009881-A	< 1	FT-82016-009881-B	< 1
16	STANTON ELEMENTARY SCHOOL	WS- 009883	8/17/2016	3	Cooler	In hallway across from room 315 High Left	FT-82016-009883-A	< 1	FT-82016-009883-B	< 1
17	STANTON ELEMENTARY SCHOOL	WS- 009884	8/17/2016	3	Cooler	In hallway across from room 315 Low Right	FT-82016-009884-A	< 1	FT-82016-009884-B	< 1