



STANTON LEAD WATER TEST RESULTS

May 24th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009847	Utility	Basement	In boiler room(Water source)	WT-042916-9864- A	< 1	WT-042916-9864- B	< 1				
2 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009848	Cooler	Basement	In hallway adjacent to cafeteria Left High	WT-042916-9865- A	< 1	WT-042916-9865- B	< 1				
3 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009849	Cooler	Basement	In hallway adjacent to Cafeteria Right Low	WT-042916-9866- A	< 1	WT-042916-9866- B	< 1				
4 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009850	Cooler	Basement	In Cafeteria	WT-042916-9867- A	< 1	WT-042916-9867- B	< 1				
5 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009851	Kitchen	Basement	In kitchen	WT-042916-9868- A	< 1	WT-042916-9868- B	< 1				
6 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009852	Kitchen	Basement	In kitchen	WT-042916-9869- A	< 1	WT-042916-9869- B	< 1				
7 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009853	Classroom	1	In room 102	WT-042916-9870- A	< 1	WT-042916-9870- B	< 1				
8 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009854	Classroom	1	In room 106	WT-042916-9871- A	< 1	WT-042916-9871- B	< 1				
9 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009855	Classroom	1	In room 116	WT-042916-9872- A	< 1	WT-042916-9872- B	< 1				
10 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009856	Classroom	1	In room 120	WT-042916-9873- A	< 1	WT-042916-9873- B	< 1				
11 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009857	Cooler	1	In hallway adjacent to health clinic 117 Left High	WT-042916-9874- A	< 1	WT-042916-9874- B	< 1				
12 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009858	Cooler	1	In hallway adjacent to health clinic 117 Right Low	WT-042916-9875- A	< 1	WT-042916-9875- B	< 1				
13 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009859	Cooler	1	In hallway across from room 106 Left High	WT-042916-9876- A	< 1	WT-042916-9876- B	< 1				
14 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009860	Cooler	1	In hallway across from the room 106 Right Low	WT-042916-9877- A	< 1	WT-042916-9877- B	< 1				
15 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009861	Classroom	1	In room 131 Left Low	WT-042916-9878- A	< 1	WT-042916-9878- B	< 1				
16 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009862	Classroom	1	In room 131 Right High	WT-042916-9879- A	< 1	WT-042916-9879- B	< 1				
17 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009863	Classroom	1	In room 132 Left High	WT-042916-9880- A	< 1	WT-042916-9880- B	< 1				
18 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009864	Classroom	1	In Room 132 Right Low	WT-042916-9881- A	< 1	WT-042916-9881- B	< 1				
19 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009865	Classroom	1	In room133 Left Low	WT-042916-9882- A	< 1	WT-042916-9882- B	< 1				
20 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009866	Classroom	1	In room 133 Right High	WT-042916-9883- A	< 1	WT-042916-9883- B	< 1				
21 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009867	Classroom	1	In room 134 Left High	WT-042916-9884- A	< 1	WT-042916-9884- B	< 1				
22 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009868	Classroom	1	In room 134 Right Low	WT-042916-9885- A	< 1	WT-042916-9885- B	< 1				
23 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009869	Classroom	1	In room 135 Left Low	WT-042916-9886- A	< 1	WT-042916-9886- B	< 1				
24 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009870	Classroom	1	In room 135 Right High	WT-042916-9887- A	< 1	WT-042916-9887- B	< 1				
25 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009871	Classroom	1	In room 136 Left High	WT-042916-9888- A	2.5	WT-042916-9888- B	< 1				
26 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009872	Classroom	1	In room 136 Right Low	WT-042916-9889- A	< 1	WT-042916-9889- B	< 1				
27 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009873	Other	2	Teacher work room	WT-042916-9890- A	< 1	WT-042916-9890- B	< 1				
28 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009874	Classroom	2	In room 207 Left	WT-042916-9891- A	< 1	WT-042916-9891- B	< 1				
29 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009875	Classroom	2	In room 207 Right	WT-042916-9892- A	< 1	WT-042916-9892- B	< 1				
30 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009876	Cooler	2	In hallway across from the room 207 Left High	WT-042916-9893- A	< 1	WT-042916-9893- B	< 1				
31 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009877	Cooler	2	In. Hallway across from the room 207 Right Low	WT-042916-9894- A	< 1	WT-042916-9894- B	< 1				
32 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009878	Cooler	2	In hallway across from the room 214 Left High	WT-042916-9895- A	< 1	WT-042916-9895- B	< 1				
33 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009879	Cooler	2	In hallway across from the room 214 Right Low	WT-042916-9896- A	< 1	WT-042916-9896- B	< 1				
34 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009880	Cooler	3	In hallway across from the room 307 Left High	WT-042916-9897- A	< 1	WT-042916-9897- B	< 1				
35 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009881	Cooler	3	In hallways across from the room 307 Right Low	WT-042916-9898- A	< 1	WT-042916-9898- B	< 1				
36 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009882	Break Room	3	In room 312	WT-042916-9899- A	< 1	WT-042916-9899- B	< 1				
37 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009883	Cooler	3	In hallways across from the room315 Left High	WT-042916-9900- A	< 1	WT-042916-9900- B	< 1				
38 STANTON ELEMENTARY SCHOOL	5/11/2016	WS- 009884	Cooler	3	In hallway across from the room 315 Right Low	WT-042916-9901- A	< 1	WT-042916-9901- B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.