



# STANTON ES LEAD WATER TEST RESULTS



## Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	STANTON ELEMENTARY SCHOOL	WS- 002536	12/26/2016	1	Break Room	In break room 130F	FT-102016-002536-A	< 1	FT-102016-002536-B	< 1
2	STANTON ELEMENTARY SCHOOL	WS- 009853	12/26/2016	1	Classroom Faucet	In classroom 102	FT-122016-009853-A	< 1	FT-122016-009853-B	< 1
3	STANTON ELEMENTARY SCHOOL	WS- 009854	12/26/2016	1	Classroom Faucet	In classroom 106	FT-122016-009854-A	< 1	FT-122016-009854-B	< 1
4	STANTON ELEMENTARY SCHOOL	WS- 009855	12/26/2016	1	Classroom Faucet	In classroom 116	FT-122016-009855-A	< 1	FT-122016-009855-B	< 1
5	STANTON ELEMENTARY SCHOOL	WS- 009856	12/26/2016	1	Classroom Faucet	In classroom 120	FT-122016-009856-A	< 1	FT-122016-009856-B	< 1
6	STANTON ELEMENTARY SCHOOL	WS- 009861	12/26/2016	1	Classroom Faucet	In classroom 131 Low Left	FT-122016-009861-A	< 1	FT-122016-009861-B	< 1
7	STANTON ELEMENTARY SCHOOL	WS- 009862	12/26/2016	1	Classroom Faucet	In classroom 131 High Right	FT-122016-009862-A	< 1	FT-122016-009862-B	< 1
8	STANTON ELEMENTARY SCHOOL	WS- 009863	12/26/2016	1	Classroom Faucet	In classroom 132 High Left	FT-122016-009863-A	< 1	FT-122016-009863-B	< 1
9	STANTON ELEMENTARY SCHOOL	WS- 009864	12/26/2016	1	Classroom Faucet	In classroom 132 Low Right	FT-122016-009864-A	< 1	FT-122016-009864-B	< 1
10	STANTON ELEMENTARY SCHOOL	WS- 009865	12/26/2016	1	Classroom Faucet	In classroom 133 Low Left	FT-122016-009865-A	< 1	FT-122016-009865-B	< 1
11	STANTON ELEMENTARY SCHOOL	WS- 009866	12/26/2016	1	Classroom Faucet	In classroom 133 High Right	FT-122016-009866-A	< 1	FT-122016-009866-B	< 1
12	STANTON ELEMENTARY SCHOOL	WS- 009867	12/26/2016	1	Classroom Faucet	In classroom 134 High Left	FT-122016-009867-A	< 1	FT-122016-009867-B	< 1
13	STANTON ELEMENTARY SCHOOL	WS- 009868	**	1	Classroom Faucet	In classroom 134 Low Right	FT-122016-009868-A	< 1	FT-122016-009868-B	< 1
14	STANTON ELEMENTARY SCHOOL	WS- 009869	12/27/2016	1	Classroom Faucet	In classroom 135 Low Left	FT-122016-009869-A	< 1	FT-122016-009869-B	< 1
15	STANTON ELEMENTARY SCHOOL	WS- 009870	12/27/2016	1	Classroom Faucet	In classroom 135 High Right	FT-122016-009870-A	< 1	FT-122016-009870-B	< 1
16	STANTON ELEMENTARY SCHOOL	WS- 009871	12/27/2016	1	Classroom Faucet	In classroom 136 High Left	FT-122016-009871-A	< 1	FT-122016-009871-B	< 1
17	STANTON ELEMENTARY SCHOOL	WS- 009872	12/27/2016	1	Classroom Faucet	In classroom 136 Low Right	FT-122016-009872-A	< 1	FT-122016-009872-B	< 1
18	STANTON ELEMENTARY SCHOOL	WS- 009873	12/27/2016	2	Break Room	In staff work room	FT-102016-009873-A	< 1	FT-102016-009873-B	< 1
19	STANTON ELEMENTARY SCHOOL	WS- 009874	12/27/2016	2	Classroom Faucet	In classroom 207 Left	FT-122016-009874-A	< 1	FT-122016-009874-B	< 1
20	STANTON ELEMENTARY SCHOOL	WS- 009875	12/27/2016	2	Classroom Faucet	In classroom 207 Right	FT-122016-009875-A	< 1	FT-122016-009875-B	< 1
21	STANTON ELEMENTARY SCHOOL	WS- 009882	12/27/2016	3	Break Room	In staff lounge 312	FT-102016-009882-A	< 1	FT-102016-009882-B	< 1

\*\* 1st draw and 2nd draw analyzed on 12/26/2016 and 12/27/2016, respectively.

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb