



Stanton ES Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002536	6/21/2017	6/21/2018	1	Break Room	In break room 130F	WF-62017-002536	11/21/2017	FT-FY18-62017-002536-A	<1	FT-FY18-62017-002536-B	<1
WS- 009850	6/21/2017	6/21/2018	Basement	Cooler	In cafeteria	WF-62017-009850	11/21/2017	FT-FY18-62017-009850-A	<1	FT-FY18-62017-009850-B	<1
WS- 009853	11/1/2017	11/1/2018	1	Classroom Faucet	In classroom 102	WF-112017-009853	11/21/2017	FT-FY18-112017-009853-A	<1	FT-FY18-112017-009853-B	<1
WS- 009854	11/1/2017	11/1/2018	1	Classroom Faucet	In classroom 106	WF-112017-009854	11/21/2017	FT-FY18-112017-009854-A	<1	FT-FY18-112017-009854-B	<1
WS- 009858	6/21/2017	6/21/2018	1	Cooler	In hallway adjacent to room 117	WF-62017-009858	11/21/2017	FT-FY18-62017-009858-A	<1	FT-FY18-62017-009858-B	<1
WS- 009859	6/21/2017	6/21/2018	1	Cooler	In hallway across from room 106	WF-62017-009859	11/21/2017	FT-FY18-62017-009859-A	<1	FT-FY18-62017-009859-B	<1
WS- 009867	11/1/2017	11/1/2018	1	Classroom Faucet	In classroom 134	WF-112017-009867	11/21/2017	FT-FY18-112017-009867-A	<1	FT-FY18-112017-009867-B	<1
WS- 009872	11/1/2017	11/1/2018	1	Classroom Faucet	In classroom 136	WF-112017-009872	11/21/2017	FT-FY18-112017-009872-A	1.3	FT-FY18-112017-009872-B	<1
WS- 009873	6/21/2017	6/21/2018	2	Break Room	In staff work room	WF-62017-009873	11/21/2017	FT-FY18-62017-009873-A	<1	FT-FY18-62017-009873-B	<1
WS- 009874	11/1/2017	11/1/2018	2	Classroom Faucet	In classroom 207	WF-112017-009874	11/21/2017	FT-FY18-112017-009874-A	<1	FT-FY18-112017-009874-B	<1
WS- 009882	6/21/2017	6/21/2018	3	Break Room	In staff lounge 312	WF-62017-009882	11/21/2017	FT-FY18-62017-009882-A	<1	FT-FY18-62017-009882-B	<1
WS- 009883	6/21/2017	6/21/2018	3	Cooler	In hallway across from room 315	WF-62017-009883	11/21/2017	FT-FY18-62017-009883-A	<1	FT-FY18-62017-009883-B	<1
WS- 009884	6/21/2017	6/21/2018	3	Cooler	In hallway across from room 315	WF-62017-009884	11/21/2017	FT-FY18-62017-009884-A	<1	FT-FY18-62017-009884-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation									
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009851	Basement	Food Prep Sink	In kitchen first clockwise from entry door	11/21/2017	FT-FY18-102017-009851-A	<1	FT-FY18-102017-009851-B	<1	