



Stanton ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002535	6/4/2018	6/4/2019	1	Health Suite	In health suite 101	WF-06042018-002535	11/6/2018	FT-FY19-102018-002535-A	< 1	FT-FY19-102018-002535-B	< 1
WS- 002536	6/4/2018	6/4/2019	1	Break Room	In break room 130F	WF-06042018-002536	11/6/2018	FT-FY19-102018-002536-A	< 1	FT-FY19-102018-002536-B	< 1
WS- 009848	6/4/2018	6/4/2019	Basement	Cooler	In hallway adjacent to cafeteria High Left	WF-06042018-009848	11/6/2018	FT-FY19-102018-009848-A	< 1	FT-FY19-102018-009848-B	< 1
WS- 009849	6/4/2018	6/4/2019	Basement	Cooler	In hallway adjacent to cafeteria Low Right	WF-06042018-009849	11/6/2018	FT-FY19-102018-009849-A	< 1	FT-FY19-102018-009849-B	< 1
WS- 009850	6/4/2018	6/4/2019	Basement	Cooler	In cafeteria	WF-06042018-009850	11/6/2018	FT-FY19-102018-009850-A	< 1	FT-FY19-102018-009850-B	< 1
WS- 009853	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 102	WF-10092018-009853	11/6/2018	FT-FY19-102018-009853-A	< 1	FT-FY19-102018-009853-B	< 1
WS- 009854	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 106	WF-10092018-009854	11/6/2018	FT-FY19-102018-009854-A	< 1	FT-FY19-102018-009854-B	< 1
WS- 009855	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 116	WF-10092018-009855	11/6/2018	FT-FY19-102018-009855-A	< 1	FT-FY19-102018-009855-B	< 1
WS- 009856	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 120	WF-10092018-009856	11/6/2018	FT-FY19-102018-009856-A	< 1	FT-FY19-102018-009856-B	< 1
WS- 009857	6/4/2018	6/4/2019	1	Cooler	In hallway across from room 116 High Left	WF-06042018-009857	11/6/2018	FT-FY19-102018-009857-A	< 1	FT-FY19-102018-009857-B	< 1
WS- 009858	6/4/2018	6/4/2019	1	Cooler	In hallway across from room 116 Low Right	WF-06042018-009858	11/6/2018	FT-FY19-102018-009858-A	< 1	FT-FY19-102018-009858-B	< 1
WS- 009859	6/4/2018	6/4/2019	1	Cooler	In hallway across from room 106 High Left	WF-06042018-009859	11/6/2018	FT-FY19-102018-009859-A	< 1	FT-FY19-102018-009859-B	< 1
WS- 009860	6/4/2018	6/4/2019	1	Cooler	In hallway across from room 106 Low Right	WF-06042018-009860	11/6/2018	FT-FY19-102018-009860-A	< 1	FT-FY19-102018-009860-B	< 1
WS- 009861	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 131 Low Left	WF-10092018-009861	11/6/2018	FT-FY19-102018-009861-A	< 1	FT-FY19-102018-009861-B	< 1
WS- 009862	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 131 High Right	WF-10092018-009862	11/6/2018	FT-FY19-102018-009862-A	< 1	FT-FY19-102018-009862-B	< 1
WS- 009863	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 132 High Left	WF-10092018-009863	11/6/2018	FT-FY19-102018-009863-A	< 1	FT-FY19-102018-009863-B	< 1
WS- 009864	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 132 Low Right	WF-10092018-009864	11/6/2018	FT-FY19-102018-009864-A	< 1	FT-FY19-102018-009864-B	< 1
WS- 009865	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 133 Low Left	WF-10092018-009865	11/6/2018	FT-FY19-102018-009865-A	< 1	FT-FY19-102018-009865-B	< 1
WS- 009866	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 133 High Right	WF-10092018-009866	11/6/2018	FT-FY19-102018-009866-A	< 1	FT-FY19-102018-009866-B	< 1
WS- 009867	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 134 High Left	WF-10092018-009867	11/6/2018	FT-FY19-102018-009867-A	< 1	FT-FY19-102018-009867-B	< 1
WS- 009868	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 134 Low Right	WF-10092018-009868	11/6/2018	FT-FY19-102018-009868-A	< 1	FT-FY19-102018-009868-B	< 1
WS- 009869	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 135 Low Left	WF-10092018-009869	11/6/2018	FT-FY19-102018-009869-A	< 1	FT-FY19-102018-009869-B	< 1
WS- 009870	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 135 High Right	WF-10092018-009870	11/6/2018	FT-FY19-102018-009870-A	< 1	FT-FY19-102018-009870-B	< 1
WS- 009871	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 136 High Left	WF-10092018-009871	11/6/2018	FT-FY19-102018-009871-A	< 1	FT-FY19-102018-009871-B	< 1
WS- 009872	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 136 Low Right	WF-10092018-009872	11/6/2018	FT-FY19-102018-009872-A	< 1	FT-FY19-102018-009872-B	< 1
WS- 009873	6/4/2018	6/4/2019	2	Break Room	In teacher workroom 223	WF-06042018-009873	11/6/2018	FT-FY19-102018-009873-A	< 1	FT-FY19-102018-009873-B	< 1
WS- 009874	10/9/2018	10/9/2019	2	Classroom Faucet	In classroom 207 Left	WF-10092018-009874	11/6/2018	FT-FY19-102018-009874-A	< 1	FT-FY19-102018-009874-B	< 1
WS- 009875	10/9/2018	10/9/2019	2	Classroom Faucet	In classroom 207 Right	WF-10092018-009875	11/6/2018	FT-FY19-102018-009875-A	< 1	FT-FY19-102018-009875-B	< 1
WS- 009876	6/4/2018	6/4/2019	2	Cooler	In hallway across from room 207 High Left	WF-06042018-009876	11/6/2018	FT-FY19-102018-009876-A	< 1	FT-FY19-102018-009876-B	< 1
WS- 009877	6/4/2018	6/4/2019	2	Cooler	In hallway across from room 207 Low Right	WF-06042018-009877	11/6/2018	FT-FY19-102018-009877-A	< 1	FT-FY19-102018-009877-B	< 1

WS- 009878	6/4/2018	6/4/2019	2	Cooler	In hallway across from room 214	High	Left	WF-06042018-009878	11/6/2018	FT-FY19-102018-009878-A	< 1	FT-FY19-102018-009878-B	< 1
WS- 009879	6/4/2018	6/4/2019	2	Cooler	In hallway across from room 214	Low	Right	WF-06042018-009879	11/6/2018	FT-FY19-102018-009879-A	< 1	FT-FY19-102018-009879-B	< 1
WS- 009880	6/4/2018	6/4/2019	3	Cooler	In hallway across from room 307	High	Left	WF-06042018-009880	11/6/2018	FT-FY19-102018-009880-A	< 1	FT-FY19-102018-009880-B	< 1
WS- 009881	6/4/2018	6/4/2019	3	Cooler	In hallway across from room 307	Low	Right	WF-06042018-009881	11/6/2018	FT-FY19-102018-009881-A	< 1	FT-FY19-102018-009881-B	< 1
WS- 009882	6/4/2018	6/4/2019	3	Break Room	In staff lounge 312			WF-06042018-009882	11/6/2018	FT-FY19-102018-009882-A	< 1	FT-FY19-102018-009882-B	< 1
WS- 009883	6/4/2018	6/4/2019	3	Cooler	In hallway across from room 315	High	Left	WF-06042018-009883	11/6/2018	FT-FY19-102018-009883-A	< 1	FT-FY19-102018-009883-B	< 1
WS- 009884	6/4/2018	6/4/2019	3	Cooler	In hallway across from room 315	Low	Right	WF-06042018-009884	11/6/2018	FT-FY19-102018-009884-A	< 1	FT-FY19-102018-009884-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation										
Record ID	Floor	Device Type	Device Location			Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009851	Basement	Food Prep Sink	In kitchen first clockwise from entry door			11/6/2018	FT-FY19-102018-009851-A	< 1	FT-FY19-102018-009851-B	< 1