



Stead RC Lead Water Test Results



FY18 Filter Test

| Less than 5 ppb - Devices Requiring No Remediation | | | | | | | | | | | |
|--|-----------------------|------------------------|-------|-------------|------------------|--------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| RECORD ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | WATER FILTERS Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
| WS- 006537 | 6/30/2017 | 6/30/2018 | 1 | Cooler | In computer room | WF-62017-006537 | 1/23/2018 | FT-FY18--62017-006537-A | <1 | FT-FY18--62017-006537-B | <1 |

Food Prep Sink

| Less than 5 ppb - Devices Requiring No Remediation | | | | | | | | | | | |
|--|-----------------------|------------------------|-------|----------------|-----------------|--------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| RECORD ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | WATER FILTERS Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
| WS- 006536 | 6/30/2017 | 6/30/2018 | 2 | Food Prep Sink | In kitchen | WF-62017-006536 | 1/23/2018 | FT-FY18--62017-006536-A | <1 | FT-FY18--62017-006536-B | <1 |