Stoddert ES Lead in Water Test Results

FY27 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002306	8/29/2025	8/29/2026	1	Health Suite	In health suite in treatment room 117 Left	WF-08292025-002306	8/13/2026	FT-FY27-08022026-002306-A	1.3	FT-FY27-08022026-002306-B	<1
WS- 002307	2/27/2026	2/27/2027	1	Bathroom	In classroom 119 in bathroom	WF-02272026-002307	8/13/2026	FT-FY27-08022026-002307-A	<1	FT-FY27-08022026-002307-B	<1
WS- 002308	2/27/2026	2/27/2027	1	Bathroom	In classroom 132 in bathroom	WF-02272026-002308	8/13/2026	FT-FY27-08022026-002308-A	<1	FT-FY27-08022026-002308-B	<1
WS- 002309	2/27/2026	2/27/2027	1	Bathroom	In classroom 133 in bathroom	WF-02272026-002309	8/13/2026	FT-FY27-08022026-002309-A	<1	FT-FY27-08022026-002309-B	<1
WS- 002310	2/27/2026	2/27/2027	1	Bathroom	In classroom 134 in bathroom	WF-02272026-002310	8/13/2026	FT-FY27-08022026-002310-A	<1	FT-FY27-08022026-002310-B	<1
WS- 002311	2/27/2026	2/27/2027	1	Bottle Filler	In hallway adjacent to restrooms	WF-02272026-002311	8/13/2026	FT-FY27-08022026-002311-A	<1	FT-FY27-08022026-002311-B	<1
WS- 002318	2/27/2026	2/27/2027	1	Combo Fountain	In treatment room 117 in health suite Right	WF-02272026-002318	8/13/2026	FT-FY27-08022026-002318-A	<1	FT-FY27-08022026-002318-B	<1
WS- 003469	2/27/2026	2/27/2027	2	Bottle Filler	In hallway adjacent to restrooms	WF-02272026-003469	8/13/2026	FT-FY27-08022026-003469-A	<1	FT-FY27-08022026-003469-B	<1
WS- 003615	8/21/2025	8/21/2026	1	Combo Faucet	In classroom 132	WF-08212025-003615	8/13/2026	FT-FY27-08022026-003615-A	<1	FT-FY27-08022026-003615-B	<1
WS- 003616	2/27/2026	2/27/2027	1	Combo Fountain	In classroom 132	WF-02272026-003616	8/13/2026	FT-FY27-08022026-003616-A	1.1	FT-FY27-08022026-003616-B	<1
WS- 003617	8/21/2025	8/21/2026	1	Combo Faucet	In classroom 133	WF-08212025-003617	8/13/2026	FT-FY27-08022026-003617-A	<1	FT-FY27-08022026-003617-B	<1
WS- 003618	2/27/2026	2/27/2027	1	Combo Fountain	In classroom 133	WF-02272026-003618	8/13/2026	FT-FY27-08022026-003618-A	<1	FT-FY27-08022026-003618-B	<1
WS- 003619	8/21/2025	8/21/2026	1	Combo Faucet	In classroom 134	WF-08212025-003619	8/13/2026	FT-FY27-08022026-003619-A	<1	FT-FY27-08022026-003619-B	<1
WS- 003620	2/27/2026	2/27/2027	1	Combo Fountain	In classroom 134	WF-02272026-003620	8/13/2026	FT-FY27-08022026-003620-A	<1	FT-FY27-08022026-003620-B	<1
WS- 003622	2/27/2026	2/27/2027	1	Combo Fountain	In classroom 142	WF-02272026-003622	8/13/2026	FT-FY27-08022026-003622-A	<1	FT-FY27-08022026-003622-B	<1
WS- 003624	2/27/2026	2/27/2027	1	Combo Fountain	In classroom 144	WF-02272026-003624	8/13/2026	FT-FY27-08022026-003624-A	<1	FT-FY27-08022026-003624-B	<1
WS- 003626	2/27/2026	2/27/2027	1	Combo Fountain	In classroom 147	WF-02272026-003626	8/13/2026	FT-FY27-08022026-003626-A	<1	FT-FY27-08022026-003626-B	<1
WS- 003628	2/27/2026	2/27/2027	1	Combo Fountain	In classroom 146	WF-02272026-003628	8/13/2026	FT-FY27-08022026-003628-A	<1	FT-FY27-08022026-003628-B	<1
WS- 003630	2/27/2026	2/27/2027	1	Combo Fountain	In classroom 145	WF-02272026-003630	8/13/2026	FT-FY27-08022026-003630-A	<1	FT-FY27-08022026-003630-B	<1
WS- 003631	2/27/2026	2/27/2027	1	Cooler	In hallway adjacent to restrooms High Left	WF-02272026-003631	8/13/2026	FT-FY27-08022026-003631-A	<1	FT-FY27-08022026-003631-B	<1
WS- 003632	2/27/2026	2/27/2027	1	Cooler	In hallway adjacent to restrooms Low Right	WF-02272026-003632	8/13/2026	FT-FY27-08022026-003632-A	<1	FT-FY27-08022026-003632-B	<1
WS- 003633	2/27/2026	2/27/2027	2	Cooler	In hallway adjacent to restrooms High Left	WF-02272026-003633	8/13/2026	FT-FY27-08022026-003633-A	<1	FT-FY27-08022026-003633-B	<1
WS- 003634	2/27/2026	2/27/2027	2	Cooler	In hallway adjacent to restrooms Low Right	WF-02272026-003634	8/13/2026	FT-FY27-08022026-003634-A	<1	FT-FY27-08022026-003634-B	<1
WS- 003636	2/27/2026	2/27/2027	2	Combo Fountain	In classroom 227 first clockwise from entry door	WF-02272026-003636	8/13/2026	FT-FY27-08022026-003636-A	1.5	FT-FY27-08022026-003636-B	<1
WS- 003638	2/27/2026	2/27/2027	2	Combo Fountain	In classroom 227 second clockwise from entry door Mid	WF-02272026-003638	8/13/2026	FT-FY27-08022026-003638-A	<1	FT-FY27-08022026-003638-B	<1
WS- 003640	2/27/2026	2/27/2027	2	Combo Fountain	In classroom 227 third clockwise from entry door	WF-02272026-003640	8/13/2026	FT-FY27-08022026-003640-A	1.4	FT-FY27-08022026-003640-B	<1
WS- 003642	2/27/2026	2/27/2027	2	Combo Fountain	In classroom 247	WF-02272026-003642	8/13/2026	FT-FY27-08022026-003642-A	2.2	FT-FY27-08022026-003642-B	<1
WS- 003644	2/27/2026	2/27/2027	2	Combo Fountain	In classroom 244	WF-02272026-003644	8/13/2026	FT-FY27-08022026-003644-A	<1	FT-FY27-08022026-003644-B	<1
WS- 003646	2/27/2026	2/27/2027	2	Combo Fountain	In classroom 245	WF-02272026-003646	8/13/2026	FT-FY27-08022026-003646-A	1.2	FT-FY27-08022026-003646-B	<1
WS- 003649	2/27/2026	2/27/2027	2	Break Room	In break room 230	WF-02272026-003649	8/13/2026	FT-FY27-08022026-003649-A	<1	FT-FY27-08022026-003649-B	<1
WS- 003652	2/27/2026	2/27/2027	2	Combo Fountain	In classroom 231	WF-02272026-003652	8/13/2026	FT-FY27-08022026-003652-A	<1	FT-FY27-08022026-003652-B	<1
WS- 003654	2/27/2026	2/27/2027	2	Combo Fountain	In classroom 232	WF-02272026-003654	8/13/2026	FT-FY27-08022026-003654-A	<1	FT-FY27-08022026-003654-B	<1
WS- 003656	2/27/2026	2/27/2027	2	Combo Fountain	In classroom 233	WF-02272026-003656	8/13/2026	FT-FY27-08022026-003656-A	<1	FT-FY27-08022026-003656-B	<1
WS- 003658	2/27/2026	2/27/2027	2	Combo Fountain	In classroom 234	WF-02272026-003658	8/13/2026	FT-FY27-08022026-003658-A	<1	FT-FY27-08022026-003658-B	<1

WS- 005118	2/27/2026	2/27/2027	1	Bottle Filler	In hallway adjacent to 1310 boy's restroom			WF-02272026-005118	8/13/2026	FT-FY27-08022026-005118-A	<1	FT-FY27-08022026-005118-B	<1
WS- 005119	2/27/2026	2/27/2027	1	Cooler	In hallway adjacent to 1310 boy's restroom	High	Left	WF-02272026-005119	8/13/2026	FT-FY27-08022026-005119-A	<1	FT-FY27-08022026-005119-B	<1
WS- 005120	2/27/2026	2/27/2027	1	Cooler	In hallway adjacent to 1310 boy's restroom	Low	Right	WF-02272026-005120	8/13/2026	FT-FY27-08022026-005120-A	<1	FT-FY27-08022026-005120-B	<1
WS- 005122	2/27/2026	2/27/2027	1	Combo Fountain	In room 108			WF-02272026-005122	8/13/2026	FT-FY27-08022026-005122-A	<1	FT-FY27-08022026-005122-B	<1
WS- 005124	2/27/2026	2/27/2027	1	Combo Fountain	In room 107			WF-02272026-005124	8/13/2026	FT-FY27-08022026-005124-A	<1	FT-FY27-08022026-005124-B	<1
WS- 005126	2/27/2026	2/27/2027	1	Combo Fountain	In room 106			WF-02272026-005126	8/13/2026	FT-FY27-08022026-005126-A	<1	FT-FY27-08022026-005126-B	<1
WS- 005127	2/27/2026	2/27/2027	1	Bottle Filler	In hallway adjacent to 1312 storage			WF-02272026-005127	8/13/2026	FT-FY27-08022026-005127-A	<1	FT-FY27-08022026-005127-B	<1
WS- 005128	2/27/2026	2/27/2027	1	Cooler	In hallway adjacent to 1312 storage	High	Left	WF-02272026-005128	8/13/2026	FT-FY27-08022026-005128-A	<1	FT-FY27-08022026-005128-B	<1
WS- 005129	2/27/2026	2/27/2027	1	Cooler	In hallway adjacent to 1312 storage	Low	Right	WF-02272026-005129	8/13/2026	FT-FY27-08022026-005129-A	<1	FT-FY27-08022026-005129-B	<1
WS- 005146	2/27/2026	2/27/2027	1	Combo Fountain	In room 105			WF-02272026-005146	8/13/2026	FT-FY27-08022026-005146-A	<1	FT-FY27-08022026-005146-B	<1
WS- 005148	2/27/2026	2/27/2027	1	Combo Fountain	In room 104			WF-02272026-005148	8/13/2026	FT-FY27-08022026-005148-A	<1	FT-FY27-08022026-005148-B	<1
WS- 005149	2/27/2026	2/27/2027	2	Bottle Filler	In hallway adjacent to 2311 boy's restroom			WF-02272026-005149	8/13/2026	FT-FY27-08022026-005149-A	<1	FT-FY27-08022026-005149-B	<1
WS- 005153	2/27/2026	2/27/2027	2	Cooler	in hallway adjacent to 2311 boy's restroom	High	Left	WF-02272026-005153	8/13/2026	FT-FY27-08022026-005153-A	<1	FT-FY27-08022026-005153-B	<1
WS- 005154	2/27/2026	2/27/2027	2	Cooler	in hallway adjacent to 2311 boy's restroom	Low	Right	WF-02272026-005154	8/13/2026	FT-FY27-08022026-005154-A	<1	FT-FY27-08022026-005154-B	<1
WS- 005156	2/27/2026	2/27/2027	2	Combo Fountain	In room 210			WF-02272026-005156	8/13/2026	FT-FY27-08022026-005156-A	<1	FT-FY27-08022026-005156-B	<1
WS- 005158	2/27/2026	2/27/2027	2	Combo Fountain	In room 209			WF-02272026-005158	8/13/2026	FT-FY27-08022026-005158-A	<1	FT-FY27-08022026-005158-B	<1
WS- 005160	2/27/2026	2/27/2027	2	Combo Fountain	In room 208			WF-02272026-005160	8/13/2026	FT-FY27-08022026-005160-A	<1	FT-FY27-08022026-005160-B	<1
WS- 005162	2/27/2026	2/27/2027	2	Combo Fountain	In room 207			WF-02272026-005162	8/13/2026	FT-FY27-08022026-005162-A	<1	FT-FY27-08022026-005162-B	<1
WS- 005164	2/27/2026	2/27/2027	2	Combo Fountain	In room 206			WF-02272026-005164	8/13/2026	FT-FY27-08022026-005164-A	<1	FT-FY27-08022026-005164-B	<1
WS- 006303	7/27/2026	7/27/2027	1	Bottle Filler	In cafeteria			WF-07272026-006303	8/13/2026	FT-FY27-08022026-006303-A	<1	FT-FY27-08022026-006303-B	<1
WS- 006304	7/27/2026	7/27/2027	1	Cooler	In cafeteria	High	Left	WF-07272026-006304	8/13/2026	FT-FY27-08022026-006304-A	<1	FT-FY27-08022026-006304-B	<1
WS- 006305	7/27/2026	7/27/2027	1	Cooler	In cafeteria	Low	Right	WF-07272026-006305	8/13/2026	FT-FY27-08022026-006305-A	<1	FT-FY27-08022026-006305-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation										
Record ID	**Filter Installed Date**	**Filter Expiration Date**	**Floor**	**Device Type**	**Device Location**	**Water Filter's Name**	**Date Analyzed**	**1st Draw - Sample ID**	**FT Final Result - 1st Draw (ppb)**	**2nd Draw - Sample ID**	**FT Final Result - 2nd Draw (ppb)**
WS- 006308	7/27/2026	7/27/2027	1	Food Prep Sink	In back of kitchen	WF-07272026-006308	8/13/2026	FT-FY27-08022026-006308-A	<1	FT-FY27-08022026-006308-B	<1