



Stoddert Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002306	3/31/2021	3/31/2022	1	Health Suite	In health suite in treatment room 117 Left	WF-03312021-002306	12/10/2021	FT-FY22-11222021-002306-A	2.5	FT-FY22-11222021-002306-B	2.3
WS-002307	3/31/2021	3/31/2022	1	Bathroom	In classroom 119 in bathroom	WF-03312021-002307	12/10/2021	FT-FY22-11222021-002307-A	<1	FT-FY22-11222021-002307-B	<1
WS-002308	3/31/2021	3/31/2022	1	Bathroom	In classroom 132 in bathroom	WF-03312021-002308	12/10/2021	FT-FY22-11222021-002308-A	<1	FT-FY22-11222021-002308-B	<1
WS-002309	3/31/2021	3/31/2022	1	Bathroom	In classroom 133 in bathroom	WF-03312021-002309	12/10/2021	FT-FY22-11222021-002309-A	<1	FT-FY22-11222021-002309-B	<1
WS-002310	3/31/2021	3/31/2022	1	Bathroom	In classroom 134 in bathroom	WF-03312021-002310	12/10/2021	FT-FY22-11222021-002310-A	<1	FT-FY22-11222021-002310-B	<1
WS-002311	3/31/2021	3/31/2022	1	Bottle Filler	In hallway adjacent to restrooms	WF-03312021-002311	12/10/2021	FT-FY22-11222021-002311-A	<1	FT-FY22-11222021-002311-B	<1
WS-002318	3/31/2021	3/31/2022	1	Combo Fountain	In treatment room 117 in health suite Right	WF-03312021-002318	12/10/2021	FT-FY22-11222021-002318-A	4.0	FT-FY22-11222021-002318-B	2.8
WS-003614	3/31/2021	3/31/2022	1	Combo Fountain	In classroom 131	WF-03312021-003614	12/10/2021	FT-FY22-11222021-003614-A	<1	FT-FY22-11222021-003614-B	<1
WS-003615	9/13/2021	9/13/2022	1	Combo Faucet	In classroom 132	WF-09132021-003615	12/10/2021	FT-FY22-11222021-003615-A	<1	FT-FY22-11222021-003615-B	<1
WS-003616	3/31/2021	3/31/2022	1	Combo Fountain	In classroom 132	WF-03312021-003616	12/10/2021	FT-FY22-11222021-003616-A	<1	FT-FY22-11222021-003616-B	<1
WS-003617	9/13/2021	9/13/2022	1	Combo Faucet	In classroom 133	WF-09132021-003617	12/10/2021	FT-FY22-11222021-003617-A	<1	FT-FY22-11222021-003617-B	<1
WS-003618	3/31/2021	3/31/2022	1	Combo Fountain	In classroom 133	WF-03312021-003618	12/10/2021	FT-FY22-11222021-003618-A	<1	FT-FY22-11222021-003618-B	<1
WS-003619	9/13/2021	9/13/2022	1	Combo Faucet	In classroom 134	WF-09132021-003619	12/10/2021	FT-FY22-11222021-003619-A	<1	FT-FY22-11222021-003619-B	<1
WS-003620	3/31/2021	3/31/2022	1	Combo Fountain	In classroom 134	WF-03312021-003620	12/10/2021	FT-FY22-11222021-003620-A	<1	FT-FY22-11222021-003620-B	<1
WS-003622	3/31/2021	3/31/2022	1	Combo Fountain	In classroom 142	WF-03312021-003622	12/10/2021	FT-FY22-11222021-003622-A	<1	FT-FY22-11222021-003622-B	<1
WS-003624	3/31/2021	3/31/2022	1	Combo Fountain	In classroom 144	WF-03312021-003624	12/10/2021	FT-FY22-11222021-003624-A	<1	FT-FY22-11222021-003624-B	<1
WS-003626	3/31/2021	3/31/2022	1	Combo Fountain	In classroom 147	WF-03312021-003626	12/10/2021	FT-FY22-11222021-003626-A	<1	FT-FY22-11222021-003626-B	<1
WS-003628	3/31/2021	3/31/2022	1	Combo Fountain	In classroom 146	WF-03312021-003628	12/10/2021	FT-FY22-11222021-003628-A	<1	FT-FY22-11222021-003628-B	<1
WS-003630	3/31/2021	3/31/2022	1	Combo Fountain	In classroom 145	WF-03312021-003630	12/10/2021	FT-FY22-11222021-003630-A	<1	FT-FY22-11222021-003630-B	<1
WS-003631	3/31/2021	3/31/2022	1	Cooler	In hallway adjacent to restrooms High Left	WF-03312021-003631	12/10/2021	FT-FY22-11222021-003631-A	<1	FT-FY22-11222021-003631-B	<1
WS-003632	3/31/2021	3/31/2022	1	Cooler	In hallway adjacent to restrooms Low Right	WF-03312021-003632	12/10/2021	FT-FY22-11222021-003632-A	<1	FT-FY22-11222021-003632-B	<1
WS-003633	3/31/2021	3/31/2022	2	Cooler	In hallway adjacent to restrooms High Left	WF-03312021-003633	12/10/2021	FT-FY22-11222021-003633-A	<1	FT-FY22-11222021-003633-B	<1
WS-003634	3/31/2021	3/31/2022	2	Cooler	In hallway adjacent to restrooms Low Right	WF-03312021-003634	12/10/2021	FT-FY22-11222021-003634-A	<1	FT-FY22-11222021-003634-B	<1
WS-003636	3/31/2021	3/31/2022	2	Combo Fountain	In classroom 227 first clockwise from entry door	WF-03312021-003636	12/10/2021	FT-FY22-11222021-003636-A	<1	FT-FY22-11222021-003636-B	<1
WS-003638	3/31/2021	3/31/2022	2	Combo Fountain	In classroom 227 second clockwise from entry door Mid	WF-03312021-003638	12/10/2021	FT-FY22-11222021-003638-A	<1	FT-FY22-11222021-003638-B	<1
WS-003640	3/31/2021	3/31/2022	2	Combo Fountain	In classroom 227 third clockwise from entry door	WF-03312021-003640	12/10/2021	FT-FY22-11222021-003640-A	<1	FT-FY22-11222021-003640-B	<1
WS-003642	3/31/2021	3/31/2022	2	Combo Fountain	In classroom 247	WF-03312021-003642	12/10/2021	FT-FY22-11222021-003642-A	<1	FT-FY22-11222021-003642-B	<1
WS-003644	3/31/2021	3/31/2022	2	Combo Fountain	In classroom 244	WF-03312021-003644	12/10/2021	FT-FY22-11222021-003644-A	<1	FT-FY22-11222021-003644-B	<1
WS-003646	3/31/2021	3/31/2022	2	Combo Fountain	In classroom 245	WF-03312021-003646	12/10/2021	FT-FY22-11222021-003646-A	<1	FT-FY22-11222021-003646-B	<1
WS-003648	3/31/2021	3/31/2022	2	Combo Fountain	In classroom 246	WF-03312021-003648	12/10/2021	FT-FY22-11222021-003648-A	<1	FT-FY22-11222021-003648-B	<1
WS-003649	3/31/2021	3/31/2022	2	Break Room	In break room 230	WF-03312021-003649	12/10/2021	FT-FY22-11222021-003649-A	<1	FT-FY22-11222021-003649-B	<1
WS-003650	3/31/2021	3/31/2022	2	Combo Fountain	In break room 230	WF-03312021-003650	12/10/2021	FT-FY22-11222021-003650-A	<1	FT-FY22-11222021-003650-B	<1
WS-003652	3/31/2021	3/31/2022	2	Combo Fountain	In classroom 231	WF-03312021-003652	12/10/2021	FT-FY22-11222021-003652-A	<1	FT-FY22-11222021-003652-B	<1
WS-003654	3/31/2021	3/31/2022	2	Combo Fountain	In classroom 232	WF-03312021-003654	12/10/2021	FT-FY22-11222021-003654-A	<1	FT-FY22-11222021-003654-B	<1
WS-003656	3/31/2021	3/31/2022	2	Combo Fountain	In classroom 233	WF-03312021-003656	12/10/2021	FT-FY22-11222021-003656-A	<1	FT-FY22-11222021-003656-B	<1
WS-003658	3/31/2021	3/31/2022	2	Combo Fountain	In classroom 234	WF-03312021-003658	12/10/2021	FT-FY22-11222021-003658-A	<1	FT-FY22-11222021-003658-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003608	1/26/2021	1/26/2022	1	Food Prep Sink	In kitchen	WF-01262021-003608	12/10/2021	FT-FY22-11222021-003608-A	<1	FT-FY22-11222021-003608-B	<1
WS-003609	1/26/2021	1/26/2022	1	Food Prep Sink	In servers room 127A in kitchen third clockwise from entry door	WF-01262021-003609	12/10/2021	FT-FY22-11222021-003609-A	<1	FT-FY22-11222021-003609-B	<1