



# Stoddert Elementary School Lead in Water Test Results

## FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002307	3/22/2022	3/22/2023	1	Bathroom	In classroom 119 in bathroom	WF-03222022-002307	1/9/2023	FT-FY23-11182022-002307-A	<1	FT-FY23-11182022-002307-B	<1
WS-002308	3/22/2022	3/22/2023	1	Bathroom	In classroom 132 in bathroom	WF-03222022-002308	1/9/2023	FT-FY23-11182022-002308-A	<1	FT-FY23-11182022-002308-B	<1
WS-002309	3/22/2022	3/22/2023	1	Bathroom	In classroom 133 in bathroom	WF-03222022-002309	1/9/2023	FT-FY23-11182022-002309-A	<1	FT-FY23-11182022-002309-B	<1
WS-002310	3/22/2022	3/22/2023	1	Bathroom	In classroom 134 in bathroom	WF-03222022-002310	1/9/2023	FT-FY23-11182022-002310-A	<1	FT-FY23-11182022-002310-B	<1
WS-002311	3/22/2022	3/22/2023	1	Bottle Filler	In hallway adjacent to restrooms	WF-03222022-002311	1/9/2023	FT-FY23-11182022-002311-A	<1	FT-FY23-11182022-002311-B	<1
WS-002318	3/22/2022	3/22/2023	1	Combo Fountain	In treatment room 117 in health suite	Right WF-03222022-002318	1/9/2023	FT-FY23-11182022-002318-A	<1	FT-FY23-11182022-002318-B	<1
WS-003614	3/22/2022	3/22/2023	1	Combo Fountain	In classroom 131	WF-03222022-003614	1/9/2023	FT-FY23-11182022-003614-A	<1	FT-FY23-11182022-003614-B	<1
WS-003615	9/6/2022	9/6/2023	1	Combo Faucet	In classroom 132	WF-09062022-003615	1/9/2023	FT-FY23-11182022-003615-A	4.4	FT-FY23-11182022-003615-B	<1
WS-003616	3/22/2022	3/22/2023	1	Combo Fountain	In classroom 132	WF-03222022-003616	1/9/2023	FT-FY23-11182022-003616-A	<1	FT-FY23-11182022-003616-B	<1
WS-003617	9/6/2022	9/6/2023	1	Combo Faucet	In classroom 133	WF-09062022-003617	1/9/2023	FT-FY23-11182022-003617-A	<1	FT-FY23-11182022-003617-B	<1
WS-003618	3/22/2022	3/22/2023	1	Combo Fountain	In classroom 133	WF-03222022-003618	1/9/2023	FT-FY23-11182022-003618-A	<1	FT-FY23-11182022-003618-B	<1
WS-003619	9/6/2022	9/6/2023	1	Combo Faucet	In classroom 134	WF-09062022-003619	1/9/2023	FT-FY23-11182022-003619-A	<1	FT-FY23-11182022-003619-B	<1
WS-003620	3/22/2022	3/22/2023	1	Combo Fountain	In classroom 134	WF-03222022-003620	1/9/2023	FT-FY23-11182022-003620-A	<1	FT-FY23-11182022-003620-B	<1
WS-003622	3/22/2022	3/22/2023	1	Combo Fountain	In classroom 142	WF-03222022-003622	1/9/2023	FT-FY23-11182022-003622-A	<1	FT-FY23-11182022-003622-B	<1
WS-003624	3/22/2022	3/22/2023	1	Combo Fountain	In classroom 144	WF-03222022-003624	1/9/2023	FT-FY23-11182022-003624-A	<1	FT-FY23-11182022-003624-B	<1
WS-003626	3/22/2022	3/22/2023	1	Combo Fountain	In classroom 147	WF-03222022-003626	1/9/2023	FT-FY23-11182022-003626-A	<1	FT-FY23-11182022-003626-B	<1
WS-003630	3/22/2022	3/22/2023	1	Combo Fountain	In classroom 145	WF-03222022-003630	1/9/2023	FT-FY23-11182022-003630-A	<1	FT-FY23-11182022-003630-B	<1
WS-003631	3/22/2022	3/22/2023	1	Cooler	In hallway adjacent to restrooms	High Left WF-03222022-003631	1/9/2023	FT-FY23-11182022-003631-A	<1	FT-FY23-11182022-003631-B	<1
WS-003632	3/22/2022	3/22/2023	1	Cooler	In hallway adjacent to restrooms	Low Right WF-03222022-003632	1/9/2023	FT-FY23-11182022-003632-A	<1	FT-FY23-11182022-003632-B	<1
WS-003633	10/7/2022	10/7/2023	2	Cooler	In hallway adjacent to restrooms	High Left WF-10072022-003633	1/9/2023	FT-FY23-11182022-003633-A	<1	FT-FY23-11182022-003633-B	<1
WS-003634	10/7/2022	10/7/2023	2	Cooler	In hallway adjacent to restrooms	Low Right WF-10072022-003634	1/9/2023	FT-FY23-11182022-003634-A	<1	FT-FY23-11182022-003634-B	<1
WS-003636	3/22/2022	3/22/2023	2	Combo Fountain	In classroom 227 first clockwise from entry door	WF-03222022-003636	1/9/2023	FT-FY23-11182022-003636-A	<1	FT-FY23-11182022-003636-B	<1
WS-003638	3/22/2022	3/22/2023	2	Combo Fountain	In classroom 227 second clockwise from entry door	Mid WF-03222022-003638	1/9/2023	FT-FY23-11182022-003638-A	<1	FT-FY23-11182022-003638-B	<1
WS-003640	3/22/2022	3/22/2023	2	Combo Fountain	In classroom 227 third clockwise from entry door	WF-03222022-003640	1/9/2023	FT-FY23-11182022-003640-A	<1	FT-FY23-11182022-003640-B	<1
WS-003642	3/22/2022	3/22/2023	2	Combo Fountain	In classroom 247	WF-03222022-003642	1/9/2023	FT-FY23-11182022-003642-A	<1	FT-FY23-11182022-003642-B	<1
WS-003644	3/22/2022	3/22/2023	2	Combo Fountain	In classroom 244	WF-03222022-003644	1/9/2023	FT-FY23-11182022-003644-A	<1	FT-FY23-11182022-003644-B	<1
WS-003646	3/22/2022	3/22/2023	2	Combo Fountain	In classroom 245	WF-03222022-003646	1/9/2023	FT-FY23-11182022-003646-A	<1	FT-FY23-11182022-003646-B	<1
WS-003648	3/22/2022	3/22/2023	2	Combo Fountain	In classroom 246	WF-03222022-003648	1/9/2023	FT-FY23-11182022-003648-A	<1	FT-FY23-11182022-003648-B	<1
WS-003649	3/22/2022	3/22/2023	2	Break Room	In break room 230	WF-03222022-003649	1/9/2023	FT-FY23-11182022-003649-A	<1	FT-FY23-11182022-003649-B	<1
WS-003652	3/22/2022	3/22/2023	2	Combo Fountain	In classroom 231	WF-03222022-003652	1/9/2023	FT-FY23-11182022-003652-A	<1	FT-FY23-11182022-003652-B	<1
WS-003654	3/22/2022	3/22/2023	2	Combo Fountain	In classroom 232	WF-03222022-003654	1/9/2023	FT-FY23-11182022-003654-A	<1	FT-FY23-11182022-003654-B	<1
WS-003656	3/22/2022	3/22/2023	2	Combo Fountain	In classroom 233	WF-03222022-003656	1/9/2023	FT-FY23-11182022-003656-A	<1	FT-FY23-11182022-003656-B	<1
WS-003658	3/22/2022	3/22/2023	2	Combo Fountain	In classroom 234	WF-03222022-003658	1/9/2023	FT-FY23-11182022-003658-A	<1	FT-FY23-11182022-003658-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003608	1/19/2022	1/19/2023	1	Food Prep Sink	In kitchen	WF-01192022-003608	1/9/2023	FT-FY23-11182022-003608-A	<1	FT-FY23-11182022-003608-B	<1
WS-003609	1/19/2022	1/19/2023	1	Food Prep Sink	In servers room 127A in kitchen third clockwise from entry door	WF-01192022-003609	1/9/2023	FT-FY23-11182022-003609-A	<1	FT-FY23-11182022-003609-B	<1

### FY23 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002306	3/22/2022	3/22/2023	1	Health Suite	In health suite in treatment room 117	Left WF-03222022-002306	1/9/2023	FT-FY23-11182022-002306-A	8.6	FT-FY23-11182022-002306-B	2.6