



# Stoddert ES Lead in Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002306	4/16/2019	4/16/2020	1	Health Suite	In health suite in treatment room 117	Left	WF-04162019-002306	12/1/2019	FT-FY20-112019-002306-A	4.1	FT-FY20-112019-002306-B	<1
WS-002307	4/16/2019	4/16/2020	1	Bathroom	In classroom 119 in bathroom		WF-04162019-002307	12/1/2019	FT-FY20-112019-002307-A	<1	FT-FY20-112019-002307-B	<1
WS-002308	4/16/2019	4/16/2020	1	Bathroom	In classroom 132 in bathroom		WF-04162019-002308	12/1/2019	FT-FY20-112019-002308-A	<1	FT-FY20-112019-002308-B	<1
WS-002309	4/16/2019	4/16/2020	1	Bathroom	In classroom 133 in bathroom		WF-04162019-002309	12/1/2019	FT-FY20-112019-002309-A	<1	FT-FY20-112019-002309-B	<1
WS-002310	4/16/2019	4/16/2020	1	Bathroom	In classroom 134 in bathroom		WF-04162019-002310	12/1/2019	FT-FY20-112019-002310-A	<1	FT-FY20-112019-002310-B	<1
WS-002311	9/18/2019	9/18/2020	1	Bottle Filler	In hallway adjacent to restrooms		WF-09182019-002311	12/1/2019	FT-FY20-112019-002311-A	<1	FT-FY20-112019-002311-B	<1
WS-002318	4/16/2019	4/16/2020	1	Combo Fountain	In treatment room 117 in health suite	Right	WF-04162019-002318	12/1/2019	FT-FY20-112019-002318-A	<1	FT-FY20-112019-002318-B	<1
WS-003614	4/16/2019	4/16/2020	1	Combo Fountain	In classroom 131		WF-04162019-003614	12/1/2019	FT-FY20-112019-003614-A	<1	FT-FY20-112019-003614-B	<1
WS-003615	9/25/2019	9/25/2020	1	Combo Faucet	In classroom 132		WF-09252019-003615	12/1/2019	FT-FY20-112019-003615-A	1.6	FT-FY20-112019-003615-B	<1
WS-003616	4/16/2019	4/16/2020	1	Combo Fountain	In classroom 132		WF-04162019-003616	12/1/2019	FT-FY20-112019-003616-A	<1	FT-FY20-112019-003616-B	<1
WS-003617	9/25/2019	9/25/2020	1	Combo Faucet	In classroom 133		WF-09252019-003617	12/1/2019	FT-FY20-112019-003617-A	<1	FT-FY20-112019-003617-B	<1
WS-003618	4/16/2019	4/16/2020	1	Combo Fountain	In classroom 133		WF-04162019-003618	12/1/2019	FT-FY20-112019-003618-A	<1	FT-FY20-112019-003618-B	<1
WS-003619	9/25/2019	9/25/2020	1	Combo Faucet	In classroom 134		WF-09252019-003619	12/1/2019	FT-FY20-112019-003619-A	<1	FT-FY20-112019-003619-B	<1
WS-003620	4/16/2019	4/16/2020	1	Combo Fountain	In classroom 134		WF-04162019-003620	12/1/2019	FT-FY20-112019-003620-A	<1	FT-FY20-112019-003620-B	<1
WS-003622	4/16/2019	4/16/2020	1	Combo Fountain	In classroom 142		WF-04162019-003622	12/1/2019	FT-FY20-112019-003622-A	<1	FT-FY20-112019-003622-B	<1
WS-003624	4/16/2019	4/16/2020	1	Combo Fountain	In classroom 144		WF-04162019-003624	12/1/2019	FT-FY20-112019-003624-A	<1	FT-FY20-112019-003624-B	<1
WS-003626	4/16/2019	4/16/2020	1	Combo Fountain	In classroom 147		WF-04162019-003626	12/1/2019	FT-FY20-112019-003626-A	<1	FT-FY20-112019-003626-B	<1
WS-003628	4/16/2019	4/16/2020	1	Combo Fountain	In classroom 146		WF-04162019-003628	12/1/2019	FT-FY20-112019-003628-A	<1	FT-FY20-112019-003628-B	<1
WS-003630	4/16/2019	4/16/2020	1	Combo Fountain	In classroom 145		WF-04162019-003630	12/1/2019	FT-FY20-112019-003630-A	<1	FT-FY20-112019-003630-B	<1
WS-003631	9/18/2019	9/18/2020	1	Cooler	In hallway adjacent to restrooms	High Left	WF-09182019-003631	12/1/2019	FT-FY20-112019-003631-A	<1	FT-FY20-112019-003631-B	<1
WS-003632	9/18/2019	9/18/2020	1	Cooler	In hallway adjacent to restrooms	Low Right	WF-09182019-003632	12/1/2019	FT-FY20-112019-003632-A	<1	FT-FY20-112019-003632-B	<1
WS-003633	9/18/2019	9/18/2020	2	Cooler	In hallway adjacent to restrooms	High Left	WF-09182019-003633	12/1/2019	FT-FY20-112019-003633-A	<1	FT-FY20-112019-003633-B	<1
WS-003634	9/18/2019	9/18/2020	2	Cooler	In hallway adjacent to restrooms	Low Right	WF-09182019-003634	12/1/2019	FT-FY20-112019-003634-A	<1	FT-FY20-112019-003634-B	<1
WS-003636	4/16/2019	4/16/2020	2	Combo Fountain	In classroom 227 first clockwise from entry door		WF-04162019-003636	12/1/2019	FT-FY20-112019-003636-A	2.3	FT-FY20-112019-003636-B	<1
WS-003638	4/16/2019	4/16/2020	2	Combo Fountain	In classroom 227 second clockwise from entry door	Mid	WF-04162019-003638	12/1/2019	FT-FY20-112019-003638-A	<1	FT-FY20-112019-003638-B	<1
WS-003640	4/16/2019	4/16/2020	2	Combo Fountain	In classroom 227 third clockwise from entry door		WF-04162019-003640	12/1/2019	FT-FY20-112019-003640-A	<1	FT-FY20-112019-003640-B	<1
WS-003642	4/16/2019	4/16/2020	2	Combo Fountain	In classroom 247		WF-04162019-003642	12/1/2019	FT-FY20-112019-003642-A	<1	FT-FY20-112019-003642-B	<1
WS-003644	4/16/2019	4/16/2020	2	Combo Fountain	In classroom 244		WF-04162019-003644	12/1/2019	FT-FY20-112019-003644-A	<1	FT-FY20-112019-003644-B	<1
WS-003646	4/16/2019	4/16/2020	2	Combo Fountain	In classroom 245		WF-04162019-003646	12/1/2019	FT-FY20-112019-003646-A	<1	FT-FY20-112019-003646-B	<1
WS-003648	4/16/2019	4/16/2020	2	Combo Fountain	In classroom 246		WF-04162019-003648	12/1/2019	FT-FY20-112019-003648-A	<1	FT-FY20-112019-003648-B	<1
WS-003649	4/16/2019	4/16/2020	2	Break Room	In break room 230		WF-04162019-003649	12/1/2019	FT-FY20-112019-003649-A	<1	FT-FY20-112019-003649-B	<1
WS-003650	4/16/2019	4/16/2020	2	Combo Fountain	In break room 230		WF-04162019-003650	12/1/2019	FT-FY20-112019-003650-A	<1	FT-FY20-112019-003650-B	<1
WS-003652	4/16/2019	4/16/2020	2	Combo Fountain	In classroom 231		WF-04162019-003652	12/1/2019	FT-FY20-112019-003652-A	<1	FT-FY20-112019-003652-B	<1
WS-003654	4/16/2019	4/16/2020	2	Combo Fountain	In classroom 232		WF-04162019-003654	12/1/2019	FT-FY20-112019-003654-A	<1	FT-FY20-112019-003654-B	<1
WS-003656	4/16/2019	4/16/2020	2	Combo Fountain	In classroom 233		WF-04162019-003656	12/1/2019	FT-FY20-112019-003656-A	<1	FT-FY20-112019-003656-B	<1
WS-003658	4/16/2019	4/16/2020	2	Combo Fountain	In classroom 234		WF-04162019-003658	12/1/2019	FT-FY20-112019-003658-A	<1	FT-FY20-112019-003658-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003608	7/15/2019	7/15/2020	1	Food Prep Sink	In kitchen	WF-07152019-003608	12/1/2019	FT-FY20-112019-003608-A	<1	FT-FY20-112019-003608-B	<1
WS- 003609	7/24/2019	7/24/2020	1	Food Prep Sink	In servers room 127A in kitchen third clockwise from entry door	WF-07242019-003609	12/1/2019	FT-FY20-112019-003609-A	<1	FT-FY20-112019-003609-B	<1