



Stoddert Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002307	3/15/2023	3/15/2024	1	Bathroom	In classroom 119 in bathroom	WF-03152023-002307	11/1/2023	FT-FY24-09282023-002307-A	<1	FT-FY24-09282023-002307-B	<1
WS- 002309	3/15/2023	3/15/2024	1	Bathroom	In classroom 133 in bathroom	WF-03152023-002309	11/1/2023	FT-FY24-09282023-002309-A	<1	FT-FY24-09282023-002309-B	<1
WS- 002310	3/15/2023	3/15/2024	1	Bathroom	In classroom 134 in bathroom	WF-03152023-002310	11/1/2023	FT-FY24-09282023-002310-A	<1	FT-FY24-09282023-002310-B	<1
WS- 002311	6/2/2023	6/2/2024	1	Bottle Filler	In hallway adjacent to restrooms	WF-06022023-002311	11/1/2023	FT-FY24-09282023-002311-A	<1	FT-FY24-09282023-002311-B	<1
WS- 002318	3/15/2023	3/15/2024	1	Combo Fountain	In treatment room 117 in health suite Right	WF-03152023-002318	11/1/2023	FT-FY24-09282023-002318-A	1.9	FT-FY24-09282023-002318-B	<1
WS- 003614	3/15/2023	3/15/2024	1	Combo Fountain	In classroom 131	WF-03152023-003614	11/1/2023	FT-FY24-09282023-003614-A	<1	FT-FY24-09282023-003614-B	<1
WS- 003615	8/30/2023	8/30/2024	1	Combo Faucet	In classroom 132	WF-08302023-003615	11/1/2023	FT-FY24-09282023-003615-A	2.9	FT-FY24-09282023-003615-B	<1
WS- 003616	3/15/2023	3/15/2024	1	Combo Fountain	In classroom 132	WF-03152023-003616	11/1/2023	FT-FY24-09282023-003616-A	1.5	FT-FY24-09282023-003616-B	<1
WS- 003617	8/30/2023	8/30/2024	1	Combo Faucet	In classroom 133	WF-08302023-003617	11/1/2023	FT-FY24-09282023-003617-A	1.1	FT-FY24-09282023-003617-B	<1
WS- 003618	3/15/2023	3/15/2024	1	Combo Fountain	In classroom 133	WF-03152023-003618	11/1/2023	FT-FY24-09282023-003618-A	<1	FT-FY24-09282023-003618-B	<1
WS- 003619	8/30/2023	8/30/2024	1	Combo Faucet	In classroom 134	WF-08302023-003619	11/1/2023	FT-FY24-09282023-003619-A	2.4	FT-FY24-09282023-003619-B	<1
WS- 003620	3/15/2023	3/15/2024	1	Combo Fountain	In classroom 134	WF-03152023-003620	11/1/2023	FT-FY24-09282023-003620-A	<1	FT-FY24-09282023-003620-B	<1
WS- 003622	3/15/2023	3/15/2024	1	Combo Fountain	In classroom 142	WF-03152023-003622	11/1/2023	FT-FY24-09282023-003622-A	<1	FT-FY24-09282023-003622-B	<1
WS- 003624	3/15/2023	3/15/2024	1	Combo Fountain	In classroom 144	WF-03152023-003624	11/1/2023	FT-FY24-09282023-003624-A	<1	FT-FY24-09282023-003624-B	<1
WS- 003626	3/15/2023	3/15/2024	1	Combo Fountain	In classroom 147	WF-03152023-003626	11/1/2023	FT-FY24-09282023-003626-A	1.5	FT-FY24-09282023-003626-B	<1
WS- 003630	3/15/2023	3/15/2024	1	Combo Fountain	In classroom 145	WF-03152023-003630	11/1/2023	FT-FY24-09282023-003630-A	<1	FT-FY24-09282023-003630-B	<1
WS- 003636	3/15/2023	3/15/2024	2	Combo Fountain	In classroom 227 first clockwise from entry door	WF-03152023-003636	11/1/2023	FT-FY24-09282023-003636-A	<1	FT-FY24-09282023-003636-B	<1
WS- 003638	3/15/2023	3/15/2024	2	Combo Fountain	In classroom 227 second clockwise from entry door Mid	WF-03152023-003638	11/1/2023	FT-FY24-09282023-003638-A	<1	FT-FY24-09282023-003638-B	<1
WS- 003640	3/15/2023	3/15/2024	2	Combo Fountain	In classroom 227 third clockwise from entry door	WF-03152023-003640	11/1/2023	FT-FY24-09282023-003640-A	<1	FT-FY24-09282023-003640-B	<1
WS- 003642	3/15/2023	3/15/2024	2	Combo Fountain	In classroom 247	WF-03152023-003642	11/1/2023	FT-FY24-09282023-003642-A	<1	FT-FY24-09282023-003642-B	<1
WS- 003644	3/15/2023	3/15/2024	2	Combo Fountain	In classroom 244	WF-03152023-003644	11/1/2023	FT-FY24-09282023-003644-A	<1	FT-FY24-09282023-003644-B	<1
WS- 003646	3/15/2023	3/15/2024	2	Combo Fountain	In classroom 245	WF-03152023-003646	11/1/2023	FT-FY24-09282023-003646-A	<1	FT-FY24-09282023-003646-B	<1
WS- 003648	3/15/2023	3/15/2024	2	Combo Fountain	In classroom 246	WF-03152023-003648	11/1/2023	FT-FY24-09282023-003648-A	<1	FT-FY24-09282023-003648-B	<1
WS- 003649	3/15/2023	3/15/2024	2	Break Room	In break room 230	WF-03152023-003649	11/1/2023	FT-FY24-09282023-003649-A	<1	FT-FY24-09282023-003649-B	<1
WS- 003652	3/15/2023	3/15/2024	2	Combo Fountain	In classroom 231	WF-03152023-003652	11/1/2023	FT-FY24-09282023-003652-A	<1	FT-FY24-09282023-003652-B	<1
WS- 003654	3/15/2023	3/15/2024	2	Combo Fountain	In classroom 232	WF-03152023-003654	11/1/2023	FT-FY24-09282023-003654-A	<1	FT-FY24-09282023-003654-B	<1
WS- 003656	3/15/2023	3/15/2024	2	Combo Fountain	In classroom 233	WF-03152023-003656	11/1/2023	FT-FY24-09282023-003656-A	<1	FT-FY24-09282023-003656-B	<1
WS- 003658	7/19/2023	7/19/2024	2	Combo Fountain	In classroom 234	WF-07192023-003658	11/1/2023	FT-FY24-09282023-003658-A	1.7	FT-FY24-09282023-003658-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003608	12/28/2022	12/28/2023	1	Food Prep Sink	In kitchen	WF-12282022-003608	11/1/2023	FT-FY24-09282023-003608-A	<1	FT-FY24-09282023-003608-B	<1
WS- 003609	12/28/2022	12/28/2023	1	Food Prep Sink	In servers room 127A in kitchen third clockwise from entry door	WF-12282022-003609	11/1/2023	FT-FY24-09282023-003609-A	<1	FT-FY24-09282023-003609-B	<1

FY24 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002306	3/15/2023	3/15/2024	1	Health Suite	In health suite in treatment room 117 Left	WF-03152023-002306	11/1/2023	FT-FY24-09282023-002306-A	10.5	FT-FY24-09282023-002306-B	3.9

First Re-test (After Plumbing Check)

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002306	11/3/2023	11/3/2024	1	Health Suite	In health suite in treatment room 117 Left	WF-11032023-002306	11/14/2023	FT-FY24-11062023-002306-A	1.7	FT-FY24-11062023-002306-B	1.7