



STODDERT ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	STODDERT ELEMENTARY SCHOOL	WS- 002306	8/13/2016	1	Health Suite	In treatment room 117 in health suite Left	FT-72016-002306-A	< 1	FT-72016-002306-B	< 1
2	STODDERT ELEMENTARY SCHOOL	WS- 002318	8/13/2016	1	Fountain	In treatment room 117 in health suite Right	FT-82016-002318-A	< 1	FT-82016-002318-B	< 1
3	STODDERT ELEMENTARY SCHOOL	WS- 003608	8/13/2016	1	Food Prep Sink	In kitchen	FT-82016-003608-A	< 1	FT-82016-003608-B	< 1
4	STODDERT ELEMENTARY SCHOOL	WS- 003614	8/13/2016	1	Fountain	In classroom 131	FT-82016-003614-A	< 1	FT-82016-003614-B	< 1
5	STODDERT ELEMENTARY SCHOOL	WS- 003616	8/13/2016	1	Fountain	In classroom 132	FT-82016-003616-A	< 1	FT-82016-003616-B	< 1
6	STODDERT ELEMENTARY SCHOOL	WS- 003618	8/13/2016	1	Fountain	In classroom 133	FT-82016-003618-A	< 1	FT-82016-003618-B	< 1
7	STODDERT ELEMENTARY SCHOOL	WS- 003620	8/13/2016	1	Fountain	In classroom 134	FT-82016-003620-A	< 1	FT-82016-003620-B	< 1
8	STODDERT ELEMENTARY SCHOOL	WS- 003622	8/13/2016	1	Fountain	In classroom 142	FT-82016-003622-A	< 1	FT-82016-003622-B	< 1
9	STODDERT ELEMENTARY SCHOOL	WS- 003624	8/13/2016	1	Fountain	In classroom 144	FT-82016-003624-A	< 1	FT-82016-003624-B	< 1
10	STODDERT ELEMENTARY SCHOOL	WS- 003626	8/13/2016	1	Fountain	In classroom 147	FT-82016-003626-A	< 1	FT-82016-003626-B	< 1
11	STODDERT ELEMENTARY SCHOOL	WS- 003628	8/13/2016	1	Fountain	In classroom 146	FT-82016-003628-A	< 1	FT-82016-003628-B	< 1
12	STODDERT ELEMENTARY SCHOOL	WS- 003630	8/13/2016	1	Fountain	In classroom 145	FT-82016-003630-A	< 1	FT-82016-003630-B	< 1
13	STODDERT ELEMENTARY SCHOOL	WS- 003631	8/13/2016	1	Cooler	In hallway adjacent to restrooms High Left	FT-82016-003631-A	< 1	FT-82016-003631-B	< 1
14	STODDERT ELEMENTARY SCHOOL	WS- 003632	8/13/2016	1	Cooler	In hallway adjacent to restrooms Low Right	FT-82016-003632-A	< 1	FT-82016-003632-B	< 1
15	STODDERT ELEMENTARY SCHOOL	WS- 003633	8/13/2016	2	Cooler	In hallway adjacent to restrooms High Left	FT-82016-003633-A	< 1	FT-82016-003633-B	< 1
16	STODDERT ELEMENTARY SCHOOL	WS- 003634	8/13/2016	2	Cooler	In hallway adjacent to restrooms Low Right	FT-82016-003634-A	< 1	FT-82016-003634-B	< 1
17	STODDERT ELEMENTARY SCHOOL	WS- 003636	8/13/2016	2	Fountain	In classroom 227 first clockwise from entry door	FT-82016-003636-A	< 1	FT-82016-003636-B	< 1
18	STODDERT ELEMENTARY SCHOOL	WS- 003638	8/13/2016	2	Fountain	In classroom 227 second clockwise from entry door Mid	FT-82016-003638-A	< 1	FT-82016-003638-B	< 1
19	STODDERT ELEMENTARY SCHOOL	WS- 003640	8/13/2016 10/10/2016	2	Fountain	In classroom 227 third clockwise from entry door	FT-82016-003640-A Re-test A	< 1 1.7	FT-82016-003640-B Re-test B	1.4 < 1
20	STODDERT ELEMENTARY SCHOOL	WS- 003642	8/13/2016	2	Fountain	In classroom 247	FT-82016-003642-A	< 1	FT-82016-003642-B	< 1
21	STODDERT ELEMENTARY SCHOOL	WS- 003644	8/13/2016	2	Fountain	In classroom 244	FT-82016-003644-A	< 1	FT-82016-003644-B	< 1
22	STODDERT ELEMENTARY SCHOOL	WS- 003646	8/13/2016	2	Fountain	In classroom 245	FT-82016-003646-A	< 1	FT-82016-003646-B	< 1
23	STODDERT ELEMENTARY SCHOOL	WS- 003648	8/13/2016	2	Fountain	In classroom 246	FT-82016-003648-A	< 1	FT-82016-003648-B	< 1
24	STODDERT ELEMENTARY SCHOOL	WS- 003650	8/13/2016	2	Fountain	In break room 230	FT-82016-003650-A	< 1	FT-82016-003650-B	< 1
25	STODDERT ELEMENTARY SCHOOL	WS- 003652	8/13/2016	2	Fountain	In classroom 231	FT-82016-003652-A	< 1	FT-82016-003652-B	< 1
26	STODDERT ELEMENTARY SCHOOL	WS- 003654	8/13/2016	2	Fountain	In classroom 232	FT-82016-003654-A	< 1	FT-82016-003654-B	< 1
27	STODDERT ELEMENTARY SCHOOL	WS- 003656	8/13/2016	2	Fountain	In classroom 233	FT-82016-003656-A	< 1	FT-82016-003656-B	< 1
28	STODDERT ELEMENTARY SCHOOL	WS- 003658	8/13/2016	2	Fountain	In classroom 234	FT-82016-003658-A	< 1	FT-82016-003658-B	< 1