



Stoddert ES Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002306	5/30/2017	5/30/2018	1	Health Suite	In health suite in treatment room 117 Left	WF-52017-002306	11/10/2017	FT-FY18--52017-002306-A	<1	FT-FY18--52017-002306-B	<1
WS-002308	8/10/2017	8/10/2018	1	Bathroom	In classroom 132 in bathroom	WF-82017-002308	11/10/2017	FT-FY18--82017-002308-A	<1	FT-FY18--82017-002308-B	<1
WS-002309	8/10/2017	8/10/2018	1	Bathroom	In classroom 133 in bathroom	WF-82017-002309	11/10/2017	FT-FY18--82017-002309-A	<1	FT-FY18--82017-002309-B	<1
WS-003614	5/30/2017	5/30/2018	1	Combo Fountain	In classroom 131	WF-52017-003614	11/10/2017	FT-FY18--52017-003614-A	<1	FT-FY18--52017-003614-B	<1
WS-003618	5/30/2017	5/30/2018	1	Combo Fountain	In classroom 133	WF-52017-003618	11/10/2017	FT-FY18--52017-003618-A	<1	FT-FY18--52017-003618-B	<1
WS-003620	5/30/2017	5/30/2018	1	Combo Fountain	In classroom 134	WF-52017-003620	11/10/2017	FT-FY18--52017-003620-A	<1	FT-FY18--52017-003620-B	<1
WS-003627	5/30/2017	5/30/2018	1	Combo Faucet	In classroom 146	WF-52017-003627	11/10/2017	FT-FY18--52017-003627-A	<1	FT-FY18--52017-003627-B	<1
WS-003630	5/30/2017	5/30/2018	1	Combo Fountain	In classroom 145	WF-52017-003630	11/10/2017	FT-FY18--52017-003630-A	<1	FT-FY18--52017-003630-B	<1
WS-003634	5/30/2017	5/30/2018	2	Cooler	In hallway adjacent to restrooms Right Low	WF-52017-003634	11/10/2017	FT-FY18--52017-003634-A	<1	FT-FY18--52017-003634-B	<1
WS-003636	5/30/2017	5/30/2018	2	Combo Fountain	In classroom 227 first clockwise from entry door	WF-52017-003636	11/10/2017	FT-FY18--52017-003636-A	2.1	FT-FY18--52017-003636-B	<1
WS-003644	5/30/2017	5/30/2018	2	Combo Fountain	In classroom 244	WF-52017-003644	11/10/2017	FT-FY18--52017-003644-A	<1	FT-FY18--52017-003644-B	<1
WS-003650	5/30/2017	5/30/2018	2	Combo Fountain	In break room 230	WF-52017-003650	11/10/2017	FT-FY18--52017-003650-A	<1	FT-FY18--52017-003650-B	<1
WS-003656	5/30/2017	5/30/2018	2	Combo Fountain	In classroom 233	WF-52017-003656	11/10/2017	FT-FY18--52017-003656-A	<1	FT-FY18--52017-003656-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003608	1	Food Prep Sink	In kitchen	11/10/2017	FT-FY18-102017-003608-A	<1	FT-FY18-102017-003608-B	<1