



# Stoddert ES Lead Water Test Results



## FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002306	4/23/2018	4/23/2019	1	Health Suite	In health suite in treatment room 117 Left	WF-04232018-002306	11/26/2018	FT-FY19-112018-002306-A	1	FT-FY19-112018-002306-B	<1
WS-002307	4/23/2018	4/23/2019	1	Bathroom	In classroom 119 in bathroom	WF-04232018-002307	11/26/2018	FT-FY19-112018-002307-A	<1	FT-FY19-112018-002307-B	<1
WS-002308	4/23/2018	4/23/2019	1	Bathroom	In classroom 132 in bathroom	WF-04232018-002308	11/26/2018	FT-FY19-112018-002308-A	<1	FT-FY19-112018-002308-B	<1
WS-002309	4/23/2018	4/23/2019	1	Bathroom	In classroom 133 in bathroom	WF-04232018-002309	11/26/2018	FT-FY19-112018-002309-A	<1	FT-FY19-112018-002309-B	<1
WS-002310	4/23/2018	4/23/2019	1	Bathroom	In classroom 134 in bathroom	WF-04232018-002310	11/26/2018	FT-FY19-112018-002310-A	<1	FT-FY19-112018-002310-B	<1
WS-002311	8/17/2018	8/17/2019	1	Bottle Filler	In hallway adjacent to restrooms	WF-08172018-002311	11/26/2018	FT-FY19-112018-002311-A	<1	FT-FY19-112018-002311-B	<1
WS-002318	4/26/2018	4/26/2019	1	Combo Fountain	In treatment room 117 in health suite Right	WF-04262018-002318	11/26/2018	FT-FY19-112018-002318-A	<1	FT-FY19-112018-002318-B	<1
WS-003614	4/23/2018	4/23/2019	1	Combo Fountain	In classroom 131	WF-04232018-003614	11/26/2018	FT-FY19-112018-003614-A	<1	FT-FY19-112018-003614-B	<1
WS-003615	10/3/2018	10/3/2019	1	Combo Faucet	In classroom 132	WF-10032018-003615	11/26/2018	FT-FY19-112018-003615-A	<1	FT-FY19-112018-003615-B	<1
WS-003616	4/23/2018	4/23/2019	1	Combo Fountain	In classroom 132	WF-04232018-003616	11/26/2018	FT-FY19-112018-003616-A	<1	FT-FY19-112018-003616-B	<1
WS-003617	10/3/2018	10/3/2019	1	Combo Faucet	In classroom 133	WF-10032018-003617	11/26/2018	FT-FY19-112018-003617-A	<1	FT-FY19-112018-003617-B	<1
WS-003618	4/23/2018	4/23/2019	1	Combo Fountain	In classroom 133	WF-04232018-003618	11/26/2018	FT-FY19-112018-003618-A	<1	FT-FY19-112018-003618-B	<1
WS-003619	10/3/2018	10/3/2019	1	Combo Faucet	In classroom 134	WF-10032018-003619	11/26/2018	FT-FY19-112018-003619-A	<1	FT-FY19-112018-003619-B	<1
WS-003620	4/23/2018	4/23/2019	1	Combo Fountain	In classroom 134	WF-04232018-003620	11/26/2018	FT-FY19-112018-003620-A	<1	FT-FY19-112018-003620-B	<1
WS-003622	4/23/2018	4/23/2019	1	Combo Fountain	In classroom 142	WF-04232018-003622	11/26/2018	FT-FY19-112018-003622-A	<1	FT-FY19-112018-003622-B	<1
WS-003624	4/23/2018	4/23/2019	1	Combo Fountain	In classroom 144	WF-04232018-003624	11/26/2018	FT-FY19-112018-003624-A	<1	FT-FY19-112018-003624-B	<1
WS-003626	4/23/2018	4/23/2019	1	Combo Fountain	In classroom 147	WF-04232018-003626	11/26/2018	FT-FY19-112018-003626-A	<1	FT-FY19-112018-003626-B	<1
WS-003628	4/23/2018	4/23/2019	1	Combo Fountain	In classroom 146	WF-04232018-003628	11/26/2018	FT-FY19-112018-003628-A	<1	FT-FY19-112018-003628-B	<1
WS-003630	4/23/2018	4/23/2019	1	Combo Fountain	In classroom 145	WF-04232018-003630	11/26/2018	FT-FY19-112018-003630-A	<1	FT-FY19-112018-003630-B	<1
WS-003631	8/17/2018	8/17/2019	1	Cooler	In hallway adjacent to restrooms High Left	WF-08172018-003631	11/26/2018	FT-FY19-112018-003631-A	<1	FT-FY19-112018-003631-B	<1
WS-003632	8/17/2018	8/17/2019	1	Cooler	In hallway adjacent to restrooms Low Right	WF-08172018-003632	11/26/2018	FT-FY19-112018-003632-A	<1	FT-FY19-112018-003632-B	<1
WS-003633	4/23/2018	4/23/2019	2	Cooler	In hallway adjacent to restrooms High Left	WF-04232018-003633	11/26/2018	FT-FY19-112018-003633-A	<1	FT-FY19-112018-003633-B	<1
WS-003634	4/23/2018	4/23/2019	2	Cooler	In hallway adjacent to restrooms Low Right	WF-04232018-003634	11/26/2018	FT-FY19-112018-003634-A	<1	FT-FY19-112018-003634-B	<1
WS-003636	4/23/2018	4/23/2019	2	Combo Fountain	In classroom 227 first clockwise from entry door	WF-04232018-003636	11/26/2018	FT-FY19-112018-003636-A	<1	FT-FY19-112018-003636-B	<1
WS-003638	4/23/2018	4/23/2019	2	Combo Fountain	In classroom 227 second clockwise from entry door Mid	WF-04232018-003638	11/26/2018	FT-FY19-112018-003638-A	<1	FT-FY19-112018-003638-B	<1
WS-003640	4/23/2018	4/23/2019	2	Combo Fountain	In classroom 227 third clockwise from entry door	WF-04232018-003640	11/26/2018	FT-FY19-112018-003640-A	<1	FT-FY19-112018-003640-B	<1
WS-003642	4/23/2018	4/23/2019	2	Combo Fountain	In classroom 247	WF-04232018-003642	11/26/2018	FT-FY19-112018-003642-A	<1	FT-FY19-112018-003642-B	<1
WS-003644	4/23/2018	4/23/2019	2	Combo Fountain	In classroom 244	WF-04232018-003644	11/26/2018	FT-FY19-112018-003644-A	<1	FT-FY19-112018-003644-B	<1
WS-003646	4/23/2018	4/23/2019	2	Combo Fountain	In classroom 245	WF-04232018-003646	11/26/2018	FT-FY19-112018-003646-A	<1	FT-FY19-112018-003646-B	<1
WS-003648	4/23/2018	4/23/2019	2	Combo Fountain	In classroom 246	WF-04232018-003648	11/26/2018	FT-FY19-112018-003648-A	<1	FT-FY19-112018-003648-B	<1
WS-003649	4/23/2018	4/23/2019	2	Break Room	In break room 230	WF-04232018-003649	11/26/2018	FT-FY19-112018-003649-A	<1	FT-FY19-112018-003649-B	<1
WS-003650	4/23/2018	4/23/2019	2	Combo Fountain	In break room 230	WF-04232018-003650	11/26/2018	FT-FY19-112018-003650-A	<1	FT-FY19-112018-003650-B	<1

WS- 003652	4/23/2018	4/23/2019	2	Combo Fountain	In classroom 231	WF-04232018-003652	11/26/2018	FT-FY19-112018-003652-A	<1	FT-FY19-112018-003652-B	<1
WS- 003654	4/23/2018	4/23/2019	2	Combo Fountain	In classroom 232	WF-04232018-003654	11/26/2018	FT-FY19-112018-003654-A	<1	FT-FY19-112018-003654-B	<1
WS- 003656	4/23/2018	4/23/2019	2	Combo Fountain	In classroom 233	WF-04232018-003656	11/26/2018	FT-FY19-112018-003656-A	<1	FT-FY19-112018-003656-B	<1
WS- 003658	4/23/2018	4/23/2019	2	Combo Fountain	In classroom 234	WF-04232018-003658	11/26/2018	FT-FY19-112018-003658-A	<1	FT-FY19-112018-003658-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation										
Record ID	Floor	Device Type	Device Location			Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003608	1	Food Prep Sink	In kitchen			11/26/2018	FT-FY19-112018-003608-A	<1	FT-FY19-112018-003608-B	<1