



STODDERT LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003607	Utility	Basement	In custodian office room 022 (no direct tap to water main this is the closest source)	WT-042916-3624- A	< 1	WT-042916-3624- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003608	Kitchen	1	In kitchen back wall	WT-042916-3625- A	< 1	WT-042916-3625- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003609	Kitchen	1	In servers room 127A	WT-042916-3626- A	< 1	WT-042916-3626- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003610	Kitchen	1	In servery room 127A	WT-042916-3627- A	< 1	WT-042916-3627- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003611	Other	1	In kitchen servery room 127A (spray nozzle) Left	WT-042916-3628- A	< 1	WT-042916-3628- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003612	Other	1	In kitchen servery room 127A (spray nozzle) Right High	WT-042916-3629- A	3.44	WT-042916-3629- B	16.7				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003613	Classroom	1	In classroom 131	WT-042916-3630- A	257	WT-042916-3630- B	115	Filtered	6/15/2016	<1	<1
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003614	Fountain	1	In classroom 131	WT-042916-3631- A	< 1	WT-042916-3631- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003615	Classroom	1	In classroom 132	WT-042916-3632- A	< 1	WT-042916-3632- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003616	Fountain	1	In classroom 132	WT-042916-3633- A	< 1	WT-042916-3633- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003617	Classroom	1	In classroom 133	WT-042916-3634- A	2.09	WT-042916-3634- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003618	Fountain	1	In classroom 133	WT-042916-3635- A	< 1	WT-042916-3635- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003619	Classroom	1	In classroom 134	WT-042916-3636- A	< 1	WT-042916-3636- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003620	Fountain	1	In classroom 134	WT-042916-3637- A	< 1	WT-042916-3637- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003621	Classroom	1	In classroom 142	WT-042916-3638- A	7.72	WT-042916-3638- B	3.18				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003622	Fountain	1	In classroom 142	WT-042916-3639- A	2.12	WT-042916-3639- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003623	Classroom	1	In classroom 144	WT-042916-3640- A	2.11	WT-042916-3640- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003624	Fountain	1	In classroom 144	WT-042916-3641- A	< 1	WT-042916-3641- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003625	Classroom	1	In classroom 147	WT-042916-3642- A	< 1	WT-042916-3642- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003626	Fountain	1	In classroom 147	WT-042916-3643- A	< 1	WT-042916-3643- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003627	Classroom	1	In classroom 146	WT-042916-3644- A	< 1	WT-042916-3644- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003628	Fountain	1	In classroom 146	WT-042916-3645- A	< 1	WT-042916-3645- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003629	Classroom	1	In classroom 145	WT-042916-3646- A	< 1	WT-042916-3646- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003630	Fountain	1	In classroom 145	WT-042916-3647- A	< 1	WT-042916-3647- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003631	Cooler	1	In lobby between bathrooms 125 and 126	WT-042916-3648- A	< 1	WT-042916-3648- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003632	Cooler	1	In lobby between bathrooms 125 and 126	WT-042916-3649- A	< 1	WT-042916-3649- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003633	Cooler	2	Lobby between bathrooms 225 and 226	WT-042916-3650- A	< 1	WT-042916-3650- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003634	Cooler	2	Lobby between bathrooms 225 and 226	WT-042916-3651- A	< 1	WT-042916-3651- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003635	Classroom	2	In classroom 227 (leftmost sink clockwise from door)	WT-042916-3652- A	98.6	WT-042916-3652- B	1.46	Filtered	6/15/2016	<1	<1
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003636	Fountain	2	In classroom 227 (leftmost sink clockwise from door)	WT-042916-3653- A	< 1	WT-042916-3653- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003637	Classroom	2	In classroom 227 (second sink clockwise from door)	WT-042916-3654- A	12.7	WT-042916-3654- B	2.71				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003638	Fountain	2	In classroom 227 (second sink clockwise from door)	WT-042916-3655- A	25.4	WT-042916-3655- B	6.72	Filtered	6/15/2016	<1	<1
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003639	Classroom	2	In classroom 227 (third sink clockwise from door)	WT-042916-3656- A	16.9	WT-042916-3656- B	< 1	Filtered	6/15/2016	<1	<1
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003640	Fountain	2	In classroom 227 (third sink clockwise from door)	WT-042916-3657- A	14.8	WT-042916-3657- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003641	Classroom	2	In classroom 247	WT-042916-3658- A	3.24	WT-042916-3658- B	1.29				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003642	Fountain	2	In classroom 247	WT-042916-3659- A	9.65	WT-042916-3659- B	5.86				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003643	Classroom	2	In classroom 244	WT-042916-3660- A	4.24	WT-042916-3660- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003644	Fountain	2	In classroom 244	WT-042916-3661- A	< 1	WT-042916-3661- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003645	Classroom	2	In classroom 245	WT-042916-3662- A	3.19	WT-042916-3662- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003646	Fountain	2	In classroom 245	WT-042916-3663- A	< 1	WT-042916-3663- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003647	Classroom	2	In classroom 246	WT-042916-3664- A	5.56	WT-042916-3664- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003648	Fountain	2	In classroom 246	WT-042916-3665- A	1.64	WT-042916-3665- B	1.84				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003649	Break Room	2	In break room 230	WT-042916-3666- A	< 1	WT-042916-3666- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003650	Fountain	2	In break room 230	WT-042916-3667- A	< 1	WT-042916-3667- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003651	Classroom	2	In classroom 231	WT-042916-3668- A	47.3	WT-042916-3668- B	1.06	Filtered	6/15/2016	<1	<1
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003652	Fountain	2	In classroom 231	WT-042916-3669- A	< 1	WT-042916-3669- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003653	Classroom	2	In classroom 232	WT-042916-3670- A	< 1	WT-042916-3670- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003654	Fountain	2	In classroom 232	WT-042916-3671- A	< 1	WT-042916-3671- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003655	Classroom	2	In classroom 233	WT-042916-3672- A	< 1	WT-042916-3672- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS-003656	Fountain	2	In classroom 233	WT-042916-3673- A	< 1	WT-042916-3673- B	< 1				



STODDERT LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS- 003657	Classroom	2	In classroom 234	WT-042916-3674- A	< 1	WT-042916-3674- B	< 1				
STODDERT ELEMENTARY SCHOOL	5/6/2016	WS- 003658	Fountain	2	In classroom 234	WT-042916-3675- A	< 1	WT-042916-3675- B	< 1				

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.