



STUART HOBSON MS LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	STUART-HOBSON MIDDLE SCHOOL	WS- 010592	8/19/2016	Ground Floor	Bottle Filler	In hallway adjacent to room L11 (bottle filler) High Left	FT-82016-010592-A	< 1	FT-82016-010592-B	< 1
2	STUART-HOBSON MIDDLE SCHOOL	WS- 010593	8/19/2016	Ground Floor	Cooler	In hallway adjacent to room L11 Low Left	FT-82016-010593-A	< 1	FT-82016-010593-B	< 1
3	STUART-HOBSON MIDDLE SCHOOL	WS- 010594	8/19/2016	Ground Floor	Cooler	In hallway adjacent to room L11 Right	FT-82016-010594-A	< 1	FT-82016-010594-B	< 1
4	STUART-HOBSON MIDDLE SCHOOL	WS- 010595	8/19/2016	Basement	Cooler	In hallway adjacent to room G07	FT-82016-010595-A	< 1	FT-82016-010595-B	< 1
5	STUART-HOBSON MIDDLE SCHOOL	WS- 010597	8/19/2016	Basement	Cooler	In hallway adjacent to room G09	FT-82016-010597-A	< 1	FT-82016-010597-B	< 1
6	STUART-HOBSON MIDDLE SCHOOL	WS- 010598	8/19/2016	Basement	Cooler	In hallway adjacent to room G05	FT-82016-010598-A	< 1	FT-82016-010598-B	< 1
7	STUART-HOBSON MIDDLE SCHOOL	WS- 010604	8/19/2016	Basement	Cooler	In hallway adjacent to room G15 High Left	FT-82016-010604-A	< 1	FT-82016-010604-B	< 1
8	STUART-HOBSON MIDDLE SCHOOL	WS- 010605	8/19/2016	Basement	Cooler	In hallway adjacent to room G15 Low Right	FT-82016-010605-A	< 1	FT-82016-010605-B	< 1
9	STUART-HOBSON MIDDLE SCHOOL	WS- 010606	8/19/2016	Basement	Cooler	In cafeteria Left	FT-82016-010606-A	< 1	FT-82016-010606-B	< 1
10	STUART-HOBSON MIDDLE SCHOOL	WS- 010607	8/19/2016	Basement	Cooler	In cafeteria Right	FT-82016-010607-A	< 1	FT-82016-010607-B	< 1
11	STUART-HOBSON MIDDLE SCHOOL	WS- 010608	8/19/2016	Basement	Other	In kitchen first clockwise from entry door (dishwashing hose) Left	FT-72016-010608-A	< 1	FT-72016-010608-B	< 1
12	STUART-HOBSON MIDDLE SCHOOL	WS- 010609	8/19/2016	Basement	Food Prep Sink	In kitchen second clockwise from entry door Mid	FT-72016-010609-A	< 1	FT-72016-010609-B	< 1
13	STUART-HOBSON MIDDLE SCHOOL	WS- 010610	8/19/2016	Basement	Food Prep Sink	In kitchen third clockwise from entry door Right	FT-82016-010610-A	< 1	FT-82016-010610-B	< 1
14	STUART-HOBSON MIDDLE SCHOOL	WS- 010614	8/19/2016	1	Cooler	In hallway adjacent to room 105	FT-82016-010614-A	< 1	FT-82016-010614-B	< 1
15	STUART-HOBSON MIDDLE SCHOOL	WS- 010615	8/19/2016	1	Fountain	In health suite 104 Right	FT-82016-010615-A	< 1	FT-82016-010615-B	< 1
16	STUART-HOBSON MIDDLE SCHOOL	WS- 010616	8/19/2016	1	Health Suite	In health suite 104 Left	FT-82016-010616-A	< 1	FT-82016-010616-B	< 1
17	STUART-HOBSON MIDDLE SCHOOL	WS- 010619	8/19/2016	1	Cooler	In hallway adjacent to girls' restroom	FT-82016-010619-A	< 1	FT-82016-010619-B	< 1
18	STUART-HOBSON MIDDLE SCHOOL	WS- 010620	8/19/2016	1	Cooler	In hallway adjacent to room 117	FT-82016-010620-A	< 1	FT-82016-010620-B	< 1
19	STUART-HOBSON MIDDLE SCHOOL	WS- 010636	8/19/2016	2	Cooler	In hallway adjacent to room 218	FT-82016-010636-A	< 1	FT-82016-010636-B	< 1
20	STUART-HOBSON MIDDLE SCHOOL	WS- 010638	8/19/2016	2	Cooler	In hallway adjacent to room 213	FT-82016-010638-A	< 1	FT-82016-010638-B	< 1
21	STUART-HOBSON MIDDLE SCHOOL	WS- 010639	8/19/2016	2	Cooler	In hallway adjacent to room 203	FT-82016-010639-A	< 1	FT-82016-010639-B	< 1
22	STUART-HOBSON MIDDLE SCHOOL	WS- 010641	8/19/2016	2	Fountain	In classroom 201 Right	FT-82016-010641-A	< 1	FT-82016-010641-B	< 1
23	STUART-HOBSON MIDDLE SCHOOL	WS- 010648	8/19/2016	3	Cooler	In hallway adjacent to room 304	FT-82016-010648-A	< 1	FT-82016-010648-B	< 1
24	STUART-HOBSON MIDDLE SCHOOL	WS- 010649	8/19/2016	3	Cooler	In hallway adjacent to room 312	FT-82016-010649-A	< 1	FT-82016-010649-B	< 1