



STUART-HOBSON LEAD WATER TEST RESULTS

May 24th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010652	Other	1	Spray nozzle in room 108 Left	WT-042916-10669- A	< 1	WT-042916-10669- B	< 1				
2	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010651	Other	Basement	Spray nozzle in room G-07D Right	WT-042916-10668- A	29.7	WT-042916-10668- B	< 1	Filter will be installed and then retested			
3	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010650	Break Room	3	In room 310	WT-042916-10667- A	< 1	WT-042916-10667- B	< 1				
4	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010649	Cooler	3	In hallway adjacent to room 312 storage	WT-042916-10666- A	< 1	WT-042916-10666- B	< 1				
5	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010648	Cooler	3	In hallway adjacent to room 304	WT-042916-10665- A	< 1	WT-042916-10665- B	< 1				
6	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010647	Classroom	3	In classroom 303,6	WT-042916-10664- A	< 1	WT-042916-10664- B	< 1				
7	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010646	Classroom	3	In room 303,5	WT-042916-10663- A	< 1	WT-042916-10663- B	< 1				
8	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010645	Classroom	3	In classroom,4	WT-042916-10662- A	< 1	WT-042916-10662- B	< 1				
9	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010644	Classroom	3	In room 303,3	WT-042916-10661- A	< 1	WT-042916-10661- B	< 1				
10	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010643	Classroom	3	In classroom 303,2	WT-042916-10660- A	< 1	WT-042916-10660- B	< 1				
11	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010642	Classroom	3	In classroom 303, 1	WT-042916-10659- A	< 1	WT-042916-10659- B	< 1				
12	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010641	Fountain	2	In classroom 201 Right	WT-042916-10658- A	< 1	WT-042916-10658- B	< 1				
13	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010640	Classroom	2	In room 201	WT-042916-10657- A	< 1	WT-042916-10657- B	< 1				
14	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010639	Cooler	2	In hallway adjacent to room 203	WT-042916-10656- A	< 1	WT-042916-10656- B	< 1				
15	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010638	Cooler	2	In hallway adjacent to room 213	WT-042916-10655- A	< 1	WT-042916-10655- B	< 1				
16	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010637	Classroom	2	In room 213	WT-042916-10654- A	< 1	WT-042916-10654- B	< 1				
17	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010636	Cooler	2	In hallway adjacent to room 218	WT-042916-10653- A	< 1	WT-042916-10653- B	< 1				
18	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010635	Classroom	2	In classroom 222,6	WT-042916-10652- A	< 1	WT-042916-10652- B	< 1				
19	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010634	Classroom	2	In classroom 222,5	WT-042916-10651- A	< 1	WT-042916-10651- B	< 1				
20	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010633	Classroom	2	In classroom 222,4	WT-042916-10650- A	< 1	WT-042916-10650- B	< 1				
21	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010632	Classroom	2	In classroom 222,3	WT-042916-10649- A	< 1	WT-042916-10649- B	< 1				
22	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010631	Classroom	2	In room 222,2	WT-042916-10648- A	3.2	WT-042916-10648- B	1.2				
23	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010630	Classroom	2	In classroom 222,1	WT-042916-10647- A	< 1	WT-042916-10647- B	< 1				
24	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010629	Other	1	Spray nozzle in room 120 Right	WT-042916-10646- A	< 1	WT-042916-10646- B	< 1				
25	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010628	Classroom	1	In room 120	WT-042916-10645- A	< 1	WT-042916-10645- B	< 1				
26	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010627	Classroom	1	In classroom 122	WT-042916-10644- A	1.8	WT-042916-10644- B	< 1				
27	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010626	Classroom	1	In room 122,5	WT-042916-10643- A	< 1	WT-042916-10643- B	< 1				
28	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010625	Classroom	1	In room 122,4	WT-042916-10642- A	< 1	WT-042916-10642- B	< 1				
29	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010624	Classroom	1	Room 122,3	WT-042916-10641- A	1.7	WT-042916-10641- B	< 1				
30	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010623	Classroom	1	In room 122,2	WT-042916-10640- A	3	WT-042916-10640- B	< 1				
31	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010622	Classroom	1	In classroom 122,1	WT-042916-10639- A	< 1	WT-042916-10639- B	< 1				
32	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010621	Classroom	1	In classroom 117	WT-042916-10638- A	1.1	WT-042916-10638- B	< 1				
33	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010620	Cooler	1	In hallway adjacent to room 117	WT-042916-10637- A	< 1	WT-042916-10637- B	< 1				
34	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010619	Cooler	1	In hallway adjacent to room 112	WT-042916-10636- A	< 1	WT-042916-10636- B	< 1				
35	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010618	Classroom	1	In classroom 108	WT-042916-10635- A	< 1	WT-042916-10635- B	< 1				
36	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010617	Break Room	1	Room 105	WT-042916-10634- A	< 1	WT-042916-10634- B	< 1				
37	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010616	Health Suite	1	In room 104 Left	WT-042916-10633- A	< 1	WT-042916-10633- B	< 1				
38	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010615	Fountain	1	In health suite 104 Right	WT-042916-10632- A	< 1	WT-042916-10632- B	< 1				
39	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010614	Cooler	1	In hallway adjacent to room 105	WT-042916-10631- A	< 1	WT-042916-10631- B	< 1				
40	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010613	Other	Basement	Spray nozzle in kitchen Left	WT-042916-10630- A	< 1	WT-042916-10630- B	< 1				
41	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010612	Kitchen	Basement	In kitchen	WT-042916-10629- A	< 1	WT-042916-10629- B	< 1				
42	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010611	Kitchen	Basement	In kitchen	WT-042916-10628- A	< 1	WT-042916-10628- B	< 1				
43	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010610	Kitchen	Basement	In kitchen Right	WT-042916-10627- A	< 1	WT-042916-10627- B	< 1				
44	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010609	Kitchen	Basement	In kitchen Mid	WT-042916-10626- A	< 1	WT-042916-10626- B	< 1				
45	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010608	Other	Basement	In kitchen (spray nozzle) Left	WT-042916-10625- A	1.8	WT-042916-10625- B	< 1				
46	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010607	Cooler	Basement	In cafeteria Right	WT-042916-10624- A	< 1	WT-042916-10624- B	< 1				
47	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010606	Cooler	Basement	In cafeteria Left	WT-042916-10623- A	< 1	WT-042916-10623- B	< 1				
48	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010605	Cooler	Basement	In hallway adjacent to room G-015 Right Low	WT-042916-10622- A	< 1	WT-042916-10622- B	< 1				
49	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010604	Cooler	Basement	In hallway adjacent to room G15 Left High	WT-042916-10621- A	< 1	WT-042916-10621- B	< 1				
50	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010603	Classroom	Basement	In room G-03 (art room), fourth one from right Right	WT-042916-10620- A	3	WT-042916-10620- B	< 1				
51	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010602	Classroom	Basement	In classroom G03 (art room) third one from right Right	WT-042916-10619- A	1.4	WT-042916-10619- B	< 1				
52	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010601	Classroom	Basement	In room G-03 art room, right 2 Right	WT-042916-10618- A	2.3	WT-042916-10618- B	< 1				
53	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010600	Classroom	Basement	In classroom G03 art room, first one from right Right	WT-042916-10617- A	7	WT-042916-10617- B	< 1				
54	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010599	Classroom	Basement	In classroom G-02	WT-042916-10616- A	< 1	WT-042916-10616- B	< 1				
55	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010598	Cooler	Basement	In hallway adjacent to room G-05	WT-042916-10615- A	< 1	WT-042916-10615- B	< 1				
56	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010597	Cooler	Basement	In hallway adjacent to janitor closet G09	WT-042916-10614- A	< 1	WT-042916-10614- B	< 1				
57	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010596	Break Room	Basement	Behind library, room G-07D	WT-042916-10613- A	< 1	WT-042916-10613- B	< 1				
58	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010595	Cooler	Basement	In hallway adjacent to media center G07	WT-042916-10612- A	< 1	WT-042916-10612- B	< 1				



STUART-HOBSON LEAD WATER TEST RESULTS

May 24th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
59	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010594	Cooler	Ground Floor	in hallway adjacent to custodian office L11 Right	WT-042916-10611- A	< 1	WT-042916-10611- B	< 1				
60	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010593	Cooler	Ground Floor	in hallway adjacent to room L-11 Left Low	WT-042916-10610- A	< 1	WT-042916-10610- B	< 1				
61	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010592	Cooler	Ground Floor	in hallway adjacent to custodian office L11 Left High	WT-042916-10609- A	< 1	WT-042916-10609- B	< 1				
62	STUART-HOBSON MIDDLE SCHOOL	5/13/2016	WS- 010591	Utility	Ground Floor	in boiler room (water source)	WT-042916-10608- A	< 1	WT-042916-10608- B	< 1				

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.