



Stuart Hobson Middle School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-010592	6/9/2020	6/9/2021	Ground Floor	Bottle Filler	In hallway adjacent to room L11 (bottle filler)	WF-06092020-010592	4/25/2021	FT-FY21-042021-010592-A	<1	FT-FY21-042021-010592-B	<1
WS-010593	6/9/2020	6/9/2021	Ground Floor	Cooler	In hallway adjacent to room L11	WF-06092020-010593	4/25/2021	FT-FY21-042021-010593-A	<1	FT-FY21-042021-010593-B	<1
WS-010594	6/9/2020	6/9/2021	Ground Floor	Cooler	In hallway adjacent to room L11	WF-06092020-010594	4/25/2021	FT-FY21-042021-010594-A	<1	FT-FY21-042021-010594-B	<1
WS-010596	6/9/2020	6/9/2021	Basement	Break Room	In break room G07D in library	WF-06092020-010596	4/25/2021	FT-FY21-042021-010596-A	<1	FT-FY21-042021-010596-B	<1
WS-010597	6/9/2020	6/9/2021	Basement	Cooler	In hallway adjacent to room G09	WF-06092020-010597	4/25/2021	FT-FY21-042021-010597-A	<1	FT-FY21-042021-010597-B	<1
WS-010598	7/6/2020	7/6/2021	Basement	Cooler	In hallway adjacent to room G05	WF-07062020-010598	4/25/2021	FT-FY21-042021-010598-A	<1	FT-FY21-042021-010598-B	<1
WS-010604	6/9/2020	6/9/2021	Basement	Cooler	In hallway adjacent to room G15	WF-06092020-010604	4/25/2021	FT-FY21-042021-010604-A	<1	FT-FY21-042021-010604-B	<1
WS-010605	6/9/2020	6/9/2021	Basement	Cooler	In hallway adjacent to room G15	WF-06092020-010605	4/25/2021	FT-FY21-042021-010605-A	<1	FT-FY21-042021-010605-B	<1
WS-010606	6/9/2020	6/9/2021	Basement	Cooler	In cafeteria on west wall	WF-06092020-010606	4/25/2021	FT-FY21-042021-010606-A	<1	FT-FY21-042021-010606-B	<1
WS-010607	6/9/2020	6/9/2021	Basement	Cooler	In cafeteria on east wall	WF-06092020-010607	4/25/2021	FT-FY21-042021-010607-A	<1	FT-FY21-042021-010607-B	<1
WS-010614	6/9/2020	6/9/2021	1	Cooler	In hallway adjacent to room 105	WF-06092020-010614	4/25/2021	FT-FY21-042021-010614-A	<1	FT-FY21-042021-010614-B	<1
WS-010615	6/9/2020	6/9/2021	1	Combo Fountain	In health suite 104	WF-06092020-010615	4/25/2021	FT-FY21-042021-010615-A	<1	FT-FY21-042021-010615-B	<1
WS-010616	6/9/2020	6/9/2021	1	Health Suite	In health suite 104	WF-06092020-010616	4/25/2021	FT-FY21-042021-010616-A	<1	FT-FY21-042021-010616-B	<1
WS-010617	6/9/2020	6/9/2021	1	Break Room	In break room 105	WF-06092020-010617	4/25/2021	FT-FY21-042021-010617-A	<1	FT-FY21-042021-010617-B	<1
WS-010620	6/9/2020	6/9/2021	1	Cooler	In hallway adjacent to room 117	WF-06092020-010620	4/25/2021	FT-FY21-042021-010620-A	<1	FT-FY21-042021-010620-B	<1
WS-010628	6/9/2020	6/9/2021	1	Break Room	In break room 120	WF-06092020-010628	4/25/2021	FT-FY21-042021-010628-A	<1	FT-FY21-042021-010628-B	<1
WS-010636	6/9/2020	6/9/2021	2	Cooler	In hallway adjacent to room 218	WF-06092020-010636	4/25/2021	FT-FY21-042021-010636-A	<1	FT-FY21-042021-010636-B	<1
WS-010640	10/7/2020	10/7/2021	2	Combo Faucet	In classroom 201	WF-10072020-010640	4/25/2021	FT-FY21-042021-010640-A	<1	FT-FY21-042021-010640-B	<1
WS-010641	6/9/2020	6/9/2021	2	Combo Fountain	In classroom 201	WF-06092020-010641	4/25/2021	FT-FY21-042021-010641-A	<1	FT-FY21-042021-010641-B	<1
WS-010648	6/9/2020	6/9/2021	3	Cooler	In hallway adjacent to room 304	WF-06092020-010648	4/25/2021	FT-FY21-042021-010648-A	<1	FT-FY21-042021-010648-B	<1
WS-010649	6/9/2020	6/9/2021	3	Cooler	In hallway adjacent to room 312	WF-06092020-010649	4/25/2021	FT-FY21-042021-010649-A	<1	FT-FY21-042021-010649-B	<1
WS-010650	6/9/2020	6/9/2021	3	Break Room	In break room 310	WF-06092020-010650	4/25/2021	FT-FY21-042021-010650-A	<1	FT-FY21-042021-010650-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-010609	2/16/2021	2/16/2022	Basement	Food Prep Sink	In kitchen second clockwise from entry door	WF-02162021-010609	4/25/2021	FT-FY21-042021-010609-A	<1	FT-FY21-042021-010609-B	<1
WS-010611	2/16/2021	2/16/2022	Basement	Food Prep Sink	In kitchen fifth clockwise from entry door	WF-02162021-010611	4/25/2021	FT-FY21-042021-010611-A	<1	FT-FY21-042021-010611-B	<1