



# Stuart Hobson Middle School Lead in Water Test Results

## FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010592	5/3/2022	5/3/2023	Ground Floor	Bottle Filler	In hallway adjacent to room L11 (bottle filler)	WF-05032022-010592	1/23/2023	FT-FY23-01102023-010592-A	<1	FT-FY23-01102023-010592-B	<1
WS- 010593	5/3/2022	5/3/2023	Ground Floor	Cooler	In hallway adjacent to room L11 Low Left	WF-05032022-010593	1/23/2023	FT-FY23-01102023-010593-A	<1	FT-FY23-01102023-010593-B	<1
WS- 010594	5/3/2022	5/3/2023	Ground Floor	Cooler	In hallway adjacent to room L11 High Right	WF-05032022-010594	1/23/2023	FT-FY23-01102023-010594-A	<1	FT-FY23-01102023-010594-B	<1
WS- 010596	5/3/2022	5/3/2023	Basement	Break Room	In break room G07D in library	WF-05032022-010596	1/23/2023	FT-FY23-01102023-010596-A	<1	FT-FY23-01102023-010596-B	<1
WS- 010597	5/3/2022	5/3/2023	Basement	Cooler	In hallway adjacent to room G09	WF-05032022-010597	1/23/2023	FT-FY23-01102023-010597-A	<1	FT-FY23-01102023-010597-B	<1
WS- 010598	5/3/2022	5/3/2023	Basement	Cooler	In hallway adjacent to room G05	WF-05032022-010598	1/23/2023	FT-FY23-01102023-010598-A	<1	FT-FY23-01102023-010598-B	<1
WS- 010604	5/3/2022	5/3/2023	Basement	Cooler	In hallway adjacent to room G15 High Left	WF-05032022-010604	1/23/2023	FT-FY23-01102023-010604-A	<1	FT-FY23-01102023-010604-B	<1
WS- 010605	5/3/2022	5/3/2023	Basement	Cooler	In hallway adjacent to room G15 Low Right	WF-05032022-010605	1/23/2023	FT-FY23-01102023-010605-A	<1	FT-FY23-01102023-010605-B	<1
WS- 010607	5/3/2022	5/3/2023	Basement	Cooler	In cafeteria on east wall	WF-05032022-010607	1/23/2023	FT-FY23-01102023-010607-A	<1	FT-FY23-01102023-010607-B	<1
WS- 010614	5/3/2022	5/3/2023	1	Cooler	In hallway adjacent to room 105	WF-05032022-010614	1/23/2023	FT-FY23-01102023-010614-A	<1	FT-FY23-01102023-010614-B	<1
WS- 010615	5/3/2022	5/3/2023	1	Combo Fountain	In health suite 104 Right	WF-05032022-010615	1/23/2023	FT-FY23-01102023-010615-A	1.6	FT-FY23-01102023-010615-B	<1
WS- 010616	5/3/2022	5/3/2023	1	Health Suite	In health suite 104 Left	WF-05032022-010616	1/23/2023	FT-FY23-01102023-010616-A	<1	FT-FY23-01102023-010616-B	<1
WS- 010617	5/3/2022	5/3/2023	1	Break Room	In break room 105	WF-05032022-010617	1/23/2023	FT-FY23-01102023-010617-A	<1	FT-FY23-01102023-010617-B	<1
WS- 010619	5/3/2022	5/3/2023	1	Cooler	In hallway adjacent to girls' restroom	WF-05032022-010619	1/23/2023	FT-FY23-01102023-010619-A	<1	FT-FY23-01102023-010619-B	<1
WS- 010620	5/3/2022	5/3/2023	1	Cooler	In hallway adjacent to room 117	WF-05032022-010620	1/23/2023	FT-FY23-01102023-010620-A	<1	FT-FY23-01102023-010620-B	<1
WS- 010628	5/3/2022	5/3/2023	1	Break Room	In break room 120 Left	WF-05032022-010628	1/23/2023	FT-FY23-01102023-010628-A	<1	FT-FY23-01102023-010628-B	<1
WS- 010636	5/3/2022	5/3/2023	2	Cooler	In hallway adjacent to room 218	WF-05032022-010636	1/23/2023	FT-FY23-01102023-010636-A	<1	FT-FY23-01102023-010636-B	<1
WS- 010638	5/3/2022	5/3/2023	2	Cooler	In hallway adjacent to room 213	WF-05032022-010638	1/23/2023	FT-FY23-01102023-010638-A	<1	FT-FY23-01102023-010638-B	<1
WS- 010639	5/3/2022	5/3/2023	2	Cooler	In hallway adjacent to room 203	WF-05032022-010639	1/23/2023	FT-FY23-01102023-010639-A	<1	FT-FY23-01102023-010639-B	<1
WS- 010640	9/21/2022	9/21/2023	2	Combo Faucet	In classroom 201 Left	WF-09212022-010640	1/23/2023	FT-FY23-01102023-010640-A	3.9	FT-FY23-01102023-010640-B	<1
WS- 010641	5/3/2022	5/3/2023	2	Combo Fountain	In classroom 201 Right	WF-05032022-010641	1/23/2023	FT-FY23-01102023-010641-A	<1	FT-FY23-01102023-010641-B	<1
WS- 010648	5/3/2022	5/3/2023	3	Cooler	In hallway adjacent to room 304	WF-05032022-010648	1/23/2023	FT-FY23-01102023-010648-A	<1	FT-FY23-01102023-010648-B	<1
WS- 010649	5/3/2022	5/3/2023	3	Cooler	In hallway adjacent to room 312	WF-05032022-010649	1/23/2023	FT-FY23-01102023-010649-A	<1	FT-FY23-01102023-010649-B	<1
WS- 010650	5/3/2022	5/3/2023	3	Break Room	In break room 310	WF-05032022-010650	1/23/2023	FT-FY23-01102023-010650-A	<1	FT-FY23-01102023-010650-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010609	2/10/2022	2/10/2023	Basement	Food Prep Sink	In kitchen second clockwise from entry door Mid	WF-02102022-010609	1/23/2023	FT-FY23-01102023-010609-A	<1	FT-FY23-01102023-010609-B	<1
WS- 010611	2/10/2022	2/10/2023	Basement	Food Prep Sink	In kitchen fifth clockwise from entry door	WF-02102022-010611	1/23/2023	FT-FY23-01102023-010611-A	<1	FT-FY23-01102023-010611-B	<1