



Stuart Hobson MS Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010592	4/23/2019	4/23/2020	Ground Floor	Bottle Filler	In hallway adjacent to room L11 (bottle filler)	WF-04232019-010592	1/5/2020	FT-FY20-122019-010592-A	<1	FT-FY20-122019-010592-B	<1
WS- 010593	4/23/2019	4/23/2020	Ground Floor	Cooler	In hallway adjacent to room L11 Low Left	WF-04232019-010593	1/5/2020	FT-FY20-122019-010593-A	<1	FT-FY20-122019-010593-B	<1
WS- 010594	4/23/2019	4/23/2020	Ground Floor	Cooler	In hallway adjacent to room L11 High Right	WF-04232019-010594	1/5/2020	FT-FY20-122019-010594-A	<1	FT-FY20-122019-010594-B	<1
WS- 010595	4/23/2019	4/23/2020	Basement	Cooler	In hallway adjacent to room G07	WF-04232019-010595	1/5/2020	FT-FY20-122019-010595-A	<1	FT-FY20-122019-010595-B	<1
WS- 010596	4/23/2019	4/23/2020	Basement	Break Room	In break room G07D in library	WF-04232019-010596	1/5/2020	FT-FY20-122019-010596-A	<1	FT-FY20-122019-010596-B	<1
WS- 010597	4/23/2019	4/23/2020	Basement	Cooler	In hallway adjacent to room G09	WF-04232019-010597	1/5/2020	FT-FY20-122019-010597-A	<1	FT-FY20-122019-010597-B	<1
WS- 010598	4/23/2019	4/23/2020	Basement	Cooler	In hallway adjacent to room G05	WF-04232019-010598	1/5/2020	FT-FY20-122019-010598-A	<1	FT-FY20-122019-010598-B	<1
WS- 010604	4/23/2019	4/23/2020	Basement	Cooler	In hallway adjacent to room G15 High Left	WF-04232019-010604	1/5/2020	FT-FY20-122019-010604-A	<1	FT-FY20-122019-010604-B	<1
WS- 010605	4/23/2019	4/23/2020	Basement	Cooler	In hallway adjacent to room G15 Low Right	WF-04232019-010605	1/5/2020	FT-FY20-122019-010605-A	<1	FT-FY20-122019-010605-B	<1
WS- 010606	4/23/2019	4/23/2020	Basement	Cooler	In cafeteria on west wall	WF-04232019-010606	1/5/2020	FT-FY20-122019-010606-A	<1	FT-FY20-122019-010606-B	<1
WS- 010607	4/23/2019	4/23/2020	Basement	Cooler	In cafeteria on east wall	WF-04232019-010607	1/5/2020	FT-FY20-122019-010607-A	<1	FT-FY20-122019-010607-B	<1
WS- 010614	4/23/2019	4/23/2020	1	Cooler	In hallway adjacent to room 105	WF-04232019-010614	1/5/2020	FT-FY20-122019-010614-A	<1	FT-FY20-122019-010614-B	<1
WS- 010615	4/23/2019	4/23/2020	1	Combo Fountain	In health suite 104 Right	WF-04232019-010615	1/5/2020	FT-FY20-122019-010615-A	<1	FT-FY20-122019-010615-B	<1
WS- 010616	4/23/2019	4/23/2020	1	Health Suite	In health suite 104 Left	WF-04232019-010616	1/5/2020	FT-FY20-122019-010616-A	<1	FT-FY20-122019-010616-B	<1
WS- 010617	4/23/2019	4/23/2020	1	Break Room	In break room 105	WF-04232019-010617	1/5/2020	FT-FY20-122019-010617-A	<1	FT-FY20-122019-010617-B	<1
WS- 010619	4/23/2019	4/23/2020	1	Cooler	In hallway adjacent to girls' restroom	WF-04232019-010619	1/5/2020	FT-FY20-122019-010619-A	<1	FT-FY20-122019-010619-B	<1
WS- 010620	4/23/2019	4/23/2020	1	Cooler	In hallway adjacent to room 117	WF-04232019-010620	1/5/2020	FT-FY20-122019-010620-A	<1	FT-FY20-122019-010620-B	<1
WS- 010628	4/23/2019	4/23/2020	1	Break Room	In break room 120 Left	WF-04232019-010628	1/5/2020	FT-FY20-122019-010628-A	<1	FT-FY20-122019-010628-B	<1
WS- 010636	4/23/2019	4/23/2020	2	Cooler	In hallway adjacent to room 218	WF-04232019-010636	1/5/2020	FT-FY20-122019-010636-A	<1	FT-FY20-122019-010636-B	<1
WS- 010638	4/23/2019	4/23/2020	2	Cooler	In hallway adjacent to room 213	WF-04232019-010638	1/5/2020	FT-FY20-122019-010638-A	<1	FT-FY20-122019-010638-B	<1
WS- 010640	10/14/2019	10/14/2020	2	Combo Faucet	In classroom 201 Left	WF-10142019-010640	1/5/2020	FT-FY20-122019-010640-A	<1	FT-FY20-122019-010640-B	<1
WS- 010641	4/23/2019	4/23/2020	2	Combo Fountain	In classroom 201 Right	WF-04232019-010641	1/5/2020	FT-FY20-122019-010641-A	<1	FT-FY20-122019-010641-B	<1
WS- 010648	4/23/2019	4/23/2020	3	Cooler	In hallway adjacent to room 304	WF-04232019-010648	1/5/2020	FT-FY20-122019-010648-A	<1	FT-FY20-122019-010648-B	<1
WS- 010649	4/23/2019	4/23/2020	3	Cooler	In hallway adjacent to room 312	WF-04232019-010649	1/5/2020	FT-FY20-122019-010649-A	<1	FT-FY20-122019-010649-B	<1
WS- 010650	4/23/2019	4/23/2020	3	Break Room	In break room 310	WF-04232019-010650	1/5/2020	FT-FY20-122019-010650-A	<1	FT-FY20-122019-010650-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010609	7/9/2019	7/9/2020	Basement	Food Prep Sink	In kitchen second clockwise from entry door Mid	WF-07092019-010609	1/5/2020	FT-FY20-122019-010609-A	<1	FT-FY20-122019-010609-B	<1
WS- 010611	7/9/2019	7/9/2020	Basement	Food Prep Sink	In kitchen fifth clockwise from entry door	WF-07092019-010611	1/5/2020	FT-FY20-122019-010611-A	<1	FT-FY20-122019-010611-B	<1