



STUART HOBSON MS LEAD WATER TEST RESULTS



Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	STUART-HOBSON MIDDLE SCHOOL	WS- 010596	1/7/2017	Basement	Break Room	In break room G07D in library	FT-102016-010596-A	< 1	FT-102016-010596-B	< 1
2	STUART-HOBSON MIDDLE SCHOOL	WS- 010628	1/7/2017	1	Break Room	In break room 120 Left	FT-102016-010628-A	< 1	FT-102016-010628-B	< 1
3	STUART-HOBSON MIDDLE SCHOOL	WS- 010617	1/7/2017	1	Break Room	In break room 105	FT-102016-010617-A	< 1	FT-102016-010617-B	< 1
4	STUART-HOBSON MIDDLE SCHOOL	WS- 010650	1/7/2017	3	Break Room	In break room 310	FT-102016-010650-A	< 1	FT-102016-010650-B	< 1
5	STUART-HOBSON MIDDLE SCHOOL	WS- 010640	1/7/2017	2	Combo Faucet	In classroom 201 Left	FT-112016-010640-A	< 1	FT-112016-010640-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb