



# Stuart Hobson MS Lead Water Test Results



## FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

| Record ID  | Filter Installed Date | Filter Expiration Date | Floor        | Device Type    | Device Location                                 | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID    | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID    | FT Final Result - 2nd Draw (ppb) |
|------------|-----------------------|------------------------|--------------|----------------|---|---------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| WS- 010592 | 5/2/2018              | 5/2/2019               | Ground Floor | Bottle Filler  | In hallway adjacent to room L11 (bottle filler) | WF-05022018-010592  | 12/24/2018    | FT-FY19-122018-010592-A | <1                               | FT-FY19-122018-010592-B | <1                               |
| WS- 010593 | 5/2/2018              | 5/2/2019               | Ground Floor | Cooler         | In hallway adjacent to room L11 Low Left        | WF-05022018-010593  | 12/24/2018    | FT-FY19-122018-010593-A | <1                               | FT-FY19-122018-010593-B | <1                               |
| WS- 010594 | 5/2/2018              | 5/2/2019               | Ground Floor | Cooler         | In hallway adjacent to room L11 High Right      | WF-05022018-010594  | 12/24/2018    | FT-FY19-122018-010594-A | <1                               | FT-FY19-122018-010594-B | <1                               |
| WS- 010595 | 5/2/2018              | 5/2/2019               | Basement     | Cooler         | In hallway adjacent to room G07                 | WF-05022018-010595  | 12/24/2018    | FT-FY19-122018-010595-A | <1                               | FT-FY19-122018-010595-B | <1                               |
| WS- 010596 | 5/2/2018              | 5/2/2019               | Basement     | Break Room     | In break room G07D in library                   | WF-05022018-010596  | 12/24/2018    | FT-FY19-122018-010596-A | <1                               | FT-FY19-122018-010596-B | <1                               |
| WS- 010597 | 5/2/2018              | 5/2/2019               | Basement     | Cooler         | In hallway adjacent to room G09                 | WF-05022018-010597  | 12/24/2018    | FT-FY19-122018-010597-A | <1                               | FT-FY19-122018-010597-B | <1                               |
| WS- 010598 | 10/19/2018            | 10/19/2019             | Basement     | Cooler         | In hallway adjacent to room G05                 | WF-10192018-010598  | 12/24/2018    | FT-FY19-122018-010598-A | <1                               | FT-FY19-122018-010598-B | <1                               |
| WS- 010604 | 5/2/2018              | 5/2/2019               | Basement     | Cooler         | In hallway adjacent to room G15 High Left       | WF-05022018-010604  | 12/24/2018    | FT-FY19-122018-010604-A | <1                               | FT-FY19-122018-010604-B | <1                               |
| WS- 010605 | 10/24/2018            | 10/24/2019             | Basement     | Cooler         | In hallway adjacent to room G15 Low Right       | WF-10242018-010605  | 12/24/2018    | FT-FY19-122018-010605-A | <1                               | FT-FY19-122018-010605-B | <1                               |
| WS- 010606 | 5/2/2018              | 5/2/2019               | Basement     | Cooler         | In cafeteria on west wall                       | WF-05022018-010606  | 12/24/2018    | FT-FY19-122018-010606-A | <1                               | FT-FY19-122018-010606-B | <1                               |
| WS- 010607 | 5/2/2018              | 5/2/2019               | Basement     | Cooler         | In cafeteria on east wall                       | WF-05022018-010607  | 12/24/2018    | FT-FY19-122018-010607-A | <1                               | FT-FY19-122018-010607-B | <1                               |
| WS- 010614 | 5/2/2018              | 5/2/2019               | 1            | Cooler         | In hallway adjacent to room 105                 | WF-05022018-010614  | 12/24/2018    | FT-FY19-122018-010614-A | <1                               | FT-FY19-122018-010614-B | <1                               |
| WS- 010615 | 5/2/2018              | 5/2/2019               | 1            | Combo Fountain | In health suite 104 Right                       | WF-05022018-010615  | 12/24/2018    | FT-FY19-122018-010615-A | <1                               | FT-FY19-122018-010615-B | <1                               |
| WS- 010616 | 5/2/2018              | 5/2/2019               | 1            | Health Suite   | In health suite 104 Left                        | WF-05022018-010616  | 12/24/2018    | FT-FY19-122018-010616-A | <1                               | FT-FY19-122018-010616-B | <1                               |
| WS- 010617 | 5/2/2018              | 5/2/2019               | 1            | Break Room     | In break room 105                               | WF-05022018-010617  | 12/24/2018    | FT-FY19-122018-010617-A | <1                               | FT-FY19-122018-010617-B | <1                               |
| WS- 010619 | 5/2/2018              | 5/2/2019               | 1            | Cooler         | In hallway adjacent to girls' restroom          | WF-05022018-010619  | 12/24/2018    | FT-FY19-122018-010619-A | <1                               | FT-FY19-122018-010619-B | <1                               |
| WS- 010620 | 5/2/2018              | 5/2/2019               | 1            | Cooler         | In hallway adjacent to room 117                 | WF-05022018-010620  | 12/24/2018    | FT-FY19-122018-010620-A | <1                               | FT-FY19-122018-010620-B | <1                               |
| WS- 010628 | 5/2/2018              | 5/2/2019               | 1            | Break Room     | In break room 120 Left                          | WF-05022018-010628  | 12/24/2018    | FT-FY19-122018-010628-A | <1                               | FT-FY19-122018-010628-B | <1                               |
| WS- 010636 | 5/2/2018              | 5/2/2019               | 2            | Cooler         | In hallway adjacent to room 218                 | WF-05022018-010636  | 12/24/2018    | FT-FY19-122018-010636-A | <1                               | FT-FY19-122018-010636-B | <1                               |
| WS- 010638 | 5/2/2018              | 5/2/2019               | 2            | Cooler         | In hallway adjacent to room 213                 | WF-05022018-010638  | 12/24/2018    | FT-FY19-122018-010638-A | <1                               | FT-FY19-122018-010638-B | <1                               |
| WS- 010639 | 5/2/2018              | 5/2/2019               | 2            | Cooler         | In hallway adjacent to room 203                 | WF-05022018-010639  | 12/24/2018    | FT-FY19-122018-010639-A | <1                               | FT-FY19-122018-010639-B | <1                               |
| WS- 010640 | 10/23/2018            | 10/23/2019             | 2            | Combo Faucet   | In classroom 201 Left                           | WF-10232018-010640  | 12/24/2018    | FT-FY19-122018-010640-A | 1.9                              | FT-FY19-122018-010640-B | <1                               |
| WS- 010641 | 5/2/2018              | 5/2/2019               | 2            | Combo Fountain | In classroom 201 Right                          | WF-05022018-010641  | 12/24/2018    | FT-FY19-122018-010641-A | <1                               | FT-FY19-122018-010641-B | <1                               |
| WS- 010648 | 5/2/2018              | 5/2/2019               | 3            | Cooler         | In hallway adjacent to room 304                 | WF-05022018-010648  | 12/24/2018    | FT-FY19-122018-010648-A | <1                               | FT-FY19-122018-010648-B | <1                               |
| WS- 010649 | 5/2/2018              | 5/2/2019               | 3            | Cooler         | In hallway adjacent to room 312                 | WF-05022018-010649  | 12/24/2018    | FT-FY19-122018-010649-A | <1                               | FT-FY19-122018-010649-B | <1                               |
| WS- 010650 | 5/2/2018              | 5/2/2019               | 3            | Break Room     | In break room 310                               | WF-05022018-010650  | 12/24/2018    | FT-FY19-122018-010650-A | <1                               | FT-FY19-122018-010650-B | <1                               |

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation

| Record ID  | Floor    | Device Type    | Device Location                                  | Date Analyzed | 1st Draw - Sample ID    | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID    | FT Final Result - 2nd Draw (ppb) |
|------------|----------|----------------|--|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| WS- 010609 | Basement | Food Prep Sink | In kitchen second clockwise from entry door Mid  | 12/24/2018    | FT-FY19-122018-010609-A | <1                               | FT-FY19-122018-010609-B | <1                               |
| WS- 010610 | Basement | Food Prep Sink | In kitchen third clockwise from entry door Right | 12/24/2018    | FT-FY19-122018-010610-A | <1                               | FT-FY19-122018-010610-B | <1                               |