



Stuart-Hobson Middle School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 006907	4/24/2023	4/24/2024	1	Bottle Filler	In hallway adjacent to room 117	WF-04242023-006907	1/5/2024	FT-FY24-11272023-006907-A	<1	FT-FY24-11272023-006907-B	<1
WS- 006940	11/9/2023	11/9/2024	2	Bottle Filler	In hallway adjacent to room 203	WF-11092023-006940	1/5/2024	FT-FY24-11272023-006940-A	<1	FT-FY24-11272023-006940-B	<1
WS- 010592	4/24/2023	4/24/2024	Ground Floor	Bottle Filler	In hallway adjacent to room L11 (bottle filler)	WF-04242023-010592	1/5/2024	FT-FY24-11272023-010592-A	<1	FT-FY24-11272023-010592-B	<1
WS- 010593	4/24/2023	4/24/2024	Ground Floor	Cooler	In hallway adjacent to room L11 Low Left	WF-04242023-010593	1/5/2024	FT-FY24-11272023-010593-A	<1	FT-FY24-11272023-010593-B	<1
WS- 010594	4/24/2023	4/24/2024	Ground Floor	Cooler	In hallway adjacent to room L11 High Right	WF-04242023-010594	1/5/2024	FT-FY24-11272023-010594-A	<1	FT-FY24-11272023-010594-B	<1
WS- 010597	4/24/2023	4/24/2024	Basement	Cooler	In hallway adjacent to room G09	WF-04242023-010597	1/5/2024	FT-FY24-11272023-010597-A	<1	FT-FY24-11272023-010597-B	<1
WS- 010598	4/24/2023	4/24/2024	Basement	Cooler	In hallway adjacent to room G05	WF-04242023-010598	1/5/2024	FT-FY24-11272023-010598-A	<1	FT-FY24-11272023-010598-B	<1
WS- 010604	4/24/2023	4/24/2024	Basement	Cooler	In hallway adjacent to room G15 High Left	WF-04242023-010604	1/5/2024	FT-FY24-11272023-010604-A	<1	FT-FY24-11272023-010604-B	<1
WS- 010605	4/24/2023	4/24/2024	Basement	Cooler	In hallway adjacent to room G15 Low Right	WF-04242023-010605	1/5/2024	FT-FY24-11272023-010605-A	<1	FT-FY24-11272023-010605-B	<1
WS- 010607	4/24/2023	4/24/2024	Basement	Cooler	In cafeteria on east wall	WF-04242023-010607	1/5/2024	FT-FY24-11272023-010607-A	<1	FT-FY24-11272023-010607-B	<1
WS- 010614	4/24/2023	4/24/2024	1	Cooler	In hallway adjacent to room 105	WF-04242023-010614	1/5/2024	FT-FY24-11272023-010614-A	<1	FT-FY24-11272023-010614-B	<1
WS- 010615	4/24/2023	4/24/2024	1	Combo Fountain	In health suite 104 Right	WF-04242023-010615	1/5/2024	FT-FY24-11272023-010615-A	<1	FT-FY24-11272023-010615-B	<1
WS- 010616	4/24/2023	4/24/2024	1	Health Suite	In health suite 104 Left	WF-04242023-010616	1/5/2024	FT-FY24-11272023-010616-A	<1	FT-FY24-11272023-010616-B	<1
WS- 010617	4/24/2023	4/24/2024	1	Break Room	In break room 105	WF-04242023-010617	1/5/2024	FT-FY24-11272023-010617-A	<1	FT-FY24-11272023-010617-B	<1
WS- 010619	4/24/2023	4/24/2024	1	Cooler	In hallway adjacent to girls' restroom	WF-04242023-010619	1/5/2024	FT-FY24-11272023-010619-A	<1	FT-FY24-11272023-010619-B	<1
WS- 010620	4/24/2023	4/24/2024	1	Cooler	In hallway adjacent to room 117	WF-04242023-010620	1/5/2024	FT-FY24-11272023-010620-A	<1	FT-FY24-11272023-010620-B	<1
WS- 010628	4/24/2023	4/24/2024	1	Break Room	In break room 120 Left	WF-04242023-010628	1/5/2024	FT-FY24-11272023-010628-A	<1	FT-FY24-11272023-010628-B	<1
WS- 010636	4/24/2023	4/24/2024	2	Cooler	In hallway adjacent to room 218	WF-04242023-010636	1/5/2024	FT-FY24-11272023-010636-A	<1	FT-FY24-11272023-010636-B	<1
WS- 010638	4/24/2023	4/24/2024	2	Cooler	In hallway adjacent to room 213	WF-04242023-010638	1/5/2024	FT-FY24-11272023-010638-A	<1	FT-FY24-11272023-010638-B	<1
WS- 010639	11/9/2023	11/9/2024	2	Cooler	In hallway adjacent to room 203	WF-11092023-010639	1/5/2024	FT-FY24-11272023-010639-A	<1	FT-FY24-11272023-010639-B	<1
WS- 010640	9/14/2023	9/14/2024	2	Combo Faucet	In classroom 201 Left	WF-09142023-010640	1/5/2024	FT-FY24-11272023-010640-A	<1	FT-FY24-11272023-010640-B	<1
WS- 010641	4/24/2023	4/24/2024	2	Combo Fountain	In classroom 201 Right	WF-04242023-010641	1/5/2024	FT-FY24-11272023-010641-A	<1	FT-FY24-11272023-010641-B	<1
WS- 010648	4/24/2023	4/24/2024	3	Cooler	In hallway adjacent to room 304	WF-04242023-010648	1/5/2024	FT-FY24-11272023-010648-A	<1	FT-FY24-11272023-010648-B	<1
WS- 010649	4/24/2023	4/24/2024	3	Cooler	In hallway adjacent to room 312	WF-04242023-010649	1/5/2024	FT-FY24-11272023-010649-A	<1	FT-FY24-11272023-010649-B	<1
WS- 010650	4/24/2023	4/24/2024	3	Break Room	In break room 310	WF-04242023-010650	1/5/2024	FT-FY24-11272023-010650-A	<1	FT-FY24-11272023-010650-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010609	1/17/2023	1/17/2024	Basement	Food Prep Sink	In kitchen second clockwise from entry door Mid	WF-01172023-010609	1/5/2024	FT-FY24-11272023-010609-A	<1	FT-FY24-11272023-010609-B	<1
WS- 010611	1/17/2023	1/17/2024	Basement	Food Prep Sink	In kitchen fifth clockwise from entry door	WF-01172023-010611	1/5/2024	FT-FY24-11272023-010611-A	<1	FT-FY24-11272023-010611-B	<1