



# Takoma Education Campus Lead in Water Test Results

## FY25 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001575	10/11/2024	10/11/2025	1	Bottle Filler	In hallway adjacent to room 141	WF-10112024-001575	11/26/2024	FT-FY25-10312024-001575-A	<2	FT-FY25-10312024-001575-B	<2
WS-009963	9/10/2024	9/10/2025	1	Classroom Faucet	In classroom 148	WF-09102024-009963	11/26/2024	FT-FY25-10312024-009963-A	<2	FT-FY25-10312024-009963-B	<2
WS-009965	9/10/2024	9/10/2025	1	Classroom Faucet	In classroom 142	WF-09102024-009965	11/26/2024	FT-FY25-10312024-009965-A	<2	FT-FY25-10312024-009965-B	<2
WS-009966	10/11/2024	10/11/2025	1	Cooler	In hallway adjacent to room 141	Low Right WF-10112024-009966	11/26/2024	FT-FY25-10312024-009966-A	<2	FT-FY25-10312024-009966-B	<2
WS-009967	10/11/2024	10/11/2025	1	Cooler	In hallway adjacent to room 141	High Left WF-10112024-009967	11/26/2024	FT-FY25-10312024-009967-A	<2	FT-FY25-10312024-009967-B	<2
WS-009968	2/12/2024	2/12/2025	1	Cooler	In hallway adjacent to room 133	Low Right WF-02122024-009968	11/26/2024	FT-FY25-10312024-009968-A	<2	FT-FY25-10312024-009968-B	<2
WS-009969	2/12/2024	2/12/2025	1	Cooler	In hallway adjacent to room 133	High Left WF-02122024-009969	11/26/2024	FT-FY25-10312024-009969-A	<2	FT-FY25-10312024-009969-B	<2
WS-009971	9/10/2024	9/10/2025	1	Classroom Faucet	In classroom 132	WF-09102024-009971	11/26/2024	FT-FY25-10312024-009971-A	<2	FT-FY25-10312024-009971-B	<2
WS-009973	2/12/2024	2/12/2025	1	Health Suite	In health suite	WF-02122024-009973	11/26/2024	FT-FY25-10312024-009973-A	<2	FT-FY25-10312024-009973-B	<2
WS-009974	9/10/2024	9/10/2025	1	Classroom Faucet	In classroom 116	WF-09102024-009974	11/26/2024	FT-FY25-10312024-009974-A	<2	FT-FY25-10312024-009974-B	<2
WS-009975	9/10/2024	9/10/2025	1	Classroom Faucet	In classroom 113	WF-09102024-009975	11/26/2024	FT-FY25-10312024-009975-A	<2	FT-FY25-10312024-009975-B	<2
WS-009976	9/10/2024	9/10/2025	1	Classroom Faucet	In classroom 110	WF-09102024-009976	11/26/2024	FT-FY25-10312024-009976-A	<2	FT-FY25-10312024-009976-B	<2
WS-009977	9/10/2024	9/10/2025	1	Classroom Faucet	In classroom 127	WF-09102024-009977	11/26/2024	FT-FY25-10312024-009977-A	<2	FT-FY25-10312024-009977-B	<2
WS-009978	2/12/2024	2/12/2025	1	Cooler	In hallway adjacent to room G107	WF-02122024-009978	11/26/2024	FT-FY25-10312024-009978-A	<2	FT-FY25-10312024-009978-B	<2
WS-009980	2/12/2024	2/12/2025	2	Break Room	In staff lounge 218	WF-02122024-009980	11/26/2024	FT-FY25-10312024-009980-A	<2	FT-FY25-10312024-009980-B	<2
WS-009981	2/12/2024	2/12/2025	2	Cooler	In hallway adjacent to elevator	High Left WF-02122024-009981	11/26/2024	FT-FY25-10312024-009981-A	<2	FT-FY25-10312024-009981-B	<2
WS-009982	2/12/2024	2/12/2025	2	Cooler	In hallway adjacent to elevator	Low Right WF-02122024-009982	11/26/2024	FT-FY25-10312024-009982-A	<2	FT-FY25-10312024-009982-B	<2
WS-009983	2/12/2024	2/12/2025	2	Cooler	In hallway adjacent to stairwell 4	High Left WF-02122024-009983	11/26/2024	FT-FY25-10312024-009983-A	<2	FT-FY25-10312024-009983-B	<2
WS-009984	2/12/2024	2/12/2025	2	Cooler	In hallway adjacent to stairwell 4	Low Right WF-02122024-009984	11/26/2024	FT-FY25-10312024-009984-A	<2	FT-FY25-10312024-009984-B	<2
WS-009988	2/12/2024	2/12/2025	3	Break Room	In staff lounge 318	WF-02122024-009988	11/26/2024	FT-FY25-10312024-009988-A	<2	FT-FY25-10312024-009988-B	<2
WS-009995	2/12/2024	2/12/2025	3	Cooler	In hallway adjacent to room 327	High Left WF-02122024-009995	11/26/2024	FT-FY25-10312024-009995-A	<2	FT-FY25-10312024-009995-B	<2
WS-009996	2/12/2024	2/12/2025	3	Cooler	In hallway adjacent to room 327	Low Right WF-02122024-009996	11/26/2024	FT-FY25-10312024-009996-A	<2	FT-FY25-10312024-009996-B	<2

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009959	12/4/2023	12/4/2024	1	Food Prep Sink	In kitchen first clockwise from entry door (dishwashing hose)	WF-12042023-009959	11/26/2024	FT-FY25-10312024-009959-A	<2	FT-FY25-10312024-009959-B	<2

## FY25 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009970	9/10/2024	9/10/2025	1	Classroom Faucet	In classroom 133	WF-09102024-009970	11/26/2024	FT-FY25-10312024-009970-A	6.0	FT-FY25-10312024-009970-B	<2

**After First Re-test (Plumbing Check)**

**FY25 Filter Test**

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009970	12/3/2024	12/3/2025	1	Classroom Faucet	In classroom 133	WF-12032024-009970	12/17/2024	FT-FY25-12032024-009970-A	6.6	FT-FY25-12032024-009970-B	<2

**After Second Re-test (Device Replacement)**

**FY25 Filter Test**

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009970	12/26/2024	12/26/2025	1	Classroom Faucet	In classroom 133	WF-12262024-009970	1/7/2025	FT-FY25-01022025-009970-A	<2	FT-FY25-01022025-009970-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.