



# Takoma Education Campus Lead in Water Test Results

## FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009963	9/28/2021	9/28/2022	1	Classroom Faucet	In classroom 148	WF-09282021-009963	12/17/2021	FT-FY22-12012021-009963-A	<1	FT-FY22-12012021-009963-B	<1
WS-009965	9/28/2021	9/28/2022	1	Classroom Faucet	In classroom 142	WF-09282021-009965	12/17/2021	FT-FY22-12012021-009965-A	<1	FT-FY22-12012021-009965-B	<1
WS-009966	3/1/2021	3/1/2022	1	Cooler	In hallway adjacent to room 141	Low Right WF-03012021-009966	12/17/2021	FT-FY22-12012021-009966-A	<1	FT-FY22-12012021-009966-B	<1
WS-009967	3/1/2021	3/1/2022	1	Cooler	In hallway adjacent to room 141	High Left WF-03012021-009967	12/17/2021	FT-FY22-12012021-009967-A	<1	FT-FY22-12012021-009967-B	<1
WS-009968	3/1/2021	3/1/2022	1	Cooler	In hallway adjacent to room 133	Low Right WF-03012021-009968	12/17/2021	FT-FY22-12012021-009968-A	<1	FT-FY22-12012021-009968-B	<1
WS-009969	3/1/2021	3/1/2022	1	Cooler	In hallway adjacent to room 133	High Left WF-03012021-009969	12/17/2021	FT-FY22-12012021-009969-A	<1	FT-FY22-12012021-009969-B	<1
WS-009970	9/28/2021	9/28/2022	1	Classroom Faucet	In classroom 133	WF-09282021-009970	12/17/2021	FT-FY22-12012021-009970-A	<1	FT-FY22-12012021-009970-B	<1
WS-009971	9/28/2021	9/28/2022	1	Classroom Faucet	In classroom 132	WF-09282021-009971	12/17/2021	FT-FY22-12012021-009971-A	<1	FT-FY22-12012021-009971-B	<1
WS-009973	3/1/2021	3/1/2022	1	Health Suite	In health suite	WF-03012021-009973	12/17/2021	FT-FY22-12012021-009973-A	<1	FT-FY22-12012021-009973-B	<1
WS-009974	9/28/2021	9/28/2022	1	Classroom Faucet	In classroom 116	WF-09282021-009974	12/17/2021	FT-FY22-12012021-009974-A	<1	FT-FY22-12012021-009974-B	<1
WS-009975	9/28/2021	9/28/2022	1	Classroom Faucet	In classroom 113	WF-09282021-009975	12/17/2021	FT-FY22-12012021-009975-A	<1	FT-FY22-12012021-009975-B	<1
WS-009976	9/28/2021	9/28/2022	1	Classroom Faucet	In classroom 110	WF-09282021-009976	12/17/2021	FT-FY22-12012021-009976-A	<1	FT-FY22-12012021-009976-B	<1
WS-009978	3/1/2021	3/1/2022	1	Cooler	In hallway adjacent to room G107	WF-03012021-009978	12/17/2021	FT-FY22-12012021-009978-A	<1	FT-FY22-12012021-009978-B	<1
WS-009979	3/1/2021	3/1/2022	1	Cooler	In hallway adjacent to room G115	WF-03012021-009979	12/17/2021	FT-FY22-12012021-009979-A	<1	FT-FY22-12012021-009979-B	<1
WS-009980	3/1/2021	3/1/2022	2	Break Room	In staff lounge 218	WF-03012021-009980	12/17/2021	FT-FY22-12012021-009980-A	<1	FT-FY22-12012021-009980-B	<1
WS-009981	3/1/2021	3/1/2022	2	Cooler	In hallway adjacent to elevator	High Left WF-03012021-009981	12/17/2021	FT-FY22-12012021-009981-A	<1	FT-FY22-12012021-009981-B	<1
WS-009982	3/1/2021	3/1/2022	2	Cooler	In hallway adjacent to elevator	Low Right WF-03012021-009982	12/17/2021	FT-FY22-12012021-009982-A	<1	FT-FY22-12012021-009982-B	<1
WS-009983	3/1/2021	3/1/2022	2	Cooler	In hallway adjacent to stairwell 4	High Left WF-03012021-009983	12/17/2021	FT-FY22-12012021-009983-A	<1	FT-FY22-12012021-009983-B	<1
WS-009984	3/1/2021	3/1/2022	2	Cooler	In hallway adjacent to stairwell 4	Low Right WF-03012021-009984	12/17/2021	FT-FY22-12012021-009984-A	<1	FT-FY22-12012021-009984-B	<1
WS-009988	3/1/2021	3/1/2022	3	Break Room	In staff lounge 318	WF-03012021-009988	12/17/2021	FT-FY22-12012021-009988-A	<1	FT-FY22-12012021-009988-B	<1
WS-009989	3/1/2021	3/1/2022	3	Cooler	In hallway adjacent to elevator	High Left WF-03012021-009989	12/17/2021	FT-FY22-12012021-009989-A	<1	FT-FY22-12012021-009989-B	<1
WS-009990	3/1/2021	3/1/2022	3	Cooler	In hallway adjacent to elevator	Low Right WF-03012021-009990	12/17/2021	FT-FY22-12012021-009990-A	<1	FT-FY22-12012021-009990-B	<1
WS-009995	3/1/2021	3/1/2022	3	Cooler	In hallway adjacent to room 327	High Left WF-03012021-009995	12/17/2021	FT-FY22-12012021-009995-A	<1	FT-FY22-12012021-009995-B	<1
WS-009996	3/1/2021	3/1/2022	3	Cooler	In hallway adjacent to room 327	Low Right WF-03012021-009996	12/17/2021	FT-FY22-12012021-009996-A	<1	FT-FY22-12012021-009996-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009959	2/4/2021	2/4/2022	1	Food Prep Sink	In kitchen first clockwise from entry door (dishwashing hose)	WF-02042021-009959	12/17/2021	FT-FY22-12012021-009959-A	<1	FT-FY22-12012021-009959-B	<1