



Takoma Education Campus Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009963	10/5/2020	10/5/2021	1	Classroom Faucet	In classroom 148	WF-10052020-009963	2/24/2021	FT-FY21-022021-009963-A	1.3	FT-FY21-022021-009963-B	1.1	
WS- 009965	10/5/2020	10/5/2021	1	Classroom Faucet	In classroom 142	WF-10052020-009965	2/24/2021	FT-FY21-022021-009965-A	1.0	FT-FY21-022021-009965-B	<1	
WS- 009966	3/11/2020	3/11/2021	1	Cooler	In hallway adjacent to room 141	Low Right	WF-03112020-009966	2/24/2021	FT-FY21-022021-009966-A	<1	FT-FY21-022021-009966-B	<1
WS- 009967	3/11/2020	3/11/2021	1	Cooler	In hallway adjacent to room 141	High Left	WF-03112020-009967	2/24/2021	FT-FY21-022021-009967-A	<1	FT-FY21-022021-009967-B	<1
WS- 009968	3/11/2020	3/11/2021	1	Cooler	In hallway adjacent to room 133	Low Right	WF-03112020-009968	2/24/2021	FT-FY21-022021-009968-A	<1	FT-FY21-022021-009968-B	<1
WS- 009969	3/11/2020	3/11/2021	1	Cooler	In hallway adjacent to room 133	High Left	WF-03112020-009969	2/24/2021	FT-FY21-022021-009969-A	<1	FT-FY21-022021-009969-B	<1
WS- 009970	10/5/2020	10/5/2021	1	Classroom Faucet	In classroom 133	WF-10052020-009970	2/24/2021	FT-FY21-022021-009970-A	<1	FT-FY21-022021-009970-B	<1	
WS- 009971	10/5/2020	10/5/2021	1	Classroom Faucet	In classroom 132	WF-10052020-009971	2/24/2021	FT-FY21-022021-009971-A	<1	FT-FY21-022021-009971-B	<1	
WS- 009973	3/11/2020	3/11/2021	1	Health Suite	In health suite	WF-03112020-009973	2/24/2021	FT-FY21-022021-009973-A	<1	FT-FY21-022021-009973-B	<1	
WS- 009974	10/5/2020	10/5/2021	1	Classroom Faucet	In classroom 116	WF-10052020-009974	2/24/2021	FT-FY21-022021-009974-A	<1	FT-FY21-022021-009974-B	<1	
WS- 009975	10/5/2020	10/5/2021	1	Classroom Faucet	In classroom 113	WF-10052020-009975	2/24/2021	FT-FY21-022021-009975-A	<1	FT-FY21-022021-009975-B	<1	
WS- 009976	10/5/2020	10/5/2021	1	Classroom Faucet	In classroom 110	WF-10052020-009976	2/24/2021	FT-FY21-022021-009976-A	<1	FT-FY21-022021-009976-B	<1	
WS- 009978	3/11/2020	3/11/2021	1	Cooler	In hallway adjacent to room G107	WF-03112020-009978	2/24/2021	FT-FY21-022021-009978-A	<1	FT-FY21-022021-009978-B	<1	
WS- 009979	3/11/2020	3/11/2021	1	Cooler	In hallway adjacent to room G115	WF-03112020-009979	2/24/2021	FT-FY21-022021-009979-A	<1	FT-FY21-022021-009979-B	<1	
WS- 009980	3/11/2020	3/11/2021	2	Break Room	In staff lounge 218	WF-03112020-009980	2/24/2021	FT-FY21-022021-009980-A	<1	FT-FY21-022021-009980-B	<1	
WS- 009981	3/11/2020	3/11/2021	2	Cooler	In hallway adjacent to elevator	High Left	WF-03112020-009981	2/24/2021	FT-FY21-022021-009981-A	<1	FT-FY21-022021-009981-B	<1
WS- 009982	3/11/2020	3/11/2021	2	Cooler	In hallway adjacent to elevator	Low Right	WF-03112020-009982	2/24/2021	FT-FY21-022021-009982-A	<1	FT-FY21-022021-009982-B	<1
WS- 009983	3/11/2020	3/11/2021	2	Cooler	In hallway adjacent to stairwell 4	High Left	WF-03112020-009983	2/24/2021	FT-FY21-022021-009983-A	<1	FT-FY21-022021-009983-B	<1
WS- 009984	3/11/2020	3/11/2021	2	Cooler	In hallway adjacent to stairwell 4	Low Right	WF-03112020-009984	2/24/2021	FT-FY21-022021-009984-A	<1	FT-FY21-022021-009984-B	<1
WS- 009988	3/11/2020	3/11/2021	3	Break Room	In staff lounge 318	WF-03112020-009988	2/24/2021	FT-FY21-022021-009988-A	<1	FT-FY21-022021-009988-B	<1	
WS- 009989	3/11/2020	3/11/2021	3	Cooler	In hallway adjacent to elevator	High Left	WF-03112020-009989	2/24/2021	FT-FY21-022021-009989-A	<1	FT-FY21-022021-009989-B	<1
WS- 009990	3/11/2020	3/11/2021	3	Cooler	In hallway adjacent to elevator	Low Right	WF-03112020-009990	2/24/2021	FT-FY21-022021-009990-A	<1	FT-FY21-022021-009990-B	<1
WS- 009995	3/11/2020	3/11/2021	3	Cooler	In hallway adjacent to room 327	High Left	WF-03112020-009995	2/24/2021	FT-FY21-022021-009995-A	<1	FT-FY21-022021-009995-B	<1
WS- 009996	3/11/2020	3/11/2021	3	Cooler	In hallway adjacent to room 327	Low Right	WF-03112020-009996	2/24/2021	FT-FY21-022021-009996-A	<1	FT-FY21-022021-009996-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009959	2/4/2021	2/4/2022	1	Food Prep Sink	In kitchen first clockwise from entry door (dishwashing hose)	WF-02042021-009959	2/24/2021	FT-FY21-022021-009959-A	<1	FT-FY21-022021-009959-B	<1