



Takoma EC Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-009963	10/14/2019	10/14/2020	1	Classroom Faucet	In classroom 148	WF-10142019-009963	1/13/2020	FT-FY20-122019-009963-A	3.9	FT-FY20-122019-009963-B	<1	
WS-009965	10/14/2019	10/14/2020	1	Classroom Faucet	In classroom 142	WF-10142019-009965	1/13/2020	FT-FY20-122019-009965-A	4.2	FT-FY20-122019-009965-B	<1	
WS-009966	11/7/2019	11/7/2020	1	Cooler	In hallway adjacent to room 141	Low Right	WF-11072019-009966	1/13/2020	FT-FY20-122019-009966-A	<1	FT-FY20-122019-009966-B	<1
WS-009967	11/7/2019	11/7/2020	1	Cooler	In hallway adjacent to room 141	High Left	WF-11072019-009967	1/13/2020	FT-FY20-122019-009967-A	<1	FT-FY20-122019-009967-B	<1
WS-009968	5/1/2019	5/1/2020	1	Cooler	In hallway adjacent to room 133	Low Right	WF-05012019-009968	1/13/2020	FT-FY20-122019-009968-A	<1	FT-FY20-122019-009968-B	<1
WS-009969	11/7/2019	11/7/2020	1	Cooler	In hallway adjacent to room 133	High Left	WF-11072019-009969	1/13/2020	FT-FY20-122019-009969-A	<1	FT-FY20-122019-009969-B	<1
WS-009971	10/14/2019	10/14/2020	1	Classroom Faucet	In classroom 132	WF-10142019-009971	1/13/2020	FT-FY20-122019-009971-A	<1	FT-FY20-122019-009971-B	<1	
WS-009973	3/18/2019	3/18/2020	1	Health Suite	In health suite	WF-03182019-009973	1/13/2020	FT-FY20-122019-009973-A	<1	FT-FY20-122019-009973-B	<1	
WS-009974	10/14/2019	10/14/2020	1	Classroom Faucet	In classroom 116	WF-10142019-009974	1/13/2020	FT-FY20-122019-009974-A	<1	FT-FY20-122019-009974-B	<1	
WS-009975	10/14/2019	10/14/2020	1	Classroom Faucet	In classroom 113	WF-10142019-009975	1/13/2020	FT-FY20-122019-009975-A	3.4	FT-FY20-122019-009975-B	<1	
WS-009976	10/14/2019	10/14/2020	1	Classroom Faucet	In classroom 110	WF-10142019-009976	1/13/2020	FT-FY20-122019-009976-A	<1	FT-FY20-122019-009976-B	<1	
WS-009977	10/14/2019	10/14/2020	1	Classroom Faucet	In classroom 127	WF-10142019-009977	1/13/2020	FT-FY20-122019-009977-A	<1	FT-FY20-122019-009977-B	<1	
WS-009978	11/7/2019	11/7/2020	1	Cooler	In hallway adjacent to room G107	WF-11072019-009978	1/13/2020	FT-FY20-122019-009978-A	<1	FT-FY20-122019-009978-B	<1	
WS-009979	11/7/2019	11/7/2020	1	Cooler	In hallway adjacent to room G115	WF-11072019-009979	1/13/2020	FT-FY20-122019-009979-A	<1	FT-FY20-122019-009979-B	<1	
WS-009980	3/18/2019	3/18/2020	2	Break Room	In staff lounge 218	WF-03182019-009980	1/13/2020	FT-FY20-122019-009980-A	<1	FT-FY20-122019-009980-B	<1	
WS-009981	11/7/2019	11/7/2020	2	Cooler	In hallway adjacent to elevator	High Left	WF-11072019-009981	1/13/2020	FT-FY20-122019-009981-A	<1	FT-FY20-122019-009981-B	<1
WS-009982	11/7/2019	11/7/2020	2	Cooler	In hallway adjacent to elevator	Low Right	WF-11072019-009982	1/13/2020	FT-FY20-122019-009982-A	<1	FT-FY20-122019-009982-B	<1
WS-009983	11/7/2019	11/7/2020	2	Cooler	In hallway adjacent to stairwell 4	High Left	WF-11072019-009983	1/13/2020	FT-FY20-122019-009983-A	<1	FT-FY20-122019-009983-B	<1
WS-009984	11/7/2019	11/7/2020	2	Cooler	In hallway adjacent to stairwell 4	Low Right	WF-11072019-009984	1/13/2020	FT-FY20-122019-009984-A	<1	FT-FY20-122019-009984-B	<1
WS-009988	3/18/2019	3/18/2020	3	Break Room	In staff lounge 318	WF-03182019-009988	1/13/2020	FT-FY20-122019-009988-A	<1	FT-FY20-122019-009988-B	<1	
WS-009989	11/7/2019	11/7/2020	3	Cooler	In hallway adjacent to elevator	High Left	WF-11072019-009989	1/13/2020	FT-FY20-122019-009989-A	<1	FT-FY20-122019-009989-B	<1
WS-009990	11/7/2019	11/7/2020	3	Cooler	In hallway adjacent to elevator	Low Right	WF-11072019-009990	1/13/2020	FT-FY20-122019-009990-A	<1	FT-FY20-122019-009990-B	<1
WS-009995	11/7/2019	11/7/2020	3	Cooler	In hallway adjacent to room 327	High Left	WF-11072019-009995	1/13/2020	FT-FY20-122019-009995-A	<1	FT-FY20-122019-009995-B	<1
WS-009996	11/7/2019	11/7/2020	3	Cooler	In hallway adjacent to room 327	Low Right	WF-11072019-009996	1/13/2020	FT-FY20-122019-009996-A	<1	FT-FY20-122019-009996-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009959	6/26/2019	6/26/2020	1	Food Prep Sink	In kitchen first clockwise from entry door (dishwashing hose)	WF-06262019-009959	1/13/2020	FT-FY20-122019-009959-A	<1	FT-FY20-122019-009959-B	<1

FY20 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009970	10/14/2019	10/14/2020	1	Classroom Faucet	In classroom 133	WF-10142019-009970	1/13/2020	FT-FY20-122019-009970-A	11.7	FT-FY20-122019-009970-B	<1