



Takoma Education Campus Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009963	9/21/2022	9/21/2023	1	Classroom Faucet	In classroom 148	WF-09212022-009963	1/3/2023	FT-FY23-11182022-009963-A	<1	FT-FY23-11182022-009963-B	<1	
WS- 009965	9/21/2022	9/21/2023	1	Classroom Faucet	In classroom 142	WF-09212022-009965	1/3/2023	FT-FY23-11182022-009965-A	<1	FT-FY23-11182022-009965-B	<1	
WS- 009966	2/21/2022	2/21/2023	1	Cooler	In hallway adjacent to room 141	Low Right	WF-02212022-009966	1/3/2023	FT-FY23-11182022-009966-A	<1	FT-FY23-11182022-009966-B	<1
WS- 009967	2/21/2022	2/21/2023	1	Cooler	In hallway adjacent to room 141	High Left	WF-02212022-009967	1/3/2023	FT-FY23-11182022-009967-A	<1	FT-FY23-11182022-009967-B	<1
WS- 009970	9/21/2022	9/21/2023	1	Classroom Faucet	In classroom 133	WF-09212022-009970	1/3/2023	FT-FY23-11182022-009970-A	1.4	FT-FY23-11182022-009970-B	<1	
WS- 009971	9/21/2022	9/21/2023	1	Classroom Faucet	In classroom 132	WF-09212022-009971	1/3/2023	FT-FY23-11182022-009971-A	<1	FT-FY23-11182022-009971-B	<1	
WS- 009973	2/21/2022	2/21/2023	1	Health Suite	In health suite	WF-02212022-009973	1/3/2023	FT-FY23-11182022-009973-A	1.1	FT-FY23-11182022-009973-B	<1	
WS- 009974	9/21/2022	9/21/2023	1	Classroom Faucet	In classroom 116	WF-09212022-009974	1/3/2023	FT-FY23-11182022-009974-A	<1	FT-FY23-11182022-009974-B	<1	
WS- 009975	9/21/2022	9/21/2023	1	Classroom Faucet	In classroom 113	WF-09212022-009975	1/3/2023	FT-FY23-11182022-009975-A	<1	FT-FY23-11182022-009975-B	<1	
WS- 009976	9/21/2022	9/21/2023	1	Classroom Faucet	In classroom 110	WF-09212022-009976	1/3/2023	FT-FY23-11182022-009976-A	<1	FT-FY23-11182022-009976-B	<1	
WS- 009977	9/21/2022	9/21/2023	1	Classroom Faucet	In classroom 127	WF-09212022-009977	1/3/2023	FT-FY23-11182022-009977-A	<1	FT-FY23-11182022-009977-B	<1	
WS- 009978	2/21/2022	2/21/2023	1	Cooler	In hallway adjacent to room G107		WF-02212022-009978	1/3/2023	FT-FY23-11182022-009978-A	<1	FT-FY23-11182022-009978-B	<1
WS- 009980	2/21/2022	2/21/2023	2	Break Room	In staff lounge 218		WF-02212022-009980	1/3/2023	FT-FY23-11182022-009980-A	<1	FT-FY23-11182022-009980-B	<1
WS- 009981	2/21/2022	2/21/2023	2	Cooler	In hallway adjacent to elevator	High Left	WF-02212022-009981	1/3/2023	FT-FY23-11182022-009981-A	<1	FT-FY23-11182022-009981-B	<1
WS- 009982	2/21/2022	2/21/2023	2	Cooler	In hallway adjacent to elevator	Low Right	WF-02212022-009982	1/3/2023	FT-FY23-11182022-009982-A	<1	FT-FY23-11182022-009982-B	<1
WS- 009983	2/21/2022	2/21/2023	2	Cooler	In hallway adjacent to stairwell 4	High Left	WF-02212022-009983	1/3/2023	FT-FY23-11182022-009983-A	<1	FT-FY23-11182022-009983-B	<1
WS- 009984	2/21/2022	2/21/2023	2	Cooler	In hallway adjacent to stairwell 4	Low Right	WF-02212022-009984	1/3/2023	FT-FY23-11182022-009984-A	<1	FT-FY23-11182022-009984-B	<1
WS- 009988	2/21/2022	2/21/2023	3	Break Room	In staff lounge 318		WF-02212022-009988	1/3/2023	FT-FY23-11182022-009988-A	<1	FT-FY23-11182022-009988-B	<1
WS- 009989	7/19/2022	7/19/2023	3	Cooler	In hallway adjacent to elevator	High Left	WF-07192022-009989	1/3/2023	FT-FY23-11182022-009989-A	<1	FT-FY23-11182022-009989-B	<1
WS- 009990	7/19/2022	7/19/2023	3	Cooler	In hallway adjacent to elevator	Low Right	WF-07192022-009990	1/3/2023	FT-FY23-11182022-009990-A	<1	FT-FY23-11182022-009990-B	<1
WS- 009995	7/19/2022	7/19/2023	3	Cooler	In hallway adjacent to room 327	High Left	WF-07192022-009995	1/3/2023	FT-FY23-11182022-009995-A	<1	FT-FY23-11182022-009995-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009959	1/26/2022	1/26/2023	1	Food Prep Sink	In kitchen first clockwise from entry door (dishwashing hose)	WF-01262022-009959	1/3/2023	FT-FY23-11182022-009959-A	1.8	FT-FY23-11182022-009959-B	<1