



# TAKOMA EC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	TAKOMA EDUCATIONAL CAMPUS	WS- 009959	8/23/2016	1	Food Prep Sink	In kitchen first clockwise from entry door (dishwashing hose)	FT-82016-009959-A	< 1	FT-82016-009959-B	< 1
2	TAKOMA EDUCATIONAL CAMPUS	WS- 009966	8/23/2016	1	Cooler	In hallway adjacent to room 141 Low Right	FT-82016-009966-A	< 1	FT-82016-009966-B	< 1
3	TAKOMA EDUCATIONAL CAMPUS	WS- 009967	8/23/2016	1	Cooler	In hallway adjacent to room 141 High Left	FT-82016-009967-A	< 1	FT-82016-009967-B	< 1
4	TAKOMA EDUCATIONAL CAMPUS	WS- 009968	8/23/2016	1	Cooler	In hallway adjacent to room 133 Low Right	FT-82016-009968-A	< 1	FT-82016-009968-B	< 1
5	TAKOMA EDUCATIONAL CAMPUS	WS- 009969	8/23/2016	1	Cooler	In hallway adjacent to room 133 High Left	FT-82016-009969-A	< 1	FT-82016-009969-B	< 1
6	TAKOMA EDUCATIONAL CAMPUS	WS- 009973	8/23/2016	1	Health Suite	In health suite	FT-82016-009973-A	< 1	FT-82016-009973-B	< 1
7	TAKOMA EDUCATIONAL CAMPUS	WS- 009978	8/23/2016	1	Cooler	In hallway adjacent to room G107	FT-82016-009978-A	< 1	FT-82016-009978-B	< 1
8	TAKOMA EDUCATIONAL CAMPUS	WS- 009979	8/23/2016	1	Cooler	In hallway adjacent to room G115	FT-82016-009979-A	< 1	FT-82016-009979-B	< 1
9	TAKOMA EDUCATIONAL CAMPUS	WS- 009981	8/23/2016	2	Cooler	In hallway adjacent to elevator High Left	FT-82016-009981-A	< 1	FT-82016-009981-B	< 1
10	TAKOMA EDUCATIONAL CAMPUS	WS- 009982	8/23/2016	2	Cooler	In hallway adjacent to elevator Low Right	FT-82016-009982-A	< 1	FT-82016-009982-B	< 1
11	TAKOMA EDUCATIONAL CAMPUS	WS- 009983	8/23/2016	2	Cooler	In hallway adjacent to stairwell 4 High Left	FT-82016-009983-A	< 1	FT-82016-009983-B	< 1
12	TAKOMA EDUCATIONAL CAMPUS	WS- 009984	8/23/2016	2	Cooler	In hallway adjacent to stairwell 4 Low Right	FT-82016-009984-A	< 1	FT-82016-009984-B	< 1
13	TAKOMA EDUCATIONAL CAMPUS	WS- 009989	8/23/2016	3	Cooler	In hallway adjacent to elevator High Left	FT-82016-009989-A	< 1	FT-82016-009989-B	< 1
14	TAKOMA EDUCATIONAL CAMPUS	WS- 009990	8/23/2016	3	Cooler	In hallway adjacent to elevator Low Right	FT-82016-009990-A	< 1	FT-82016-009990-B	< 1
15	TAKOMA EDUCATIONAL CAMPUS	WS- 009995	8/23/2016	3	Cooler	In hallway adjacent to room 327 High Left	FT-82016-009995-A	< 1	FT-82016-009995-B	< 1
16	TAKOMA EDUCATIONAL CAMPUS	WS- 009996	8/23/2016	3	Cooler	In hallway adjacent to room 327 Low Right	FT-82016-009996-A	< 1	FT-82016-009996-B	< 1