



TAKOMA LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009958	Utility	1	In boiler room (Main Water Source)	WT-042916-9975- A	< 1	WT-042916-9975- B	< 1				
2	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009959	Kitchen	1	In kitchen	WT-042916-9976- A	< 1	WT-042916-9976- B	< 1				
3	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009960	Kitchen	1	In kitchen dishwasher room left hand side 1	WT-042916-9977- A	< 1	WT-042916-9977- B	< 1				
4	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009961	Kitchen	1	In kitchen left hand side 3	WT-042916-9978- A	< 1	WT-042916-9978- B	< 1				
5	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009962	Kitchen	1	In kitchen left hand side 2	WT-042916-9979- A	< 1	WT-042916-9979- B	< 1				
6	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009963	Classroom	1	In room 148	WT-042916-9980- A	< 1	WT-042916-9980- B	< 1				
7	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009964	Kitchen	1	In kitchen left hand side 4	WT-042916-9981- A	< 1	WT-042916-9981- B	< 1				
8	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009965	Classroom	1	In room 142	WT-042916-9982- A	< 1	WT-042916-9982- B	< 1				
9	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009966	Cooler	1	In hallway adjacent to room 141	WT-042916-9983- A	< 1	WT-042916-9983- B	< 1				
10	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009967	Cooler	1	In hallway adjacent to room 141	WT-042916-9984- A	< 1	WT-042916-9984- B	< 1				
11	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009968	Cooler	1	In hallway adjacent to 133	WT-042916-9985- A	< 1	WT-042916-9985- B	< 1				
12	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009969	Cooler	1	In hallway adjacent to room 133	WT-042916-9986- A	< 1	WT-042916-9986- B	< 1				
13	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009970	Classroom	1	In room 133	WT-042916-9987- A	< 1	WT-042916-9987- B	< 1				
14	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009971	Classroom	1	In room 132	WT-042916-9988- A	< 1	WT-042916-9988- B	< 1				
15	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009973	Health Suite	1	In Health Suite	WT-042916-9990- A	< 1	WT-042916-9990- B	< 1				
16	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009974	Classroom	1	In room 116	WT-042916-9991- A	< 1	WT-042916-9991- B	< 1				
17	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009975	Classroom	1	In room 113	WT-042916-9992- A	< 1	WT-042916-9992- B	< 1				
18	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009976	Classroom	1	In room 110	WT-042916-9993- A	< 1	WT-042916-9993- B	< 1				
19	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009977	Classroom	1	In room 127	WT-042916-9994- A	< 1	WT-042916-9994- B	< 1				
20	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009978	Cooler	1	In hallway in the gym adjacent to room G107	WT-042916-9995- A	< 1	WT-042916-9995- B	< 1				
21	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009979	Cooler	1	In hallway in gym adjacent to room G115	WT-042916-9996- A	< 1	WT-042916-9996- B	< 1				
22	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009980	Classroom	2	In Teachers Lounge	WT-042916-9997- A	1.7	WT-042916-9997- B	< 1				
23	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009981	Cooler	2	In hallway adjacent to elevator	WT-042916-9998- A	< 1	WT-042916-9998- B	< 1				
24	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009982	Cooler	2	In hallway adjacent to elevator	WT-042916-9999- A	< 1	WT-042916-9999- B	< 1				
25	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009983	Cooler	2	In hallway adjacent to stair 4	WT-042916-10000- A	< 1	WT-042916-10000- B	< 1				
26	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009984	Cooler	2	In hallway adjacent to stair 4	WT-042916-10001- A	< 1	WT-042916-10001- B	< 1				
27	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009985	Classroom	2	In room 240	WT-042916-10002- A	2.4	WT-042916-10002- B	< 1				
28	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009986	Classroom	2	In room 240	WT-042916-10003- A	27	WT-042916-10003- B	1.9	Filter will be installed and then retested			
29	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009987	Classroom	2	In room 243	WT-042916-10004- A	< 1	WT-042916-10004- B	< 1				
30	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009988	Classroom	3	In teachers lounge	WT-042916-10005- A	< 1	WT-042916-10005- B	< 1				
31	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009989	Cooler	3	In hallway adjacent to elevator	WT-042916-10006- A	< 1	WT-042916-10006- B	< 1				
32	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009990	Cooler	3	In hallway adjacent to elevator	WT-042916-10007- A	< 1	WT-042916-10007- B	< 1				
33	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009991	Classroom	3	In room 324	WT-042916-10008- A	< 1	WT-042916-10008- B	< 1				
34	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009992	Classroom	3	In room 324	WT-042916-10009- A	< 1	WT-042916-10009- B	< 1				
35	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009993	Classroom	3	In room 327	WT-042916-10010- A	2.4	WT-042916-10010- B	< 1				
36	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009994	Classroom	3	In room 327	WT-042916-10011- A	< 1	WT-042916-10011- B	< 1				
37	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009995	Cooler	3	In hallway adjacent to room 327	WT-042916-10012- A	< 1	WT-042916-10012- B	< 1				
38	TAKOMA EDUCATIONAL CAMPUS	5/11/2016	WS- 009996	Cooler	3	In hallway adjacent to room 327	WT-042916-10013- A	< 1	WT-042916-10013- B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.