



# Takoma Recreation Center Lead in Water Test Results

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005397	3/22/2024	3/22/2025	Basement	Cooler	In women's locker room	WF-03222024-005397	4/9/2024	FT-FY24-03272024-005397-A	<1	FT-FY24-03272024-005397-B	<1
WS- 005398	3/22/2024	3/22/2025	Basement	Cooler	In women's locker room	WF-03222024-005398	4/9/2024	FT-FY24-03272024-005398-A	<1	FT-FY24-03272024-005398-B	<1
WS- 005399	3/22/2024	3/22/2025	Basement	Cooler	in mens locker room	WF-03222024-005399	4/9/2024	FT-FY24-03272024-005399-A	<1	FT-FY24-03272024-005399-B	<1
WS- 005400	3/22/2024	3/22/2025	Basement	Cooler	in mens locker room	WF-03222024-005400	4/9/2024	FT-FY24-03272024-005400-A	<1	FT-FY24-03272024-005400-B	<1
WS- 005401	3/22/2024	3/22/2025	1	Cooler	In hallway adjacent to the kitchen	WF-03222024-005401	4/9/2024	FT-FY24-03272024-005401-A	<1	FT-FY24-03272024-005401-B	<1
WS- 005402	3/22/2024	3/22/2025	1	Cooler	In hallway adjacent to the kitchen	WF-03222024-005402	4/9/2024	FT-FY24-03272024-005402-A	<1	FT-FY24-03272024-005402-B	<1
WS- 005403	11/30/2023	11/30/2024	1	Food Prep Sink	In Aquatic Ctr 104 concession stand	WF-11302023-005403	4/9/2024	FT-FY24-03272024-005403-A	<1	FT-FY24-03272024-005403-B	<1
WS- 005405	11/30/2023	11/30/2024	Ground Floor	Food Prep Sink	In kitchen 157	WF-11302023-005405	4/9/2024	FT-FY24-03272024-005405-A	<1	FT-FY24-03272024-005405-B	<1
WS- 005412	12/1/2023	12/1/2024	Ground Floor	Food Prep Sink	In kitchen in accessory building north of Van Buren Street adjacent to playground	WF-12012023-005412	4/9/2024	FT-FY24-03272024-005412-A	1.0	FT-FY24-03272024-005412-B	<1
WS- 005413	3/22/2024	3/22/2025	Ground Floor	Cooler	In hallway in accessory building north of Van Buren Street adjacent to playground	WF-03222024-005413	4/9/2024	FT-FY24-03272024-005413-A	<1	FT-FY24-03272024-005413-B	<1
WS- 005414	3/22/2024	3/22/2025	Ground Floor	Cooler	In hallway in accessory building north of Van Buren Street adjacent to playground	WF-03222024-005414	4/9/2024	FT-FY24-03272024-005414-A	<1	FT-FY24-03272024-005414-B	<1