



Takoma RC Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-005397	5/8/2018	5/8/2019	Basement	Cooler	In women's locker room	WF-05082018-005397	2/19/2019	FT-FY19-022019-005397-A	<1	FT-FY19-022019-005397-B	<1	
WS-005398	5/8/2018	5/8/2019	Basement	Cooler	In women's locker room	WF-05082018-005398	2/19/2019	FT-FY19-022019-005398-A	<1	FT-FY19-022019-005398-B	<1	
WS-005399	5/8/2018	5/8/2019	Basement	Cooler	in mens locker room	WF-05082018-005399	2/19/2019	FT-FY19-022019-005399-A	<1	FT-FY19-022019-005399-B	<1	
WS-005400	5/8/2018	5/8/2019	Basement	Cooler	in mens locker room	WF-05082018-005400	2/19/2019	FT-FY19-022019-005400-A	<1	FT-FY19-022019-005400-B	<1	
WS-005401	5/8/2018	5/8/2019	1	Cooler	In hallway adjacent to the kitchen	WF-05082018-005401	2/19/2019	FT-FY19-022019-005401-A	<1	FT-FY19-022019-005401-B	<1	
WS-005402	5/8/2018	5/8/2019	1	Cooler	In hallway adjacent to the kitchen	WF-05082018-005402	2/19/2019	FT-FY19-022019-005402-A	<1	FT-FY19-022019-005402-B	<1	
WS-005413	5/8/2018	5/8/2019	Ground Floor	Cooler	In hallway in accessory building north of Van Buren Street adjacent to playground	WF-05082018-005413	2/19/2019	FT-FY19-022019-005413-A	<1	FT-FY19-022019-005413-B	<1	
WS-005414	5/8/2018	5/8/2019	Ground Floor	Cooler	In hallway in accessory building north of Van Buren Street adjacent to playground	WF-05082018-005414	2/19/2019	FT-FY19-022019-005414-A	<1	FT-FY19-022019-005414-B	<1	

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-005403	5/8/2018	5/8/2019	1	Food Prep Sink	In kitchen	WF-05082018-005403	2/19/2019	FT-FY19-022019-005403-A	<1	FT-FY19-022019-005403-B	<1	
WS-005405	5/8/2018	5/8/2019	Ground Floor	Food Prep Sink	In kitchen 157	WF-05082018-005405	2/19/2019	FT-FY19-022019-005405-A	<1	FT-FY19-022019-005405-B	<1	
WS-005412	5/8/2018	5/8/2019	Ground Floor	Food Prep Sink	In kitchen in accessory building north of Van Buren Street adjacent to playground	WF-05082018-005412	2/19/2019	FT-FY19-022019-005412-A	<1	FT-FY19-022019-005412-B	<1	