



# Takoma Recreation Center Lead in Water Test Results

## FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005397	4/11/2022	4/11/2023	Basement	Cooler	In women's locker room Low Right	WF-04112022-005397	2/17/2023	FT-FY23-01192023-005397-A	<1	FT-FY23-01192023-005397-B	<1
WS- 005398	4/11/2022	4/11/2023	Basement	Cooler	In women's locker room High Left	WF-04112022-005398	2/17/2023	FT-FY23-01192023-005398-A	<1	FT-FY23-01192023-005398-B	<1
WS- 005399	4/11/2022	4/13/2023	Basement	Cooler	in mens locker room High Left	WF-04112022-005399	2/17/2023	FT-FY23-01192023-005399-A	<1	FT-FY23-01192023-005399-B	<1
WS- 005400	4/11/2022	4/11/2023	Basement	Cooler	in mens locker room Low Right	WF-04112022-005400	2/17/2023	FT-FY23-01192023-005400-A	<1	FT-FY23-01192023-005400-B	<1
WS- 005401	4/11/2022	4/11/2023	1	Cooler	In hallway adjacent to the kitchen Low Right	WF-04112022-005401	2/17/2023	FT-FY23-01192023-005401-A	<1	FT-FY23-01192023-005401-B	<1
WS- 005402	4/11/2022	4/11/2023	1	Cooler	In hallway adjacent to the kitchen High Left	WF-04112022-005402	2/17/2023	FT-FY23-01192023-005402-A	<1	FT-FY23-01192023-005402-B	<1
WS- 005403	1/4/2023	1/4/2024	1	Food Prep Sink	In Aquatic Ctr 104 concession stand	WF-01042023-005403	2/17/2023	FT-FY23-01192023-005403-A	<1	FT-FY23-01192023-005403-B	<1
WS- 005405	1/4/2023	1/4/2024	Ground Floor	Food Prep Sink	In kitchen 157	WF-01042023-005405	2/17/2023	FT-FY23-01192023-005405-A	<1	FT-FY23-01192023-005405-B	<1
WS- 005412	1/4/2023	1/4/2024	Ground Floor	Food Prep Sink	In kitchen in accessory building north of Van Buren Street adjacent	WF-01042023-005412	2/17/2023	FT-FY23-01192023-005412-A	<1	FT-FY23-01192023-005412-B	<1
WS- 005413	4/11/2022	4/11/2023	Ground Floor	Cooler	In hallway in accessory building north of Van Buren High Left	WF-04112022-005413	2/17/2023	FT-FY23-01192023-005413-A	<1	FT-FY23-01192023-005413-B	<1
WS- 005414	4/11/2022	4/11/2023	Ground Floor	Cooler	In hallway in accessory building north of Van Buren Low Right	WF-04112022-005414	2/17/2023	FT-FY23-01192023-005414-A	<1	FT-FY23-01192023-005414-B	<1