



Takoma EC Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009963	11/15/2017	11/15/2018	1	Classroom Faucet	In classroom 148	WF-112017-009963	11/29/2017	FT-FY18-112017-009963-A	2.5	FT-FY18-112017-009963-B	<1
WS- 009969	6/28/2017	6/28/2018	1	Cooler	In hallway adjacent to room 133	WF-62017-009969	11/29/2017	FT-FY18-62017-009969-A	<1	FT-FY18-62017-009969-B	<1
WS- 009971	11/15/2017	11/15/2018	1	Classroom Faucet	In classroom 132	WF-112017-009971	11/29/2017	FT-FY18-112017-009971-A	3.5	FT-FY18-112017-009971-B	<1
WS- 009978	6/28/2017	6/28/2018	1	Cooler	In hallway adjacent to room G107	WF-62017-009978	11/29/2017	FT-FY18-62017-009978-A	<1	FT-FY18-62017-009978-B	<1
WS- 009980	6/28/2017	6/28/2018	2	Break Room	In staff lounge 218	WF-62017-009980	11/29/2017	FT-FY18-62017-009980-A	<1	FT-FY18-62017-009980-B	<1
WS- 009981	6/28/2017	6/28/2018	2	Cooler	In hallway adjacent to elevator	WF-62017-009981	11/29/2017	FT-FY18-62017-009981-A	<1	FT-FY18-62017-009981-B	<1
WS- 009982	6/28/2017	6/28/2018	2	Cooler	In hallway adjacent to elevator	WF-62017-009982	11/29/2017	FT-FY18-62017-009982-A	<1	FT-FY18-62017-009982-B	<1
WS- 009990	6/28/2017	6/28/2018	3	Cooler	In hallway adjacent to elevator	WF-62017-009990	11/29/2017	FT-FY18-62017-009990-A	<1	FT-FY18-62017-009990-B	<1
WS- 009996	6/28/2017	6/28/2018	3	Cooler	In hallway adjacent to room 327	WF-62017-009996	11/29/2017	FT-FY18-62017-009996-A	<1	FT-FY18-62017-009996-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation										
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)		
WS- 009959	1	Food Prep Sink	In kitchen first clockwise from entry door (dishwashing hose)	11/29/2017	FT-FY18-102017-009959-A	<1	FT-FY18-102017-009959-B	<1		