



Thaddeus Stevens Early Learning Center Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015350	5/14/2024	5/14/2025	1	Bottle Filler	In hallway adjacent to 127 all gender restroom	WF-05142024-015350	11/7/2024	FT-FY25-10082024-015350-A	<2	FT-FY25-10082024-015350-B	<2
WS-015351	5/14/2024	5/14/2025	1	Cooler	In hallway adjacent to 127 all gender restroom High Left	WF-05142024-015351	11/7/2024	FT-FY25-10082024-015351-A	<2	FT-FY25-10082024-015351-B	<2
WS-015352	5/14/2024	5/14/2025	1	Cooler	In hallway adjacent to 127 all gender restroom Low Right	WF-05142024-015352	11/7/2024	FT-FY25-10082024-015352-A	<2	FT-FY25-10082024-015352-B	<2
WS-015353	5/14/2024	5/14/2025	1	Health Suite	In room 130 inside health suite 131	WF-05142024-015353	11/7/2024	FT-FY25-10082024-015353-A	<2	FT-FY25-10082024-015353-B	<2
WS-015360	9/24/2024	9/24/2025	1	Combo Faucet	In room 100 infant Left	WF-09242024-015360	11/7/2024	FT-FY25-10082024-015360-A	<2	FT-FY25-10082024-015360-B	<2
WS-015361	5/14/2024	5/14/2025	1	Combo Fountain	In room 100 infant Left	WF-05142024-015361	11/7/2024	FT-FY25-10082024-015361-A	<2	FT-FY25-10082024-015361-B	<2
WS-015363	9/24/2024	9/24/2025	1	Combo Faucet	In room 100 infant Right	WF-09242024-015363	11/7/2024	FT-FY25-10082024-015363-A	<2	FT-FY25-10082024-015363-B	<2
WS-015364	9/24/2024	9/24/2025	1	Classroom Faucet	In room 101 toddler room 1	WF-09242024-015364	11/7/2024	FT-FY25-10082024-015364-A	<2	FT-FY25-10082024-015364-B	<2
WS-015365	5/14/2024	5/14/2025	1	Combo Fountain	In room 101 toddler room 1	WF-05142024-015365	11/7/2024	FT-FY25-10082024-015365-A	<2	FT-FY25-10082024-015365-B	<2
WS-015366	9/24/2024	9/24/2025	1	Combo Faucet	In room 101 toddler room 1	WF-09242024-015366	11/7/2024	FT-FY25-10082024-015366-A	<2	FT-FY25-10082024-015366-B	<2
WS-015367	5/14/2024	5/14/2025	1	Break Room	In room 105 workroom	WF-05142024-015367	11/7/2024	FT-FY25-10082024-015367-A	<2	FT-FY25-10082024-015367-B	<2
WS-015368	9/24/2024	9/24/2025	2	Combo Faucet	In room 215 pre-s/pre-k 4	WF-09242024-015368	11/7/2024	FT-FY25-10082024-015368-A	<2	FT-FY25-10082024-015368-B	<2
WS-015370	9/24/2024	9/24/2025	2	Combo Faucet	In room 218 pre-s/pre-k 5	WF-09242024-015370	11/7/2024	FT-FY25-10082024-015370-A	<2	FT-FY25-10082024-015370-B	<2
WS-015371	5/14/2024	5/14/2025	2	Combo Fountain	In room 218 pre-s/pre-k 5	WF-05142024-015371	11/7/2024	FT-FY25-10082024-015371-A	<2	FT-FY25-10082024-015371-B	<2
WS-015372	9/24/2024	9/24/2025	2	Combo Faucet	In room 200 toddler room 2	WF-09242024-015372	11/7/2024	FT-FY25-10082024-015372-A	<2	FT-FY25-10082024-015372-B	<2
WS-015373	5/14/2024	5/14/2025	2	Combo Fountain	In room 200 toddler room 2	WF-05142024-015373	11/7/2024	FT-FY25-10082024-015373-A	<2	FT-FY25-10082024-015373-B	<2
WS-015374	9/24/2024	9/24/2025	2	Classroom Faucet	In room 200 toddler room 2	WF-09242024-015374	11/7/2024	FT-FY25-10082024-015374-A	<2	FT-FY25-10082024-015374-B	<2
WS-015375	9/24/2024	9/24/2025	2	Classroom Faucet	In room 206 toddler room 3	WF-09242024-015375	11/7/2024	FT-FY25-10082024-015375-A	<2	FT-FY25-10082024-015375-B	<2
WS-015376	5/14/2024	5/14/2025	2	Combo Fountain	In room 206 toddler room 3	WF-05142024-015376	11/7/2024	FT-FY25-10082024-015376-A	<2	FT-FY25-10082024-015376-B	<2
WS-015377	9/24/2024	9/24/2025	2	Combo Faucet	In room 206 toddler room 3	WF-09242024-015377	11/7/2024	FT-FY25-10082024-015377-A	<2	FT-FY25-10082024-015377-B	<2
WS-015378	5/14/2024	5/14/2025	2	Bottle Filler	In hallway adjacent to room 212	WF-05142024-015378	11/7/2024	FT-FY25-10082024-015378-A	<2	FT-FY25-10082024-015378-B	<2
WS-015379	5/14/2024	5/14/2025	2	Cooler	In hallway adjacent to room 212 High Left	WF-05142024-015379	11/7/2024	FT-FY25-10082024-015379-A	<2	FT-FY25-10082024-015379-B	<2
WS-015380	5/14/2024	5/14/2025	2	Cooler	In hallway adjacent to room 212 Low Right	WF-05142024-015380	11/7/2024	FT-FY25-10082024-015380-A	<2	FT-FY25-10082024-015380-B	<2
WS-015381	9/24/2024	9/24/2025	2	Combo Faucet	In room 209 pre-s/pre-k 3	WF-09242024-015381	11/7/2024	FT-FY25-10082024-015381-A	<2	FT-FY25-10082024-015381-B	<2
WS-015383	9/24/2024	9/24/2025	3	Combo Faucet	In room 312 pre-s/pre-k 7	WF-09242024-015383	11/7/2024	FT-FY25-10082024-015383-A	<2	FT-FY25-10082024-015383-B	<2
WS-015384	5/14/2024	5/14/2025	3	Combo Fountain	In room 312 pre-s/pre-k 7	WF-05142024-015384	11/7/2024	FT-FY25-10082024-015384-A	<2	FT-FY25-10082024-015384-B	<2
WS-015385	9/24/2024	9/24/2025	3	Combo Faucet	In room 315 pre-s/pre-k 8	WF-09242024-015385	11/7/2024	FT-FY25-10082024-015385-A	<2	FT-FY25-10082024-015385-B	<2
WS-015388	5/14/2024	5/14/2025	3	Combo Fountain	In room 324 pre-s/pre-k 8	WF-05142024-015388	11/7/2024	FT-FY25-10082024-015388-A	<2	FT-FY25-10082024-015388-B	<2
WS-015392	5/14/2024	5/14/2025	3	Combo Fountain	In room 304 music	WF-05142024-015392	11/7/2024	FT-FY25-10082024-015392-A	<2	FT-FY25-10082024-015392-B	<2
WS-015393	5/14/2024	5/14/2025	3	Bottle Filler	In hallway adjacent to room 304	WF-05142024-015393	11/7/2024	FT-FY25-10082024-015393-A	<2	FT-FY25-10082024-015393-B	<2
WS-015394	5/14/2024	5/14/2025	3	Cooler	In hallway adjacent to room 304 High Left	WF-05142024-015394	11/7/2024	FT-FY25-10082024-015394-A	<2	FT-FY25-10082024-015394-B	<2
WS-015395	5/14/2024	5/14/2025	3	Cooler	In hallway adjacent to room 304 Low Right	WF-05142024-015395	11/7/2024	FT-FY25-10082024-015395-A	<2	FT-FY25-10082024-015395-B	<2
WS-015399	9/24/2024	9/24/2025	4	Combo Faucet	In room 413 pre-s/pre-k 9	WF-09242024-015399	11/7/2024	FT-FY25-10082024-015399-A	<2	FT-FY25-10082024-015399-B	<2

WS-015400	5/14/2024	5/14/2025	4	Combo Fountain	In room 413 pre-s/pre-k 9	WF-05142024-015400	11/7/2024	FT-FY25-10082024-015400-A	<2	FT-FY25-10082024-015400-B	<2
WS-015401	9/24/2024	9/24/2025	4	Combo Faucet	In room 419 pre-s/pre-k 10	WF-09242024-015401	11/7/2024	FT-FY25-10082024-015401-A	<2	FT-FY25-10082024-015401-B	<2
WS-015402	5/14/2024	5/14/2025	4	Combo Fountain	In room 419 pre-s/pre-k 10	WF-05142024-015402	11/7/2024	FT-FY25-10082024-015402-A	<2	FT-FY25-10082024-015402-B	<2
WS-015405	5/14/2024	5/14/2025	4	Break Room	In break room area across from room 404	WF-05142024-015405	11/7/2024	FT-FY25-10082024-015405-A	<2	FT-FY25-10082024-015405-B	<2
WS-015406	5/14/2024	5/14/2025	4	Break Room	In room 403 lactation	WF-05142024-015406	11/7/2024	FT-FY25-10082024-015406-A	<2	FT-FY25-10082024-015406-B	<2
WS-015407	5/14/2024	5/14/2025	4	Bottle Filler	In hallway adjacent to room 410	WF-05142024-015407	11/7/2024	FT-FY25-10082024-015407-A	<2	FT-FY25-10082024-015407-B	<2
WS-015408	5/14/2024	5/14/2025	4	Cooler	In hallway adjacent to room 410 High Left	WF-05142024-015408	11/7/2024	FT-FY25-10082024-015408-A	<2	FT-FY25-10082024-015408-B	<2
WS-015409	5/14/2024	5/14/2025	4	Cooler	In hallway adjacent to room 410 Low Right	WF-05142024-015409	11/7/2024	FT-FY25-10082024-015409-A	<2	FT-FY25-10082024-015409-B	<2
WS-015410	9/24/2024	9/24/2025	2	Bathroom	In bathroom of room 200	WF-09242024-015410	11/7/2024	FT-FY25-10082024-015410-A	<2	FT-FY25-10082024-015410-B	<2
WS-015411	9/24/2024	9/24/2025	2	Bathroom	In bathroom of room 206	WF-09242024-015411	11/7/2024	FT-FY25-10082024-015411-A	<2	FT-FY25-10082024-015411-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015358	12/4/2023	12/4/2024	1	Food Prep Sink	In kitchen fifth clockwise from entry	WF-12042023-015358	11/7/2024	FT-FY25-10082024-015358-A	<2	FT-FY25-10082024-015358-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.