



Thaddeus Stevens Early Learning Center Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015350	5/6/2025	5/6/2026	1	Bottle Filler	In hallway adjacent to 127 all gender restroom	WF-05062025-015350	11/11/2025	FT-FY26-10172025-015350-A	<2	FT-FY26-10172025-015350-B	<2
WS-015351	5/6/2025	5/6/2026	1	Cooler	In hallway adjacent to 127 all gender restroom High Left	WF-05062025-015351	11/11/2025	FT-FY26-10172025-015351-A	<2	FT-FY26-10172025-015351-B	<2
WS-015352	5/6/2025	5/6/2026	1	Cooler	In hallway adjacent to 127 all gender restroom Low Right	WF-05062025-015352	11/11/2025	FT-FY26-10172025-015352-A	<2	FT-FY26-10172025-015352-B	<2
WS-015353	5/6/2025	5/6/2026	1	Health Suite	In room 130 inside health suite 131	WF-05062025-015353	11/11/2025	FT-FY26-10172025-015353-A	<2	FT-FY26-10172025-015353-B	<2
WS-015360	9/15/2025	9/15/2026	1	Combo Faucet	In room 100 infant Left	WF-09152025-015360	11/11/2025	FT-FY26-10172025-015360-A	<2	FT-FY26-10172025-015360-B	<2
WS-015361	5/6/2025	5/6/2026	1	Combo Fountain	In room 100 infant Left	WF-05062025-015361	11/11/2025	FT-FY26-10172025-015361-A	<2	FT-FY26-10172025-015361-B	<2
WS-015362	5/6/2025	5/6/2026	1	Combo Fountain	In room 100 infant Right	WF-05062025-015362	11/11/2025	FT-FY26-10172025-015362-A	<2	FT-FY26-10172025-015362-B	<2
WS-015363	9/15/2025	9/15/2026	1	Combo Faucet	In room 100 infant Right	WF-09152025-015363	11/11/2025	FT-FY26-10172025-015363-A	<2	FT-FY26-10172025-015363-B	<2
WS-015364	9/15/2025	9/15/2026	1	Classroom Faucet	In room 101 toddler room 1	WF-09152025-015364	11/11/2025	FT-FY26-10172025-015364-A	<2	FT-FY26-10172025-015364-B	<2
WS-015365	5/6/2025	5/6/2026	1	Combo Fountain	In room 101 toddler room 1	WF-05062025-015365	11/11/2025	FT-FY26-10172025-015365-A	<2	FT-FY26-10172025-015365-B	<2
WS-015366	9/15/2025	9/15/2026	1	Combo Faucet	In room 101 toddler room 1	WF-09152025-015366	11/11/2025	FT-FY26-10172025-015366-A	<2	FT-FY26-10172025-015366-B	<2
WS-015367	5/6/2025	5/6/2026	1	Break Room	In room 105 workroom	WF-05062025-015367	11/11/2025	FT-FY26-10172025-015367-A	<2	FT-FY26-10172025-015367-B	<2
WS-015368	9/15/2025	9/15/2026	2	Combo Faucet	In room 215 pre-s/pre-k 4	WF-09152025-015368	11/11/2025	FT-FY26-10172025-015368-A	<2	FT-FY26-10172025-015368-B	<2
WS-015369	5/6/2025	5/6/2026	2	Combo Fountain	In room 215 pre-s/pre-k 4	WF-05062025-015369	11/11/2025	FT-FY26-10172025-015369-A	<2	FT-FY26-10172025-015369-B	<2
WS-015370	9/15/2025	9/15/2026	2	Combo Faucet	In room 218 pre-s/pre-k 5	WF-09152025-015370	11/11/2025	FT-FY26-10172025-015370-A	<2	FT-FY26-10172025-015370-B	<2
WS-015371	5/6/2025	5/6/2026	2	Combo Fountain	In room 218 pre-s/pre-k 5	WF-05062025-015371	11/11/2025	FT-FY26-10172025-015371-A	<2	FT-FY26-10172025-015371-B	<2
WS-015372	9/15/2025	9/15/2026	2	Combo Faucet	In room 200 toddler room 2	WF-09152025-015372	11/11/2025	FT-FY26-10172025-015372-A	<2	FT-FY26-10172025-015372-B	<2
WS-015373	5/6/2025	5/6/2026	2	Combo Fountain	In room 200 toddler room 2	WF-05062025-015373	11/11/2025	FT-FY26-10172025-015373-A	<2	FT-FY26-10172025-015373-B	<2
WS-015374	9/15/2025	9/15/2026	2	Classroom Faucet	In room 200 toddler room 2	WF-09152025-015374	11/11/2025	FT-FY26-10172025-015374-A	<2	FT-FY26-10172025-015374-B	<2
WS-015375	9/15/2025	9/15/2026	2	Classroom Faucet	In room 206 toddler room 3	WF-09152025-015375	11/11/2025	FT-FY26-10172025-015375-A	<2	FT-FY26-10172025-015375-B	<2
WS-015376	5/6/2025	5/6/2026	2	Combo Fountain	In room 206 toddler room 3	WF-05062025-015376	11/11/2025	FT-FY26-10172025-015376-A	<2	FT-FY26-10172025-015376-B	<2
WS-015377	9/15/2025	9/15/2026	2	Combo Faucet	In room 206 toddler room 3	WF-09152025-015377	11/11/2025	FT-FY26-10172025-015377-A	<2	FT-FY26-10172025-015377-B	<2
WS-015378	5/6/2025	5/6/2026	2	Bottle Filler	In hallway adjacent to room 212	WF-05062025-015378	11/11/2025	FT-FY26-10172025-015378-A	<2	FT-FY26-10172025-015378-B	<2
WS-015379	5/6/2025	5/6/2026	2	Cooler	In hallway adjacent to room 212 High Left	WF-05062025-015379	11/11/2025	FT-FY26-10172025-015379-A	<2	FT-FY26-10172025-015379-B	<2
WS-015380	5/6/2025	5/6/2026	2	Cooler	In hallway adjacent to room 212 Low Right	WF-05062025-015380	11/11/2025	FT-FY26-10172025-015380-A	<2	FT-FY26-10172025-015380-B	<2
WS-015381	9/15/2025	9/15/2026	2	Combo Faucet	In room 209 pre-s/pre-k 3	WF-09152025-015381	11/11/2025	FT-FY26-10172025-015381-A	<2	FT-FY26-10172025-015381-B	<2
WS-015383	9/15/2025	9/15/2026	3	Combo Faucet	In room 312 pre-s/pre-k 7	WF-09152025-015383	11/11/2025	FT-FY26-10172025-015383-A	<2	FT-FY26-10172025-015383-B	<2
WS-015385	9/15/2025	9/15/2026	3	Combo Faucet	In room 315 pre-s/pre-k 8	WF-09152025-015385	11/11/2025	FT-FY26-10172025-015385-A	<2	FT-FY26-10172025-015385-B	<2
WS-015386	5/6/2025	5/6/2026	3	Combo Fountain	In room 315 pre-s/pre-k 8	WF-05062025-015386	11/11/2025	FT-FY26-10172025-015386-A	<2	FT-FY26-10172025-015386-B	<2
WS-015388	5/6/2025	5/6/2026	3	Combo Fountain	In room 324 pre-s/pre-k 8	WF-05062025-015388	11/11/2025	FT-FY26-10172025-015388-A	<2	FT-FY26-10172025-015388-B	<2
WS-015389	9/15/2025	9/15/2026	3	Combo Faucet	In room 300 pre-s/pre-k 6	WF-09152025-015389	11/11/2025	FT-FY26-10172025-015389-A	<2	FT-FY26-10172025-015389-B	<2
WS-015390	5/6/2025	5/6/2026	3	Combo Fountain	In room 300 pre-s/pre-k 6	WF-05062025-015390	11/11/2025	FT-FY26-10172025-015390-A	<2	FT-FY26-10172025-015390-B	<2
WS-015393	5/6/2025	5/6/2026	3	Bottle Filler	In hallway adjacent to room 304	WF-05062025-015393	11/11/2025	FT-FY26-10172025-015393-A	<2	FT-FY26-10172025-015393-B	<2
WS-015394	5/6/2025	5/6/2026	3	Cooler	In hallway adjacent to room 304 High Left	WF-05062025-015394	11/11/2025	FT-FY26-10172025-015394-A	<2	FT-FY26-10172025-015394-B	<2

WS-015395	5/6/2025	5/6/2026	3	Cooler	In hallway adjacent to room 304	Low Right	WF-05062025-015395	11/11/2025	FT-FY26-10172025-015395-A	<2	FT-FY26-10172025-015395-B	<2
WS-015399	9/15/2025	9/15/2026	4	Combo Faucet	In room 413 pre-s/pre-k 9		WF-09152025-015399	11/11/2025	FT-FY26-10172025-015399-A	<2	FT-FY26-10172025-015399-B	<2
WS-015400	5/6/2025	5/6/2026	4	Combo Fountain	In room 413 pre-s/pre-k 9		WF-05062025-015400	11/11/2025	FT-FY26-10172025-015400-A	<2	FT-FY26-10172025-015400-B	<2
WS-015401	9/15/2025	9/15/2026	4	Combo Faucet	In room 419 pre-s/pre-k 10		WF-09152025-015401	11/11/2025	FT-FY26-10172025-015401-A	<2	FT-FY26-10172025-015401-B	<2
WS-015402	5/6/2025	5/6/2026	4	Combo Fountain	In room 419 pre-s/pre-k 10		WF-05062025-015402	11/11/2025	FT-FY26-10172025-015402-A	<2	FT-FY26-10172025-015402-B	<2
WS-015405	5/6/2025	5/6/2026	4	Break Room	In break room area across from room 404		WF-05062025-015405	11/11/2025	FT-FY26-10172025-015405-A	<2	FT-FY26-10172025-015405-B	<2
WS-015406	5/6/2025	5/6/2026	4	Break Room	In room 403 lactation		WF-05062025-015406	11/11/2025	FT-FY26-10172025-015406-A	<2	FT-FY26-10172025-015406-B	<2
WS-015407	5/6/2025	5/6/2026	4	Bottle Filler	In hallway adjacent to room 410		WF-05062025-015407	11/11/2025	FT-FY26-10172025-015407-A	<2	FT-FY26-10172025-015407-B	<2
WS-015408	5/6/2025	5/6/2026	4	Cooler	In hallway adjacent to room 410	High Left	WF-05062025-015408	11/11/2025	FT-FY26-10172025-015408-A	<2	FT-FY26-10172025-015408-B	<2
WS-015409	5/6/2025	5/6/2026	4	Cooler	In hallway adjacent to room 410	Low Right	WF-05062025-015409	11/11/2025	FT-FY26-10172025-015409-A	<2	FT-FY26-10172025-015409-B	<2
WS-015410	9/15/2025	9/15/2026	2	Bathroom	In bathroom of room 200		WF-09152025-015410	11/11/2025	FT-FY26-10172025-015410-A	<2	FT-FY26-10172025-015410-B	<2
WS-015411	9/15/2025	9/15/2026	2	Bathroom	In bathroom of room 206		WF-09152025-015411	11/11/2025	FT-FY26-10172025-015411-A	<2	FT-FY26-10172025-015411-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015358	12/2/2024	12/2/2025	1	Food Prep Sink	In kitchen fifth clockwise from entry	WF-12022024-015358	11/11/2025	FT-FY26-10172025-015358-A	<2	FT-FY26-10172025-015358-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.