



Thaddeus Stevens Early Learning Center Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015350	5/24/2022	5/24/2023	1	Bottle Filler	In hallway adjacent to 127 all gender restroom	WF-05242022-015350	1/19/2023	FT-FY23-12292022-015350-A	<1	FT-FY23-12292022-015350-B	<1
WS-015351	5/24/2022	5/24/2023	1	Cooler	In hallway adjacent to 127 all gender restroom High Left	WF-05242022-015351	1/19/2023	FT-FY23-12292022-015351-A	<1	FT-FY23-12292022-015351-B	<1
WS-015352	5/24/2022	5/24/2023	1	Cooler	In hallway adjacent to 127 all gender restroom Low Right	WF-05242022-015352	1/19/2023	FT-FY23-12292022-015352-A	<1	FT-FY23-12292022-015352-B	<1
WS-015353	5/24/2022	5/24/2023	1	Health Suite	In room 130 inside health suite 131	WF-05242022-015353	1/19/2023	FT-FY23-12292022-015353-A	<1	FT-FY23-12292022-015353-B	<1
WS-015361	5/24/2022	5/24/2023	1	Combo Fountain	In room 100 infant Left	WF-05242022-015361	1/19/2023	FT-FY23-12292022-015361-A	<1	FT-FY23-12292022-015361-B	<1
WS-015362	5/24/2022	5/24/2023	1	Combo Fountain	In room 100 infant Right	WF-05242022-015362	1/19/2023	FT-FY23-12292022-015362-A	<1	FT-FY23-12292022-015362-B	<1
WS-015363	10/4/2022	10/4/2023	1	Combo Faucet	In room 100 infant Right	WF-10042022-015363	1/19/2023	FT-FY23-12292022-015363-A	<1	FT-FY23-12292022-015363-B	<1
WS-015365	5/24/2022	5/24/2023	1	Combo Fountain	In room 101 toddler room 1	WF-05242022-015365	1/19/2023	FT-FY23-12292022-015365-A	<1	FT-FY23-12292022-015365-B	<1
WS-015366	10/4/2022	10/4/2023	1	Combo Faucet	In room 101 toddler room 1	WF-10042022-015366	1/19/2023	FT-FY23-12292022-015366-A	<1	FT-FY23-12292022-015366-B	<1
WS-015367	5/24/2022	5/24/2023	1	Break Room	In room 105 workroom	WF-05242022-015367	1/19/2023	FT-FY23-12292022-015367-A	<1	FT-FY23-12292022-015367-B	<1
WS-015368	10/4/2022	10/4/2023	2	Combo Faucet	In room 215 pre-s/pre-k 4	WF-10042022-015368	1/19/2023	FT-FY23-12292022-015368-A	<1	FT-FY23-12292022-015368-B	<1
WS-015370	10/4/2022	10/4/2023	2	Combo Faucet	In room 218 pre-s/pre-k 5	WF-10042022-015370	1/19/2023	FT-FY23-12292022-015370-A	<1	FT-FY23-12292022-015370-B	<1
WS-015371	5/24/2022	5/24/2023	2	Combo Fountain	In room 218 pre-s/pre-k 5	WF-05242022-015371	1/19/2023	FT-FY23-12292022-015371-A	<1	FT-FY23-12292022-015371-B	<1
WS-015372	10/4/2022	10/4/2023	2	Combo Faucet	In room 200 toddler room 2	WF-10042022-015372	1/19/2023	FT-FY23-12292022-015372-A	<1	FT-FY23-12292022-015372-B	<1
WS-015373	5/24/2022	5/24/2023	2	Combo Fountain	In room 200 toddler room 2	WF-05242022-015373	1/19/2023	FT-FY23-12292022-015373-A	<1	FT-FY23-12292022-015373-B	<1
WS-015376	5/24/2022	5/24/2023	2	Combo Fountain	In room 206 toddler room 3	WF-05242022-015376	1/19/2023	FT-FY23-12292022-015376-A	<1	FT-FY23-12292022-015376-B	<1
WS-015377	10/4/2022	10/4/2023	2	Combo Faucet	In room 206 toddler room 3	WF-10042022-015377	1/19/2023	FT-FY23-12292022-015377-A	<1	FT-FY23-12292022-015377-B	<1
WS-015378	5/24/2022	5/24/2023	2	Bottle Filler	In hallway adjacent to room 212	WF-05242022-015378	1/19/2023	FT-FY23-12292022-015378-A	<1	FT-FY23-12292022-015378-B	<1
WS-015379	5/24/2022	5/24/2023	2	Cooler	In hallway adjacent to room 212 High Left	WF-05242022-015379	1/19/2023	FT-FY23-12292022-015379-A	<1	FT-FY23-12292022-015379-B	<1
WS-015380	5/24/2022	5/24/2023	2	Cooler	In hallway adjacent to room 212 Low Right	WF-05242022-015380	1/19/2023	FT-FY23-12292022-015380-A	<1	FT-FY23-12292022-015380-B	<1
WS-015381	10/4/2022	10/4/2023	2	Combo Faucet	In room 209 pre-s/pre-k 3	WF-10042022-015381	1/19/2023	FT-FY23-12292022-015381-A	<1	FT-FY23-12292022-015381-B	<1
WS-015382	5/24/2022	5/24/2023	2	Combo Fountain	In room 209 pre-s/pre-k 3	WF-05242022-015382	1/19/2023	FT-FY23-12292022-015382-A	<1	FT-FY23-12292022-015382-B	<1
WS-015383	10/4/2022	10/4/2023	3	Combo Faucet	In room 312 pre-s/pre-k 7	WF-10042022-015383	1/19/2023	FT-FY23-12292022-015383-A	<1	FT-FY23-12292022-015383-B	<1
WS-015384	5/24/2022	5/24/2023	3	Combo Fountain	In room 312 pre-s/pre-k 7	WF-05242022-015384	1/19/2023	FT-FY23-12292022-015384-A	<1	FT-FY23-12292022-015384-B	<1
WS-015385	10/4/2022	10/4/2023	3	Combo Faucet	In room 315 pre-s/pre-k 8	WF-10042022-015385	1/19/2023	FT-FY23-12292022-015385-A	<1	FT-FY23-12292022-015385-B	<1
WS-015388	5/24/2022	5/24/2023	3	Combo Fountain	In room 324 pre-s/pre-k 8	WF-05242022-015388	1/19/2023	FT-FY23-12292022-015388-A	<1	FT-FY23-12292022-015388-B	<1
WS-015389	10/4/2022	10/4/2023	3	Combo Faucet	In room 300 pre-s/pre-k 6	WF-10042022-015389	1/19/2023	FT-FY23-12292022-015389-A	<1	FT-FY23-12292022-015389-B	<1
WS-015392	5/24/2022	5/24/2023	3	Combo Fountain	In room 304 music	WF-05242022-015392	1/19/2023	FT-FY23-12292022-015392-A	<1	FT-FY23-12292022-015392-B	<1
WS-015393	5/24/2022	5/24/2023	3	Bottle Filler	In hallway adjacent to room 304	WF-05242022-015393	1/19/2023	FT-FY23-12292022-015393-A	<1	FT-FY23-12292022-015393-B	<1
WS-015394	5/24/2022	5/24/2023	3	Cooler	In hallway adjacent to room 304 High Left	WF-05242022-015394	1/19/2023	FT-FY23-12292022-015394-A	<1	FT-FY23-12292022-015394-B	<1
WS-015395	5/24/2022	5/24/2023	3	Cooler	In hallway adjacent to room 304 Low Right	WF-05242022-015395	1/19/2023	FT-FY23-12292022-015395-A	<1	FT-FY23-12292022-015395-B	<1
WS-015397	5/24/2022	5/24/2023	3	Combo Fountain	In room 308 art lab	WF-05242022-015397	1/19/2023	FT-FY23-12292022-015397-A	<1	FT-FY23-12292022-015397-B	<1
WS-015399	10/4/2022	10/4/2023	4	Combo Faucet	In room 413 pre-s/pre-k 9	WF-10042022-015399	1/19/2023	FT-FY23-12292022-015399-A	<1	FT-FY23-12292022-015399-B	<1
WS-015401	10/4/2022	10/4/2023	4	Combo Faucet	In room 419 pre-s/pre-k 10	WF-10042022-015401	1/19/2023	FT-FY23-12292022-015401-A	<1	FT-FY23-12292022-015401-B	<1
WS-015405	5/24/2022	5/24/2023	4	Break Room	In break room area across from room 404	WF-05242022-015405	1/19/2023	FT-FY23-12292022-015405-A	<1	FT-FY23-12292022-015405-B	<1

WS-015406	5/24/2022	5/24/2023	4	Break Room	In room 403 lactation	WF-05242022-015406	1/19/2023	FT-FY23-12292022-015406-A	<1	FT-FY23-12292022-015406-B	<1
WS-015407	11/14/2022	11/14/2023	4	Bottle Filler	In hallway adjacent to room 410	WF-11142022-015407	1/19/2023	FT-FY23-12292022-015407-A	<1	FT-FY23-12292022-015407-B	<1
WS-015408	11/14/2022	11/14/2023	4	Cooler	In hallway adjacent to room 410 High Left	WF-11142022-015408	1/19/2023	FT-FY23-12292022-015408-A	<1	FT-FY23-12292022-015408-B	<1
WS-015409	11/14/2022	11/14/2023	4	Cooler	In hallway adjacent to room 410 Low Right	WF-11142022-015409	1/19/2023	FT-FY23-12292022-015409-A	<1	FT-FY23-12292022-015409-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015358	2/17/2022	2/17/2023	1	Food Prep Sink	In kitchen fifth clockwise from entry	WF-02172022-015358	1/19/2023	FT-FY23-12292022-015358-A	<1	FT-FY23-12292022-015358-B	<1