



Theodore Hagans CC Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012558	3/14/2021	3/14/2022	Ground Floor	Cooler	In lobby adjacent to restrooms	High	Left	WF-03142021-012558	3/1/2022	FT-FY22-02032022-012558-A	<1	FT-FY22-02032022-012558-B	1.1
WS- 012559	3/14/2021	3/14/2022	Ground Floor	Cooler	In lobby adjacent to restrooms	Low	Right	WF-03142021-012559	3/1/2022	FT-FY22-02032022-012559-A	1.8	FT-FY22-02032022-012559-B	<1
WS- 012560	5/12/2021	5/12/2022	Ground Floor	Food Prep Sink	In kitchen			WF-05122021-012560	3/1/2022	FT-FY22-02032022-012560-A	<1	FT-FY22-02032022-012560-B	<1