



Theodore Hagans Cultural Center Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012558	3/10/2022	3/10/2023	Ground Floor	Cooler	In lobby adjacent to restrooms	High Left	WF-03102022-012558	2/21/2023	FT-FY23-02022023-012558-A	<1	FT-FY23-02022023-012558-B	<1
WS- 012559	3/10/2022	3/10/2023	Ground Floor	Cooler	In lobby adjacent to restrooms	Low Right	WF-03102022-012559	2/21/2023	FT-FY23-02022023-012559-A	<1	FT-FY23-02022023-012559-B	<1
WS- 012560	1/27/2023	1/27/2024	Ground Floor	Food Prep Sink	In kitchen		WF-01272023-012560	2/21/2023	FT-FY23-02022023-012560-A	1.0	FT-FY23-02022023-012560-B	<1