Thomas ES Lead in Water Test Results

FY27 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 006572	7/29/2026	7/29/2027	1	Break Room	In admin room 101A	WF-07292026-006572	8/7/2026	FT-FY27-08022026-006572-A	<1	FT-FY27-08022026-006572-B	<1
WS- 006574	7/29/2026	7/29/2027	1	Health Suite	In health suite room 105A	WF-07292026-006574	8/7/2026	FT-FY27-08022026-006574-A	<1	FT-FY27-08022026-006574-B	<1
WS- 006575	7/29/2026	7/29/2027	1	Bottle Filler	In hallway adjacent to elevator	WF-07292026-006575	8/7/2026	FT-FY27-08022026-006575-A	<1	FT-FY27-08022026-006575-B	<1
WS- 006576	7/29/2026	7/29/2027	1	Cooler	In hallway adjacent to elevator High Left	WF-07292026-006576	8/7/2026	FT-FY27-08022026-006576-A	<1	FT-FY27-08022026-006576-B	<1
WS- 006577	7/29/2026	7/29/2027	1	Cooler	In hallway adjacent to elevator Low Right	WF-07292026-006577	8/7/2026	FT-FY27-08022026-006577-A	<1	FT-FY27-08022026-006577-B	<1
WS- 006578	7/29/2026	7/29/2027	1	Bottle Filler	In cafeteria	WF-07292026-006578	8/7/2026	FT-FY27-08022026-006578-A	<1	FT-FY27-08022026-006578-B	<1
WS- 006579	7/29/2026	7/29/2027	1	Cooler	In cafeteria High Left	WF-07292026-006579	8/7/2026	FT-FY27-08022026-006579-A	<1	FT-FY27-08022026-006579-B	<1
WS- 006580	7/29/2026	7/29/2027	1	Cooler	In cafeteria Low Right	WF-07292026-006580	8/7/2026	FT-FY27-08022026-006580-A	<1	FT-FY27-08022026-006580-B	<1
WS- 006588	7/29/2026	7/29/2027	1	Bottle Filler	In gym 106	WF-07292026-006588	8/7/2026	FT-FY27-08022026-006588-A	<1	FT-FY27-08022026-006588-B	<1
WS- 006589	7/29/2026	7/29/2027	1	Cooler	In gym 106 High Left	WF-07292026-006589	8/7/2026	FT-FY27-08022026-006589-A	<1	FT-FY27-08022026-006589-B	<1
WS- 006590	7/29/2026	7/29/2027	1	Cooler	In gym 106 Low Right	WF-07292026-006590	8/7/2026	FT-FY27-08022026-006590-A	<1	FT-FY27-08022026-006590-B	<1
WS- 006591	7/29/2026	7/29/2027	1	Combo Faucet	In room 120	WF-07292026-006591	8/7/2026	FT-FY27-08022026-006591-A	<1	FT-FY27-08022026-006591-B	<1
WS- 006592	7/29/2026	7/29/2027	1	Combo Fountain	In room 120	WF-07292026-006592	8/7/2026	FT-FY27-08022026-006592-A	<1	FT-FY27-08022026-006592-B	<1
WS- 006594	7/29/2026	7/29/2027	1	Combo Faucet	In room 121	WF-07292026-006594	8/7/2026	FT-FY27-08022026-006594-A	<1	FT-FY27-08022026-006594-B	<1
WS- 006595	7/29/2026	7/29/2027	1	Combo Fountain	In room 121	WF-07292026-006595	8/7/2026	FT-FY27-08022026-006595-A	<1	FT-FY27-08022026-006595-B	<1
WS- 006597	7/29/2026	7/29/2027	1	Combo Faucet	In room 122	WF-07292026-006597	8/7/2026	FT-FY27-08022026-006597-A	<1	FT-FY27-08022026-006597-B	<1
WS- 006598	7/29/2026	7/29/2027	1	Combo Fountain	In room 122	WF-07292026-006598	8/7/2026	FT-FY27-08022026-006598-A	<1	FT-FY27-08022026-006598-B	<1
WS- 006603	7/29/2026	7/29/2027	1	Bottle Filler	In hallway adjacent to stairwell 2	WF-07292026-006603	8/7/2026	FT-FY27-08022026-006603-A	<1	FT-FY27-08022026-006603-B	<1
WS- 006604	7/29/2026	7/29/2027	1	Cooler	In hallway adjacent to stairwell 2 High Left	WF-07292026-006604	8/7/2026	FT-FY27-08022026-006604-A	<1	FT-FY27-08022026-006604-B	<1
WS- 006605	7/29/2026	7/29/2027	1	Cooler	In hallway adjacent to stairwell 2 Low Right	WF-07292026-006605	8/7/2026	FT-FY27-08022026-006605-A	<1	FT-FY27-08022026-006605-B	<1
WS- 006606	7/29/2026	7/29/2027	1	Break Room	In teacher collaboration room 125	WF-07292026-006606	8/7/2026	FT-FY27-08022026-006606-A	<1	FT-FY27-08022026-006606-B	<1
WS- 006607	7/29/2026	7/29/2027	1	Combo Fountain	In teacher collaboration room 125	WF-07292026-006607	8/7/2026	FT-FY27-08022026-006607-A	<1	FT-FY27-08022026-006607-B	<1
WS- 006608	7/29/2026	7/29/2027	1	Combo Faucet	In room 127 Low Right	WF-07292026-006608	8/7/2026	FT-FY27-08022026-006608-A	<1	FT-FY27-08022026-006608-B	<1
WS- 006609	7/29/2026	7/29/2027	1	Combo Fountain	In room 127 Low Right	WF-07292026-006609	8/7/2026	FT-FY27-08022026-006609-A	<1	FT-FY27-08022026-006609-B	<1
WS- 006611	7/29/2026	7/29/2027	1	Combo Fountain	In room 127 High Left	WF-07292026-006611	8/7/2026	FT-FY27-08022026-006611-A	<1	FT-FY27-08022026-006611-B	<1
WS- 006612	7/29/2026	7/29/2027	1	Combo Faucet	In room 128 Low Left	WF-07292026-006612	8/7/2026	FT-FY27-08022026-006612-A	<1	FT-FY27-08022026-006612-B	<1
WS- 006613	7/29/2026	7/29/2027	1	Combo Fountain	In room 128 Low Left	WF-07292026-006613	8/7/2026	FT-FY27-08022026-006613-A	<1	FT-FY27-08022026-006613-B	<1
WS- 006615	7/29/2026	7/29/2027	1	Combo Fountain	In room 128 High Right	WF-07292026-006615	8/7/2026	FT-FY27-08022026-006615-A	<1	FT-FY27-08022026-006615-B	<1
WS- 006616	7/29/2026	7/29/2027	1	Combo Faucet	In room 148	WF-07292026-006616	8/7/2026	FT-FY27-08022026-006616-A	<1	FT-FY27-08022026-006616-B	<1
WS- 006617	7/29/2026	7/29/2027	1	Combo Fountain	In room 148	WF-07292026-006617	8/7/2026	FT-FY27-08022026-006617-A	<1	FT-FY27-08022026-006617-B	<1
WS- 006619	7/29/2026	7/29/2027	1	Bottle Filler	In hallway across from room 148	WF-07292026-006619	8/7/2026	FT-FY27-08022026-006619-A	<1	FT-FY27-08022026-006619-B	<1
WS- 006620	7/29/2026	7/29/2027	1	Cooler	In hallway across from room 148 High Left	WF-07292026-006620	8/7/2026	FT-FY27-08022026-006620-A	<1	FT-FY27-08022026-006620-B	<1
WS- 006621	7/29/2026	7/29/2027	1	Cooler	In hallway across from room 148 Low Right	WF-07292026-006621	8/7/2026	FT-FY27-08022026-006621-A	<1	FT-FY27-08022026-006621-B	<1
WS- 006622	7/29/2026	7/29/2027	1	Combo Faucet	In room 146	WF-07292026-006622	8/7/2026	FT-FY27-08022026-006622-A	<1	FT-FY27-08022026-006622-B	<1

WS- 006623	7/29/2026	7/29/2027	1	Combo Fountain	In room 146			WF-07292026-006623	8/7/2026	FT-FY27-08022026-006623-A	<1	FT-FY27-08022026-006623-B	<1
WS- 006625	7/29/2026	7/29/2027	1	Classroom Faucet	In room 143 first clockwise from entry			WF-07292026-006625	8/7/2026	FT-FY27-08022026-006625-A	<1	FT-FY27-08022026-006625-B	<1
WS- 006627	7/29/2026	7/29/2027	1	Classroom Faucet	In room 145 first clockwise from entry			WF-07292026-006627	8/7/2026	FT-FY27-08022026-006627-A	<1	FT-FY27-08022026-006627-B	<1
WS- 006629	7/29/2026	7/29/2027	1	Break Room	In room 144			WF-07292026-006629	8/7/2026	FT-FY27-08022026-006629-A	<1	FT-FY27-08022026-006629-B	<1
WS- 006631	7/29/2026	7/29/2027	2	Bottle Filler	In hallway adjacent to stairwell 3			WF-07292026-006631	8/7/2026	FT-FY27-08022026-006631-A	<1	FT-FY27-08022026-006631-B	<1
WS- 006632	7/29/2026	7/29/2027	2	Cooler	In hallway adjacent to stairwell 3	High	Left	WF-07292026-006632	8/7/2026	FT-FY27-08022026-006632-A	<1	FT-FY27-08022026-006632-B	<1
WS- 006633	7/29/2026	7/29/2027	2	Cooler	In hallway adjacent to stairwell 3	Low	Right	WF-07292026-006633	8/7/2026	FT-FY27-08022026-006633-A	<1	FT-FY27-08022026-006633-B	<1
WS- 006635	7/29/2026	7/29/2027	2	Combo Fountain	In room 212			WF-07292026-006635	8/7/2026	FT-FY27-08022026-006635-A	<1	FT-FY27-08022026-006635-B	<1
WS- 006637	7/29/2026	7/29/2027	2	Combo Fountain	In art room 215		Left	WF-07292026-006637	8/7/2026	FT-FY27-08022026-006637-A	<1	FT-FY27-08022026-006637-B	<1
WS- 006639	7/29/2026	7/29/2027	2	Combo Fountain	In art room 215		Right	WF-07292026-006639	8/7/2026	FT-FY27-08022026-006639-A	<1	FT-FY27-08022026-006639-B	<1
WS- 006641	7/29/2026	7/29/2027	2	Combo Fountain	In music room 216			WF-07292026-006641	8/7/2026	FT-FY27-08022026-006641-A	<1	FT-FY27-08022026-006641-B	<1
WS- 006643	7/29/2026	7/29/2027	2	Combo Fountain	In specials lab 218 first clockwise from entry			WF-07292026-006643	8/7/2026	FT-FY27-08022026-006643-A	<1	FT-FY27-08022026-006643-B	<1
WS- 006645	7/29/2026	7/29/2027	2	Combo Fountain	In specials lab 218 second clockwise from entry			WF-07292026-006645	8/7/2026	FT-FY27-08022026-006645-A	<1	FT-FY27-08022026-006645-B	<1
WS- 006647	7/29/2026	7/29/2027	2	Combo Fountain	In specials lab 218 third clockwise from entry			WF-07292026-006647	8/7/2026	FT-FY27-08022026-006647-A	<1	FT-FY27-08022026-006647-B	<1
WS- 006649	7/29/2026	7/29/2027	2	Combo Fountain	In specials lab 218 fourth clockwise from entry			WF-07292026-006649	8/7/2026	FT-FY27-08022026-006649-A	<1	FT-FY27-08022026-006649-B	<1
WS- 006650	7/29/2026	7/29/2027	2	Combo Faucet	In room 224	Low	Left	WF-07292026-006650	8/7/2026	FT-FY27-08022026-006650-A	<1	FT-FY27-08022026-006650-B	<1
WS- 006651	7/29/2026	7/29/2027	2	Combo Fountain	In room 224	Low	Left	WF-07292026-006651	8/7/2026	FT-FY27-08022026-006651-A	<1	FT-FY27-08022026-006651-B	<1
WS- 006653	7/29/2026	7/29/2027	2	Combo Fountain	In room 224	High	Right	WF-07292026-006653	8/7/2026	FT-FY27-08022026-006653-A	<1	FT-FY27-08022026-006653-B	<1
WS- 006655	7/29/2026	7/29/2027	2	Combo Fountain	In room 223	High	Left	WF-07292026-006655	8/7/2026	FT-FY27-08022026-006655-A	<1	FT-FY27-08022026-006655-B	<1
WS- 006656	7/29/2026	7/29/2027	2	Combo Faucet	In room 223	Low	Right	WF-07292026-006656	8/7/2026	FT-FY27-08022026-006656-A	<1	FT-FY27-08022026-006656-B	<1
WS- 006657	7/29/2026	7/29/2027	2	Combo Fountain	In room 223	Low	Right	WF-07292026-006657	8/7/2026	FT-FY27-08022026-006657-A	<1	FT-FY27-08022026-006657-B	<1
WS- 006658	7/29/2026	7/29/2027	2	Combo Faucet	In room 226	Low	Left	WF-07292026-006658	8/7/2026	FT-FY27-08022026-006658-A	<1	FT-FY27-08022026-006658-B	<1
WS- 006659	7/29/2026	7/29/2027	2	Combo Fountain	In room 226	Low	Left	WF-07292026-006659	8/7/2026	FT-FY27-08022026-006659-A	<1	FT-FY27-08022026-006659-B	<1
WS- 006661	7/29/2026	7/29/2027	2	Combo Fountain	In room 226	High	Right	WF-07292026-006661	8/7/2026	FT-FY27-08022026-006661-A	<1	FT-FY27-08022026-006661-B	<1
WS- 006662	7/29/2026	7/29/2027	2	Break Room	In teacher collaboration room 222			WF-07292026-006662	8/7/2026	FT-FY27-08022026-006662-A	<1	FT-FY27-08022026-006662-B	<1
WS- 006663	7/29/2026	7/29/2027	2	Combo Fountain	In teacher collaboration room 222			WF-07292026-006663	8/7/2026	FT-FY27-08022026-006663-A	<1	FT-FY27-08022026-006663-B	<1
WS- 006664	7/29/2026	7/29/2027	2	Bottle Filler	In hallway adjacent to room 229			WF-07292026-006664	8/7/2026	FT-FY27-08022026-006664-A	<1	FT-FY27-08022026-006664-B	<1
WS- 006665	7/29/2026	7/29/2027	2	Cooler	In hallway adjacent to room 229	High	Left	WF-07292026-006665	8/7/2026	FT-FY27-08022026-006665-A	<1	FT-FY27-08022026-006665-B	<1
WS- 006666	7/29/2026	7/29/2027	2	Cooler	In hallway adjacent to room 229	Low	Right	WF-07292026-006666	8/7/2026	FT-FY27-08022026-006666-A	<1	FT-FY27-08022026-006666-B	<1
WS- 006667	7/29/2026	7/29/2027	2	Combo Faucet	In room 228	Low	Left	WF-07292026-006667	8/7/2026	FT-FY27-08022026-006667-A	<1	FT-FY27-08022026-006667-B	<1
WS- 006668	7/29/2026	7/29/2027	2	Combo Fountain	In room 228	Low	Left	WF-07292026-006668	8/7/2026	FT-FY27-08022026-006668-A	<1	FT-FY27-08022026-006668-B	<1
WS- 006670	7/29/2026	7/29/2027	2	Combo Fountain	In room 228	High	Right	WF-07292026-006670	8/7/2026	FT-FY27-08022026-006670-A	<1	FT-FY27-08022026-006670-B	<1
WS- 006671	7/29/2026	7/29/2027	2	Combo Faucet	In room 231	Low	Left	WF-07292026-006671	8/7/2026	FT-FY27-08022026-006671-A	<1	FT-FY27-08022026-006671-B	<1
WS- 006672	7/29/2026	7/29/2027	2	Combo Fountain	In room 231	Low	Left	WF-07292026-006672	8/7/2026	FT-FY27-08022026-006672-A	<1	FT-FY27-08022026-006672-B	<1
WS- 006674	7/29/2026	7/29/2027	2	Combo Fountain	In room 231	High	Right	WF-07292026-006674	8/7/2026	FT-FY27-08022026-006674-A	<1	FT-FY27-08022026-006674-B	<1
WS- 006675	7/29/2026	7/29/2027	3	Bottle Filler	In hallway adjacent to stairwell 3			WF-07292026-006675	8/7/2026	FT-FY27-08022026-006675-A	<1	FT-FY27-08022026-006675-B	<1
WS- 006676	7/29/2026	7/29/2027	3	Cooler	In hallway adjacent to stairwell 3	High	Left	WF-07292026-006676	8/7/2026	FT-FY27-08022026-006676-A	<1	FT-FY27-08022026-006676-B	<1
WS- 006677	7/29/2026	7/29/2027	3	Cooler	In hallway adjacent to stairwell 3	Low	Right	WF-07292026-006677	8/7/2026	FT-FY27-08022026-006677-A	<1	FT-FY27-08022026-006677-B	<1
WS- 006679	7/29/2026	7/29/2027	3	Combo Fountain	In room 304			WF-07292026-006679	8/7/2026	FT-FY27-08022026-006679-A	<1	FT-FY27-08022026-006679-B	<1
WS- 006681	7/29/2026	7/29/2027	3	Combo Fountain	In room 306			WF-07292026-006681	8/7/2026	FT-FY27-08022026-006681-A	<1	FT-FY27-08022026-006681-B	<1
WS- 006683	7/29/2026	7/29/2027	3	Combo Fountain	In room 310			WF-07292026-006683	8/7/2026	FT-FY27-08022026-006683-A	<1	FT-FY27-08022026-006683-B	<1

WS- 006685	7/29/2026	7/29/2027	3	Combo Fountain	In room 311	WF-07292026-006685	8/7/2026	FT-FY27-08022026-006685-A	<1	FT-FY27-08022026-006685-B	<1
WS- 006687	7/29/2026	7/29/2027	3	Combo Fountain	In room 312	WF-07292026-006687	8/7/2026	FT-FY27-08022026-006687-A	<1	FT-FY27-08022026-006687-B	<1
WS- 006688	7/29/2026	7/29/2027	3	Break Room	In teacher collaboration room 318	WF-07292026-006688	8/7/2026	FT-FY27-08022026-006688-A	<1	FT-FY27-08022026-006688-B	<1
WS- 006689	7/29/2026	7/29/2027	3	Combo Fountain	In teacher collaboration room 318	WF-07292026-006689	8/7/2026	FT-FY27-08022026-006689-A	<1	FT-FY27-08022026-006689-B	<1
WS- 006691	7/29/2026	7/29/2027	3	Combo Fountain	In room 321	WF-07292026-006691	8/7/2026	FT-FY27-08022026-006691-A	<1	FT-FY27-08022026-006691-B	<1
WS- 006693	7/29/2026	7/29/2027	3	Combo Fountain	In room 320	WF-07292026-006693	8/7/2026	FT-FY27-08022026-006693-A	<1	FT-FY27-08022026-006693-B	<1
WS- 006695	7/29/2026	7/29/2027	3	Combo Fountain	In room 324	WF-07292026-006695	8/7/2026	FT-FY27-08022026-006695-A	<1	FT-FY27-08022026-006695-B	<1
WS- 006697	7/29/2026	7/29/2027	3	Combo Fountain	In room 323	WF-07292026-006697	8/7/2026	FT-FY27-08022026-006697-A	<1	FT-FY27-08022026-006697-B	<1
WS- 006698	7/29/2026	7/29/2027	3	Bottle Filler	In hallway adjacent to room 326	WF-07292026-006698	8/7/2026	FT-FY27-08022026-006698-A	<1	FT-FY27-08022026-006698-B	<1
WS- 006699	7/29/2026	7/29/2027	3	Cooler	In hallway adjacent to room 326 High Left	WF-07292026-006699	8/7/2026	FT-FY27-08022026-006699-A	<1	FT-FY27-08022026-006699-B	<1
WS- 006700	7/29/2026	7/29/2027	3	Cooler	In hallway adjacent to room 326 Low Right	WF-07292026-006700	8/7/2026	FT-FY27-08022026-006700-A	<1	FT-FY27-08022026-006700-B	<1
WS- 006704	7/29/2026	7/29/2027	3	Break Room	In lactation suite 331	WF-07292026-006704	8/7/2026	FT-FY27-08022026-006704-A	<1	FT-FY27-08022026-006704-B	<1
WS- 006705	7/29/2026	7/29/2027	3	Bottle Filler	In staff lounge 333	WF-07292026-006705	8/7/2026	FT-FY27-08022026-006705-A	<1	FT-FY27-08022026-006705-B	<1
WS- 006706	7/29/2026	7/29/2027	3	Break Room	In staff lounge 333	WF-07292026-006706	8/7/2026	FT-FY27-08022026-006706-A	<1	FT-FY27-08022026-006706-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	**Filter Installed Date**	**Filter Expiration Date**	**Floor**	**Device Type**	**Device Location**	**Water Filter's Name**	**Date Analyzed**	**1st Draw - Sample ID**	**FT Final Result - 1st Draw (ppb)**	**2nd Draw - Sample ID**	**FT Final Result - 2nd Draw (ppb)**
WS- 006585	7/29/2026	7/29/2027	1	Food Prep Sink	In kitchen on back wall	WF-07292026-006585	8/7/2026	FT-FY27-08022026-006585-A	<1	FT-FY27-08022026-006585-B	<1