Thomas Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008771	2/28/2022	2/28/2023	1	Cooler	In health suite adjacent to principal's office	WF-02282022-008771	11/11/2022	FT-FY23-10102022-008771-A	<1	FT-FY23-10102022-008771-B	<1
WS- 008772	2/28/2022	2/28/2023	1	Cooler	In hallway adjacent to room 100 Low Right	WF-02282022-008772	11/11/2022	FT-FY23-10102022-008772-A	<1	FT-FY23-10102022-008772-B	<1
WS- 008773	2/28/2022	2/28/2023	1	Cooler	In hallway adjacent to room 100 High Left	WF-02282022-008773	11/11/2022	FT-FY23-10102022-008773-A	<1	FT-FY23-10102022-008773-B	<1
WS- 008774	8/16/2022	8/16/2023	1	Classroom Faucet	In classroom 104	WF-08162022-008774	11/11/2022	FT-FY23-10102022-008774-A	<1	FT-FY23-10102022-008774-B	<1
WS- 008775	8/16/2022	8/16/2023	1	Classroom Faucet	In classroom 106	WF-08162022-008775	11/11/2022	FT-FY23-10102022-008775-A	<1	FT-FY23-10102022-008775-B	<1
WS- 008776	2/28/2022	2/28/2023	1	Cooler	In hallway adjacent room 109 Low Left	WF-02282022-008776	11/11/2022	FT-FY23-10102022-008776-A	<1	FT-FY23-10102022-008776-B	<1
WS- 008777	2/28/2022	2/28/2023	1	Cooler	In hallway adjacent room 109 High Right	WF-02282022-008777	11/11/2022	FT-FY23-10102022-008777-A	<1	FT-FY23-10102022-008777-B	<1
WS- 008778	8/16/2022	8/16/2023	1	Classroom Faucet	In classroom 109	WF-08162022-008778	11/11/2022	FT-FY23-10102022-008778-A	<1	FT-FY23-10102022-008778-B	<1
WS- 008779	8/16/2022	8/16/2023	1	Classroom Faucet	In classroom 107	WF-08162022-008779	11/11/2022	FT-FY23-10102022-008779-A	<1	FT-FY23-10102022-008779-B	<1
WS- 008780	8/16/2022	8/16/2023	1	Classroom Faucet	In classroom 105	WF-08162022-008780	11/11/2022	FT-FY23-10102022-008780-A	<1	FT-FY23-10102022-008780-B	2.0
WS- 008781	8/16/2022	8/16/2023	1	Classroom Faucet	In classroom 101	WF-08162022-008781	11/11/2022	FT-FY23-10102022-008781-A	1.4	FT-FY23-10102022-008781-B	<1
WS- 008787	2/28/2022	2/28/2023	1	Cooler	In hallway adjacent to multi-purpose room	WF-02282022-008787	11/11/2022	FT-FY23-10102022-008787-A	<1	FT-FY23-10102022-008787-B	<1
WS- 008789	2/28/2022	2/28/2023	1	Cooler	In hallway adjacent to restrooms	WF-02282022-008789	11/11/2022	FT-FY23-10102022-008789-A	<1	FT-FY23-10102022-008789-B	<1
WS- 008790	8/16/2022	8/16/2023	2	Classroom Faucet	In classroom 200	WF-08162022-008790	11/11/2022	FT-FY23-10102022-008790-A	<1	FT-FY23-10102022-008790-B	<1
WS- 008791	2/28/2022	2/28/2023	2	Cooler	In hallway adjacent to room 201 High Left	WF-02282022-008791	11/11/2022	FT-FY23-10102022-008791-A	<1	FT-FY23-10102022-008791-B	<1
WS- 008792	2/28/2022	2/28/2023	2	Cooler	In hallway adjacent to room 201 Low Right	WF-02282022-008792	11/11/2022	FT-FY23-10102022-008792-A	<1	FT-FY23-10102022-008792-B	<1
WS- 008803	8/16/2022	8/16/2023	1	Classroom Faucet	In classroom 100	WF-08162022-008803	11/11/2022	FT-FY23-10102022-008803-A	<1	FT-FY23-10102022-008803-B	<1
WS- 008804	2/28/2022	2/28/2023	2	Cooler	In hallway adjacent to room 220	WF-02282022-008804	11/11/2022	FT-FY23-10102022-008804-A	<1	FT-FY23-10102022-008804-B	<1
WS- 008805	2/28/2022	2/28/2023	2	Break Room	In break room 217	WF-02282022-008805	11/11/2022	FT-FY23-10102022-008805-A	<1	FT-FY23-10102022-008805-B	<1
WS- 008835	2/28/2022	2/28/2023	1	Bottle Filler	In cafeteria	WF-02282022-008835	11/11/2022	FT-FY23-10102022-008835-A	<1	FT-FY23-10102022-008835-B	<1
WS- 008836	2/28/2022	2/28/2023	1	Cooler	In cafeteria High Left	WF-02282022-008836	11/11/2022	FT-FY23-10102022-008836-A	<1	FT-FY23-10102022-008836-B	<1
WS- 008837	2/28/2022	2/28/2023	1	Cooler	In cafeteria Low Right	WF-02282022-008837	11/11/2022	FT-FY23-10102022-008837-A	<1	FT-FY23-10102022-008837-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008872	2/16/2022	2/16/2023	1	Food Prep Sink	In kitchen, 4th sink clockwise from entrance	WF-02162022-008872	11/11/2022	FT-FY23-10102022-008872-A	<1	FT-FY23-10102022-008872-B	<1