



Thomas ES Lead Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 008770	3/26/2019	3/26/2020	1	Cooler	In room 100	WF-03262019-008770	11/4/2019	FT-FY20-102019-008770-A	<1	FT-FY20-102019-008770-B	<1	
WS- 008771	3/26/2019	3/26/2020	1	Health Suite	In health suite	WF-03262019-008771	11/4/2019	FT-FY20-102019-008771-A	<1	FT-FY20-102019-008771-B	<1	
WS- 008772	3/26/2019	3/26/2020	1	Cooler	In hallway adjacent to health suite	Low Right	WF-03262019-008772	11/4/2019	FT-FY20-102019-008772-A	<1	FT-FY20-102019-008772-B	<1
WS- 008773	3/26/2019	3/26/2020	1	Cooler	In hallway adjacent to health suite	High Left	WF-03262019-008773	11/4/2019	FT-FY20-102019-008773-A	<1	FT-FY20-102019-008773-B	<1
WS- 008774	9/11/2019	9/11/2020	1	Classroom Faucet	In classroom 104	WF-09112019-008774	11/4/2019	FT-FY20-102019-008774-A	<1	FT-FY20-102019-008774-B	<1	
WS- 008775	9/11/2019	9/11/2020	1	Classroom Faucet	In classroom 106	WF-09112019-008775	11/4/2019	FT-FY20-102019-008775-A	<1	FT-FY20-102019-008775-B	<1	
WS- 008776	3/26/2019	3/26/2020	1	Cooler	In hallway adjacent room 109	Low Left	WF-03262019-008776	11/4/2019	FT-FY20-102019-008776-A	<1	FT-FY20-102019-008776-B	<1
WS- 008777	3/26/2019	3/26/2020	1	Cooler	In hallway adjacent room 109	High Right	WF-03262019-008777	11/4/2019	FT-FY20-102019-008777-A	<1	FT-FY20-102019-008777-B	<1
WS- 008778	9/11/2019	9/11/2020	1	Classroom Faucet	In classroom 109	WF-09112019-008778	11/4/2019	FT-FY20-102019-008778-A	1.4	FT-FY20-102019-008778-B	<1	
WS- 008779	9/11/2019	9/11/2020	1	Classroom Faucet	In classroom 107	WF-09112019-008779	11/4/2019	FT-FY20-102019-008779-A	<1	FT-FY20-102019-008779-B	<1	
WS- 008780	9/11/2019	9/11/2020	1	Classroom Faucet	In classroom 105	WF-09112019-008780	11/4/2019	FT-FY20-102019-008780-A	<1	FT-FY20-102019-008780-B	<1	
WS- 008781	9/11/2019	9/11/2020	1	Classroom Faucet	In classroom 101	WF-09112019-008781	11/4/2019	FT-FY20-102019-008781-A	<1	FT-FY20-102019-008781-B	<1	
WS- 008787	3/26/2019	3/26/2020	1	Cooler	In hallway adjacent to multi-purpose room	WF-03262019-008787	11/4/2019	FT-FY20-102019-008787-A	<1	FT-FY20-102019-008787-B	<1	
WS- 008788	3/26/2019	3/26/2020	1	Cooler	In multi-purpose room	WF-03262019-008788	11/4/2019	FT-FY20-102019-008788-A	<1	FT-FY20-102019-008788-B	<1	
WS- 008789	3/26/2019	3/26/2020	1	Cooler	In hallway adjacent to restrooms	WF-03262019-008789	11/4/2019	FT-FY20-102019-008789-A	<1	FT-FY20-102019-008789-B	<1	
WS- 008790	9/11/2019	9/11/2020	2	Classroom Faucet	In classroom 200	WF-09112019-008790	11/4/2019	FT-FY20-102019-008790-A	<1	FT-FY20-102019-008790-B	<1	
WS- 008791	3/26/2019	3/26/2020	2	Cooler	In hallway adjacent to room 201	High Left	WF-03262019-008791	11/4/2019	FT-FY20-102019-008791-A	<1	FT-FY20-102019-008791-B	<1
WS- 008792	3/26/2019	3/26/2020	2	Cooler	In hallway adjacent to room 201	Low Right	WF-03262019-008792	11/4/2019	FT-FY20-102019-008792-A	<1	FT-FY20-102019-008792-B	<1
WS- 008801	3/26/2019	3/26/2020	2	Cooler	In hallway adjacent to room 209	High Left	WF-03262019-008801	11/4/2019	FT-FY20-102019-008801-A	<1	FT-FY20-102019-008801-B	<1
WS- 008802	3/26/2019	3/26/2020	2	Cooler	In hallway adjacent to room 209	Low Right	WF-03262019-008802	11/4/2019	FT-FY20-102019-008802-A	<1	FT-FY20-102019-008802-B	<1
WS- 008804	3/26/2019	3/26/2020	2	Cooler	In hallway adjacent to room 220	WF-03262019-008804	11/4/2019	FT-FY20-102019-008804-A	<1	FT-FY20-102019-008804-B	<1	
WS- 008805	3/26/2019	3/26/2020	2	Break Room	In break room 217	WF-03262019-008805	11/4/2019	FT-FY20-102019-008805-A	<1	FT-FY20-102019-008805-B	<1	
WS- 008808	3/26/2019	3/26/2020	2	Cooler	In hallway adjacent to room 214	WF-03262019-008808	11/4/2019	FT-FY20-102019-008808-A	<1	FT-FY20-102019-008808-B	<1	
WS- 008811	3/26/2019	3/26/2020	3	Cooler	In hallway adjacent to room 309	High Left	WF-03262019-008811	11/4/2019	FT-FY20-102019-008811-A	<1	FT-FY20-102019-008811-B	<1
WS- 008812	3/26/2019	3/26/2020	3	Cooler	In hallway adjacent to room 309	Low Right	WF-03262019-008812	11/4/2019	FT-FY20-102019-008812-A	<1	FT-FY20-102019-008812-B	<1
WS- 008813	3/26/2019	3/26/2020	3	Cooler	In hallway adjacent to room 300	High Left	WF-03262019-008813	11/4/2019	FT-FY20-102019-008813-A	<1	FT-FY20-102019-008813-B	<1
WS- 008814	3/26/2019	3/26/2020	3	Cooler	In hallway adjacent to room 300	Low Right	WF-03262019-008814	11/4/2019	FT-FY20-102019-008814-A	<1	FT-FY20-102019-008814-B	<1
WS- 008835	8/22/2019	8/22/2020	1	Bottle Filler	In cafeteria	WF-08222019-008835	11/4/2019	FT-FY20-102019-008835-A	<1	FT-FY20-102019-008835-B	<1	
WS- 008836	8/22/2019	8/22/2020	1	Cooler	In cafeteria	High Left	WF-08222019-008836	11/4/2019	FT-FY20-102019-008836-A	<1	FT-FY20-102019-008836-B	<1
WS- 008837	8/22/2019	8/22/2020	1	Cooler	In cafeteria	Low Right	WF-08222019-008837	11/4/2019	FT-FY20-102019-008837-A	<1	FT-FY20-102019-008837-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
-----------	-----------------------	------------------------	-------	-------------	-----------------	---------------------	---------------	----------------------	----------------------------------	----------------------	----------------------------------

WS-008872	8/22/2019	8/22/2020	1	Food Prep Sink	in kitchen, 4th sink clockwise from entrance	WF-08222019-008872	11/4/2019	FT-FY20-102019-008872-A	<1	FT-FY20-102019-008872-B	<1
-----------	-----------	-----------	---	----------------	--	--------------------	-----------	-------------------------	----	-------------------------	----