# Thomas Elementary School Lead in Water Test Results

## FY24 Filter Test

| Less than 5ppb - Devices requiring no remediation | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
| WS- 008771 | 2/21/2023 | 2/21/2024 | 1 | Cooler | In health suite adjacent to principal's office | WF-02212023-008771 | 10/23/2023 | FT-FY24-09282023-008771-A | <1 | FT-FY24-09282023-008771-B | <1 |
| WS- 008772 | 2/21/2023 | 2/21/2024 | 1 | Cooler | In hallway adjacent to room 100 Low Right | WF-02212023-008772 | 10/23/2023 | FT-FY24-09282023-008772-A | <1 | FT-FY24-09282023-008772-B | <1 |
| WS- 008773 | 2/21/2023 | 2/21/2024 | 1 | Cooler | In hallway adjacent to room 100 High Left | WF-02212023-008773 | 10/23/2023 | FT-FY24-09282023-008773-A | <1 | FT-FY24-09282023-008773-B | <1 |
| WS- 008774 | 8/9/2023 | 8/9/2024 | 1 | Classroom Faucet | In classroom 104 | WF-08092023-008774 | 10/23/2023 | FT-FY24-09282023-008774-A | 3.0 | FT-FY24-09282023-008774-B | <1 |
| WS- 008775 | 8/9/2023 | 8/9/2024 | 1 | Classroom Faucet | In classroom 106 | WF-08092023-008775 | 10/23/2023 | FT-FY24-09282023-008775-A | 1.3 | FT-FY24-09282023-008775-B | <1 |
| WS- 008776 | 2/21/2023 | 2/21/2024 | 1 | Cooler | In hallway adjacent room 109 Low Left | WF-02212023-008776 | 10/23/2023 | FT-FY24-09282023-008776-A | <1 | FT-FY24-09282023-008776-B | <1 |
| WS- 008777 | 2/21/2023 | 2/21/2024 | 1 | Cooler | In hallway adjacent room 109 High Right | WF-02212023-008777 | 10/23/2023 | FT-FY24-09282023-008777-A | <1 | FT-FY24-09282023-008777-B | <1 |
| WS- 008778 | 8/9/2023 | 8/9/2024 | 1 | Classroom Faucet | In classroom 109 | WF-08092023-008778 | 10/23/2023 | FT-FY24-09282023-008778-A | <1 | FT-FY24-09282023-008778-B | <1 |
| WS- 008779 | 8/9/2023 | 8/9/2024 | 1 | Classroom Faucet | In classroom 107 | WF-08092023-008779 | 10/23/2023 | FT-FY24-09282023-008779-A | 2.2 | FT-FY24-09282023-008779-B | <1 |
| WS- 008780 | 8/9/2023 | 8/9/2024 | 1 | Classroom Faucet | In classroom 105 | WF-08092023-008780 | 10/23/2023 | FT-FY24-09282023-008780-A | <1 | FT-FY24-09282023-008780-B | <1 |
| WS- 008781 | 8/9/2023 | 8/9/2024 | 1 | Classroom Faucet | In classroom 101 | WF-08092023-008781 | 10/23/2023 | FT-FY24-09282023-008781-A | 1.2 | FT-FY24-09282023-008781-B | <1 |
| WS- 008787 | 2/21/2023 | 2/21/2024 | 1 | Cooler | In hallway adjacent to multi-purpose room | WF-02212023-008787 | 10/23/2023 | FT-FY24-09282023-008787-A | <1 | FT-FY24-09282023-008787-B | <1 |
| WS- 008789 | 2/21/2023 | 2/21/2024 | 1 | Cooler | In hallway adjacent to restrooms | WF-02212023-008789 | 10/23/2023 | FT-FY24-09282023-008789-A | <1 | FT-FY24-09282023-008789-B | <1 |
| WS- 008790 | 8/9/2023 | 8/9/2024 | 2 | Classroom Faucet | In classroom 200 | WF-08092023-008790 | 10/23/2023 | FT-FY24-09282023-008790-A | 2.5 | FT-FY24-09282023-008790-B | <1 |
| WS- 008791 | 2/21/2023 | 2/21/2024 | 2 | Cooler | In hallway adjacent to room 201 High Left | WF-02212023-008791 | 10/23/2023 | FT-FY24-09282023-008791-A | <1 | FT-FY24-09282023-008791-B | <1 |
| WS- 008792 | 2/21/2023 | 2/21/2024 | 2 | Cooler | In hallway adjacent to room 201 Low Right | WF-02212023-008792 | 10/23/2023 | FT-FY24-09282023-008792-A | 1.4 | FT-FY24-09282023-008792-B | <1 |
| WS- 008803 | 8/9/2023 | 8/9/2024 | 1 | Classroom Faucet | In classroom 100 | WF-08092023-008803 | 10/23/2023 | FT-FY24-09282023-008803-A | 1.6 | FT-FY24-09282023-008803-B | <1 |
| WS- 008804 | 2/21/2023 | 2/21/2024 | 2 | Cooler | In hallway adjacent to room 220 | WF-02212023-008804 | 10/23/2023 | FT-FY24-09282023-008804-A | <1 | FT-FY24-09282023-008804-B | <1 |
| WS- 008805 | 2/21/2023 | 2/21/2024 | 2 | Break Room | In break room 217 | WF-02212023-008805 | 10/23/2023 | FT-FY24-09282023-008805-A | <1 | FT-FY24-09282023-008805-B | <1 |
| WS- 008835 | 2/21/2023 | 2/21/2024 | 1 | Bottle Filler | In cafeteria | WF-02212023-008835 | 10/23/2023 | FT-FY24-09282023-008835-A | <1 | FT-FY24-09282023-008835-B | <1 |
| WS- 008836 | 2/21/2023 | 2/21/2024 | 1 | Cooler | In cafeteria High Left | WF-02212023-008836 | 10/23/2023 | FT-FY24-09282023-008836-A | 1.1 | FT-FY24-09282023-008836-B | <1 |
| WS- 008837 | 2/21/2023 | 2/21/2024 | 1 | Cooler | In cafeteria Low Right | WF-02212023-008837 | 10/23/2023 | FT-FY24-09282023-008837-A | <1 | FT-FY24-09282023-008837-B | <1 |

## Food Prep Sink

| Less than 5ppb - Devices requiring no remediation | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
| WS- 008872 | 1/23/2023 | 1/23/2024 | 1 | Food Prep Sink | In kitchen, 4th sink clockwise from entrance | WF-01232023-008872 | 10/23/2023 | FT-FY24-09282023-008872-A | <1 | FT-FY24-09282023-008872-B | <1 |