



THOMAS LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw	
1	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008823	Classroom	3	In classroom 309	WT-042916-8840-A	< 1	WT-042916-8840-B	< 1				
2	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008822	Classroom	3	In 306	WT-042916-8839-A	< 1	WT-042916-8839-B	< 1				
3	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008821	Classroom	3	In classroom 307	WT-042916-8838-A	< 1	WT-042916-8838-B	< 1				
4	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008820	Classroom	3	In classroom 304	WT-042916-8837-A	< 1	WT-042916-8837-B	< 1				
5	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008819	Classroom	3	In classroom 305	WT-042916-8836-A	< 1	WT-042916-8836-B	1.31				
6	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008818	Classroom	3	In room 302	WT-042916-8835-A	18.3	WT-042916-8835-B	1.22	Filter will be installed and then retested			
7	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008817	Classroom	3	In classroom 303	WT-042916-8834-A	< 1	WT-042916-8834-B	< 1				
8	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008816	Classroom	3	In room 300	WT-042916-8833-A	< 1	WT-042916-8833-B	< 1				
9	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008815	Classroom	3	In classroom 301	WT-042916-8832-A	< 1	WT-042916-8832-B	< 1				
10	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008814	Classroom	3	In hallway adjacent to room 300 Right Low	WT-042916-8831-A	< 1	WT-042916-8831-B	< 1				
11	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008813	Cooler	3	In the hallway adjacent to room 300 Left High	WT-042916-8830-A	< 1	WT-042916-8830-B	< 1				
12	THOMAS ELEMENTARY SCHOOL	5/7/2016	WS-008812	Cooler	3	In hallway adjacent to room 309	WT-042916-8829-A	< 1	WT-042916-8829-B	< 1				
13	THOMAS ELEMENTARY SCHOOL	5/7/2016	WS-008811	Cooler	3	In hallway adjacent room 309	WT-042916-8828-A	< 1	WT-042916-8828-B	< 1				
14	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008810	Break Room	2	In break room 211	WT-042916-8827-A	21.8	WT-042916-8827-B	2.19	Filter will be installed and then retested			
15	THOMAS ELEMENTARY SCHOOL	5/7/2016	WS-008809	Classroom	2	In classroom 210	WT-042916-8826-A	5.96	WT-042916-8826-B	1.41				
16	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008808	Cooler	2	In hallway adjacent 214 Mid	WT-042916-8825-A	< 1	WT-042916-8825-B	< 1				
17	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008807	Classroom	2	In room 216 art room south wall	WT-042916-8824-A	< 1	WT-042916-8824-B	< 1				
18	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008806	Classroom	2	In room 216 art room north wall	WT-042916-8823-A	< 1	WT-042916-8823-B	< 1				
19	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008805	Classroom	2	In room 217	WT-042916-8822-A	< 1	WT-042916-8822-B	1.25				
20	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008804	Cooler	2	In hallway adjacent room 220	WT-042916-8821-A	< 1	WT-042916-8821-B	< 1				
21	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008802	Cooler	2	In hallway adjacent room 209	WT-042916-8819-A	< 1	WT-042916-8819-B	< 1				
22	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008801	Cooler	2	In hallway adjacent to room 209 High	WT-042916-8818-A	< 1	WT-042916-8818-B	< 1				
23	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008800	Classroom	2	In room 209	WT-042916-8817-A	< 1	WT-042916-8817-B	< 1				
24	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008799	Classroom	2	In room 207	WT-042916-8816-A	< 1	WT-042916-8816-B	< 1				
25	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008798	Classroom	2	In room 201	WT-042916-8815-A	< 1	WT-042916-8815-B	< 1				
26	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008797	Classroom	2	In room 206	WT-042916-8814-A	20.2	WT-042916-8814-B	< 1	Filter will be installed and then retested			
27	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008796	Classroom	2	In room 204	WT-042916-8813-A	1.08	WT-042916-8813-B	< 1				
28	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008795	Classroom	2	In room 205	WT-042916-8812-A	< 1	WT-042916-8812-B	< 1				
29	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008794	Classroom	2	In room 202	WT-042916-8811-A	< 1	WT-042916-8811-B	< 1				
30	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008793	Classroom	2	In room 203	WT-042916-8810-A	< 1	WT-042916-8810-B	< 1				
31	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008792	Cooler	2	In hallway adjacent room 20	WT-042916-8809-A	< 1	WT-042916-8809-B	< 1				
32	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008791	Cooler	2	In hallway adjacent the room 201 High	WT-042916-8808-A	< 1	WT-042916-8808-B	< 1				
33	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008790	Classroom	2	In room 200	WT-042916-8807-A	< 1	WT-042916-8807-B	< 1				
34	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008789	Cooler	1	In hallway adjacent APR north wall	WT-042916-8806-A	< 1	WT-042916-8806-B	< 1				
35	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008788	Cooler	1	In APR	WT-042916-8805-A	< 1	WT-042916-8805-B	< 1				
36	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008787	Cooler	1	In hallway adjacent APR southwall	WT-042916-8804-A	< 1	WT-042916-8804-B	< 1				
37	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008786	Kitchen	1	In north wall far right Right	WT-042916-8803-A	18	WT-042916-8803-B	< 1	Filter will be installed and then retested			
38	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008785	Kitchen	1	In north wall middle right	WT-042916-8802-A	< 1	WT-042916-8802-B	< 1				
39	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008784	Kitchen	1	In north wall middle/left	WT-042916-8801-A	< 1	WT-042916-8801-B	< 1				
40	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008783	Kitchen	1	In north wall Left	WT-042916-8800-A	1.12	WT-042916-8800-B	< 1				
41	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008782	Kitchen	1	In west wall	WT-042916-8799-A	389	WT-042916-8799-B	96.2	Filter will be installed and then retested			
42	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008781	Classroom	1	In room 101	WT-042916-8798-A	< 1	WT-042916-8798-B	< 1				
43	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008780	Classroom	1	In room 105	WT-042916-8797-A	< 1	WT-042916-8797-B	< 1				
44	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008779	Classroom	1	In room 107	WT-042916-8796-A	< 1	WT-042916-8796-B	< 1				
45	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008778	Classroom	1	In room 109	WT-042916-8795-A	< 1	WT-042916-8795-B	< 1				
46	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008777	Cooler	1	In hallway adjacent room 109 High	WT-042916-8794-A	< 1	WT-042916-8794-B	< 1				
47	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008776	Cooler	1	In hallway adjacent room 109 Low	WT-042916-8793-A	< 1	WT-042916-8793-B	< 1				
48	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008775	Classroom	1	In room 106	WT-042916-8792-A	1.67	WT-042916-8792-B	< 1				
49	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008774	Classroom	1	In room 104	WT-042916-8791-A	< 1	WT-042916-8791-B	< 1				
50	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008773	Cooler	1	In hallway adjacent to health suite Low	WT-042916-8790-A	< 1	WT-042916-8790-B	< 1				
51	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008772	Cooler	1	In hallway adjacent to health suite High	WT-042916-8789-A	< 1	WT-042916-8789-B	< 1				
52	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008771	Health Suite	1	In Health suite/sink	WT-042916-8788-A	< 1	WT-042916-8788-B	< 1				
53	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008770	Cooler	1	In health suite	WT-042916-8787-A	< 1	WT-042916-8787-B	< 1				
54	THOMAS ELEMENTARY SCHOOL	5/6/2016	WS-008769	Utility	Basement	In boiler room	WT-042916-8786-A	614	WT-042916-8786-B	43.7	Non-drinking water source - Not accessible to children (boilers)			

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.