



THOMAS ES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	THOMAS ELEMENTARY SCHOOL	WS- 008810	1/11/2017	2	Break Room	In break room 211	FT-102016-008810-A	< 1	FT-102016-008810-B	< 1
2	THOMAS ELEMENTARY SCHOOL	WS- 008805	1/11/2017	2	Break Room	In break room 217	FT-102016-008805-A	< 1	FT-102016-008805-B	< 1
3	THOMAS ELEMENTARY SCHOOL	WS- 008779	1/11/2017	1	Classroom Faucet	In classroom 107	FT-112016-008779-A	< 1	FT-112016-008779-B	< 1
4	THOMAS ELEMENTARY SCHOOL	WS- 008774	1/11/2017	1	Classroom Faucet	In classroom 104	FT-112016-008774-A	< 1	FT-112016-008774-B	< 1
5	THOMAS ELEMENTARY SCHOOL	WS- 008781	1/11/2017	1	Classroom Faucet	In classroom 101	FT-112016-008781-A	< 1	FT-112016-008781-B	< 1
6	THOMAS ELEMENTARY SCHOOL	WS- 008775	1/11/2017	1	Classroom Faucet	In classroom 106	FT-112016-008775-A	< 1	FT-112016-008775-B	< 1
7	THOMAS ELEMENTARY SCHOOL	WS- 008780	1/11/2017	1	Classroom Faucet	In classroom 105	FT-112016-008780-A	< 1	FT-112016-008780-B	< 1
8	THOMAS ELEMENTARY SCHOOL	WS- 008778	1/11/2017	1	Classroom Faucet	In classroom 109	FT-112016-008778-A	< 1	FT-112016-008778-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb