



Thomas ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002323	4/2/2018	4/2/2019	1	Cooler	In cafeteria	WF-04022018-002323	10/30/2018	FT-FY19-102018-002323-A	< 1	FT-FY19-102018-002323-B	< 1	
WS- 008770	4/2/2018	4/2/2019	1	Cooler	In health suite	WF-04022018-008770	10/30/2018	FT-FY19-102018-008770-A	< 1	FT-FY19-102018-008770-B	< 1	
WS- 008771	4/2/2018	4/2/2019	1	Health Suite	In health suite	WF-04022018-008771	10/30/2018	FT-FY19-102018-008771-A	< 1	FT-FY19-102018-008771-B	< 1	
WS- 008772	4/2/2018	4/2/2019	1	Cooler	In hallway adjacent to health suite	High Left	WF-04022018-008772	10/30/2018	FT-FY19-102018-008772-A	< 1	FT-FY19-102018-008772-B	< 1
WS- 008773	4/2/2018	4/2/2019	1	Cooler	In hallway adjacent to health suite	Low Right	WF-04022018-008773	10/30/2018	FT-FY19-102018-008773-A	< 1	FT-FY19-102018-008773-B	< 1
WS- 008774	9/17/2018	9/17/2019	1	Classroom Faucet	In classroom 104	WF-09172018-008774	10/30/2018	FT-FY19-102018-008774-A	< 1	FT-FY19-102018-008774-B	< 1	
WS- 008775	9/17/2018	9/17/2019	1	Classroom Faucet	In classroom 106	WF-09172018-008775	10/30/2018	FT-FY19-102018-008775-A	< 1	FT-FY19-102018-008775-B	< 1	
WS- 008776	4/2/2018	4/2/2019	1	Cooler	In hallway adjacent room 109	Low Left	WF-04022018-008776	10/30/2018	FT-FY19-102018-008776-A	< 1	FT-FY19-102018-008776-B	< 1
WS- 008777	4/2/2018	4/2/2019	1	Cooler	In hallway adjacent room 109	High Right	WF-04022018-008777	10/30/2018	FT-FY19-102018-008777-A	< 1	FT-FY19-102018-008777-B	< 1
WS- 008778	9/17/2018	9/17/2019	1	Classroom Faucet	In classroom 109	WF-09172018-008778	10/30/2018	FT-FY19-102018-008778-A	< 1	FT-FY19-102018-008778-B	< 1	
WS- 008779	9/17/2018	9/17/2019	1	Classroom Faucet	In classroom 107	WF-09172018-008779	10/30/2018	FT-FY19-102018-008779-A	< 1	FT-FY19-102018-008779-B	< 1	
WS- 008780	9/17/2018	9/17/2019	1	Classroom Faucet	In classroom 105	WF-09172018-008780	10/30/2018	FT-FY19-102018-008780-A	< 1	FT-FY19-102018-008780-B	< 1	
WS- 008781	9/17/2018	9/17/2019	1	Classroom Faucet	In classroom 101	WF-09172018-008781	10/30/2018	FT-FY19-102018-008781-A	< 1	FT-FY19-102018-008781-B	< 1	
WS- 008787	4/2/2018	4/2/2019	1	Cooler	In hallway adjacent to multi-purpose room	WF-04022018-008787	10/30/2018	FT-FY19-102018-008787-A	< 1	FT-FY19-102018-008787-B	< 1	
WS- 008788	4/2/2018	4/2/2019	1	Cooler	In multi-purpose room	WF-04022018-008788	10/30/2018	FT-FY19-102018-008788-A	< 1	FT-FY19-102018-008788-B	< 1	
WS- 008789	4/2/2018	4/2/2019	1	Cooler	In hallway adjacent to restrooms	WF-04022018-008789	10/30/2018	FT-FY19-102018-008789-A	< 1	FT-FY19-102018-008789-B	< 1	
WS- 008790	9/19/2018	9/19/2019	2	Classroom Faucet	In classroom 200	WF-09192018-008790	10/30/2018	FT-FY19-102018-008790-A	< 1	FT-FY19-102018-008790-B	< 1	
WS- 008791	4/2/2018	4/2/2019	2	Cooler	In hallway adjacent to room 201	High Left	WF-04022018-008791	10/30/2018	FT-FY19-102018-008791-A	< 1	FT-FY19-102018-008791-B	< 1
WS- 008792	4/2/2018	4/2/2019	2	Cooler	In hallway adjacent to room 201	Low Right	WF-04022018-008792	10/30/2018	FT-FY19-102018-008792-A	< 1	FT-FY19-102018-008792-B	< 1
WS- 008801	10/18/2018	10/18/2019	2	Cooler	In hallway adjacent to room 209	High Left	WF-10182018-008801	10/30/2018	FT-FY19-102018-008801-A	< 1	FT-FY19-102018-008801-B	< 1
WS- 008802	10/18/2018	10/18/2019	2	Cooler	In hallway adjacent to room 209	Low Right	WF-10182018-008802	10/30/2018	FT-FY19-102018-008802-A	< 1	FT-FY19-102018-008802-B	< 1
WS- 008804	4/2/2018	4/2/2019	2	Cooler	In hallway adjacent to room 220	WF-04022018-008804	10/30/2018	FT-FY19-102018-008804-A	< 1	FT-FY19-102018-008804-B	< 1	
WS- 008805	4/2/2018	4/2/2019	2	Break Room	In break room 217	WF-04022018-008805	10/30/2018	FT-FY19-102018-008805-A	< 1	FT-FY19-102018-008805-B	< 1	
WS- 008808	4/2/2018	4/2/2019	2	Cooler	In hallway adjacent to room 214	WF-04022018-008808	10/30/2018	FT-FY19-102018-008808-A	< 1	FT-FY19-102018-008808-B	< 1	
WS- 008810	4/2/2018	4/2/2019	2	Classroom Faucet	In book storage room 211	WF-04022018-008810	10/30/2018	FT-FY19-102018-008810-A	1.4	FT-FY19-102018-008810-B	1.1	
WS- 008811	4/2/2018	4/2/2019	3	Cooler	In hallway adjacent to room 309	High Left	WF-04022018-008811	10/30/2018	FT-FY19-102018-008811-A	< 1	FT-FY19-102018-008811-B	< 1
WS- 008812	4/2/2018	4/2/2019	3	Cooler	In hallway adjacent to room 309	Low Right	WF-04022018-008812	10/30/2018	FT-FY19-102018-008812-A	< 1	FT-FY19-102018-008812-B	< 1
WS- 008813	4/2/2018	4/2/2019	3	Cooler	In hallway adjacent to room 300	High Left	WF-04022018-008813	10/30/2018	FT-FY19-102018-008813-A	< 1	FT-FY19-102018-008813-B	< 1
WS- 008814	4/2/2018	4/2/2019	3	Cooler	In hallway adjacent to room 300	Low Right	WF-04022018-008814	10/30/2018	FT-FY19-102018-008814-A	< 1	FT-FY19-102018-008814-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
---	--	--	--	--	--	--	--	--	--	--	--

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008785	1	Food Prep Sink	In kitchen fourth clockwise from entry door	10/30/2018	FT-FY19-102018-008785-A	< 1	FT-FY19-102018-008785-B	< 1
WS- 008786	1	Food Prep Sink	In kitchen fifth clockwise from entry door Right	10/30/2018	FT-FY19-102018-008786-A	< 1	FT-FY19-102018-008786-B	< 1