



# Thomson Elementary School Lead in Water Test Results



## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-000491	9/9/2020	9/9/2021	1	Combo Faucet	In classroom 123	Left	WF-09092020-000491	2/7/2021	FT-FY21-012021-000491-A	<1	FT-FY21-012021-000491-B	<1
WS-000492	6/8/2020	6/8/2021	1	Combo Fountain	In classroom 123	Right	WF-06082020-000492	2/7/2021	FT-FY21-012021-000492-A	<1	FT-FY21-012021-000492-B	<1
WS-000493	9/9/2020	9/9/2021	1	Combo Faucet	In classroom 124	Left	WF-09092020-000493	2/7/2021	FT-FY21-012021-000493-A	<1	FT-FY21-012021-000493-B	<1
WS-000494	6/8/2020	6/8/2021	1	Combo Fountain	In classroom 124	Right	WF-06082020-000494	2/7/2021	FT-FY21-012021-000494-A	<1	FT-FY21-012021-000494-B	<1
WS-000495	9/9/2020	9/9/2021	1	Combo Faucet	In classroom 126	Left	WF-09092020-000495	2/7/2021	FT-FY21-012021-000495-A	<1	FT-FY21-012021-000495-B	<1
WS-000496	6/8/2020	6/8/2021	1	Combo Fountain	In classroom 126	Right	WF-06082020-000496	2/7/2021	FT-FY21-012021-000496-A	<1	FT-FY21-012021-000496-B	<1
WS-000497	6/8/2020	6/8/2021	1	Combo Fountain	In classroom 127	Right	WF-06082020-000497	2/7/2021	FT-FY21-012021-000497-A	<1	FT-FY21-012021-000497-B	<1
WS-000498	9/9/2020	9/9/2021	1	Combo Faucet	In classroom 127	Left	WF-09092020-000498	2/7/2021	FT-FY21-012021-000498-A	<1	FT-FY21-012021-000498-B	<1
WS-000499	6/8/2020	6/8/2021	1	Cooler	In hallway adjacent to room 130	High Left	WF-06082020-000499	2/7/2021	FT-FY21-012021-000499-A	<1	FT-FY21-012021-000499-B	<1
WS-000500	6/8/2020	6/8/2021	1	Cooler	In hallway adjacent to room 129	Low Right	WF-06082020-000500	2/7/2021	FT-FY21-012021-000500-A	<1	FT-FY21-012021-000500-B	<1
WS-000501	6/8/2020	6/8/2021	1	Health Suite	In health suite in treatment room 110	Mid	WF-06082020-000501	2/7/2021	FT-FY21-012021-000501-A	<1	FT-FY21-012021-000501-B	<1
WS-000502	6/8/2020	6/8/2021	1	Combo Fountain	In classroom 112	Right	WF-06082020-000502	2/7/2021	FT-FY21-012021-000502-A	<1	FT-FY21-012021-000502-B	<1
WS-000503	9/9/2020	9/9/2021	1	Combo Faucet	In classroom 112	Left	WF-09092020-000503	2/7/2021	FT-FY21-012021-000503-A	<1	FT-FY21-012021-000503-B	<1
WS-000504	9/9/2020	9/9/2021	1	Combo Faucet	In classroom 115	Left	WF-09092020-000504	2/7/2021	FT-FY21-012021-000504-A	<1	FT-FY21-012021-000504-B	<1
WS-000505	6/8/2020	6/8/2021	1	Combo Fountain	In classroom 115	Right	WF-06082020-000505	2/7/2021	FT-FY21-012021-000505-A	<1	FT-FY21-012021-000505-B	<1
WS-000506	9/9/2020	9/9/2021	1	Combo Faucet	In classroom 114	Left	WF-09092020-000506	2/7/2021	FT-FY21-012021-000506-A	<1	FT-FY21-012021-000506-B	<1
WS-000507	6/8/2020	6/8/2021	1	Combo Fountain	In classroom 114	Right	WF-06082020-000507	2/7/2021	FT-FY21-012021-000507-A	<1	FT-FY21-012021-000507-B	<1
WS-000508	9/9/2020	9/9/2021	1	Combo Faucet	In classroom 113	Left	WF-09092020-000508	2/7/2021	FT-FY21-012021-000508-A	<1	FT-FY21-012021-000508-B	<1
WS-000510	6/8/2020	6/8/2021	1	Combo Fountain	In classroom 113	Right	WF-06082020-000510	2/7/2021	FT-FY21-012021-000510-A	<1	FT-FY21-012021-000510-B	<1
WS-000511	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 210	Right	WF-06082020-000511	2/7/2021	FT-FY21-012021-000511-A	<1	FT-FY21-012021-000511-B	<1
WS-000512	9/9/2020	9/9/2021	2	Combo Faucet	In classroom 210	Left	WF-09092020-000512	2/7/2021	FT-FY21-012021-000512-A	<1	FT-FY21-012021-000512-B	<1
WS-000513	9/9/2020	9/9/2021	2	Combo Faucet	In classroom 209	Left	WF-09092020-000513	2/7/2021	FT-FY21-012021-000513-A	<1	FT-FY21-012021-000513-B	<1
WS-000514	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 209	Right	WF-06082020-000514	2/7/2021	FT-FY21-012021-000514-A	<1	FT-FY21-012021-000514-B	<1
WS-000515	9/9/2020	9/9/2021	2	Combo Faucet	In classroom 211	Left	WF-09092020-000515	2/7/2021	FT-FY21-012021-000515-A	<1	FT-FY21-012021-000515-B	<1
WS-000516	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 211	Right	WF-06082020-000516	2/7/2021	FT-FY21-012021-000516-A	<1	FT-FY21-012021-000516-B	<1
WS-000517	9/9/2020	9/9/2021	2	Combo Faucet	In classroom 208	Left	WF-09092020-000517	2/7/2021	FT-FY21-012021-000517-A	<1	FT-FY21-012021-000517-B	<1
WS-000518	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 208	Right	WF-06082020-000518	2/7/2021	FT-FY21-012021-000518-A	<1	FT-FY21-012021-000518-B	<1
WS-000519	6/8/2020	6/8/2021	2	Cooler	In hallway adjacent to room 201	Low Left	WF-06082020-000519	2/7/2021	FT-FY21-012021-000519-A	<1	FT-FY21-012021-000519-B	<1
WS-000520	6/8/2020	6/8/2021	2	Cooler	In hallway adjacent to room 201	High Right	WF-06082020-000520	2/7/2021	FT-FY21-012021-000520-A	<1	FT-FY21-012021-000520-B	<1
WS-000521	9/9/2020	9/9/2021	2	Combo Faucet	In classroom 223	Left	WF-09092020-000521	2/7/2021	FT-FY21-012021-000521-A	<1	FT-FY21-012021-000521-B	<1
WS-000522	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 223	Right	WF-06082020-000522	2/7/2021	FT-FY21-012021-000522-A	<1	FT-FY21-012021-000522-B	<1
WS-000523	9/9/2020	9/9/2021	2	Combo Faucet	In classroom 221	Left	WF-09092020-000523	2/7/2021	FT-FY21-012021-000523-A	<1	FT-FY21-012021-000523-B	<1

WS- 000524	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 221	Right	WF-06082020-000524	2/7/2021	FT-FY21-012021-000524-A	<1	FT-FY21-012021-000524-B	<1
WS- 000525	9/9/2020	9/9/2021	2	Combo Faucet	In classroom 220	Left	WF-09092020-000525	2/7/2021	FT-FY21-012021-000525-A	<1	FT-FY21-012021-000525-B	<1
WS- 000526	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 220	Right	WF-06082020-000526	2/7/2021	FT-FY21-012021-000526-A	<1	FT-FY21-012021-000526-B	<1
WS- 000527	9/9/2020	9/9/2021	2	Combo Faucet	In classroom 219	Left	WF-09092020-000527	2/7/2021	FT-FY21-012021-000527-A	<1	FT-FY21-012021-000527-B	<1
WS- 000528	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 219	Right	WF-06082020-000528	2/7/2021	FT-FY21-012021-000528-A	<1	FT-FY21-012021-000528-B	<1
WS- 000529	9/9/2020	9/9/2021	3	Combo Faucet	In classroom 309	Left	WF-09092020-000529	2/7/2021	FT-FY21-012021-000529-A	<1	FT-FY21-012021-000529-B	<1
WS- 000530	6/8/2020	6/8/2021	3	Combo Fountain	In classroom 309	Right	WF-06082020-000530	2/7/2021	FT-FY21-012021-000530-A	<1	FT-FY21-012021-000530-B	<1
WS- 000531	9/9/2020	9/9/2021	3	Combo Faucet	In classroom 310	Left	WF-09092020-000531	2/7/2021	FT-FY21-012021-000531-A	<1	FT-FY21-012021-000531-B	<1
WS- 000532	6/8/2020	6/8/2021	3	Combo Fountain	In classroom 310	Right	WF-06082020-000532	2/7/2021	FT-FY21-012021-000532-A	<1	FT-FY21-012021-000532-B	<1
WS- 000534	6/8/2020	6/8/2021	3	Combo Fountain	In classroom 308	Right	WF-06082020-000534	2/7/2021	FT-FY21-012021-000534-A	<1	FT-FY21-012021-000534-B	<1
WS- 000535	9/9/2020	9/9/2021	3	Combo Faucet	In classroom 307	Left	WF-09092020-000535	2/7/2021	FT-FY21-012021-000535-A	<1	FT-FY21-012021-000535-B	<1
WS- 000536	6/8/2020	6/8/2021	3	Combo Fountain	In classroom 307	Right	WF-06082020-000536	2/7/2021	FT-FY21-012021-000536-A	<1	FT-FY21-012021-000536-B	<1
WS- 000546	6/8/2020	6/8/2021	2	Break Room	In staff lounge 218		WF-06082020-000546	2/7/2021	FT-FY21-012021-000546-A	<1	FT-FY21-012021-000546-B	<1
WS- 000571	6/8/2020	6/8/2021	3	Combo Fountain	In library in room 301 Reading / Learning / Circle Area		WF-06082020-000571	2/7/2021	FT-FY21-012021-000571-A	<1	FT-FY21-012021-000571-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000541	1/22/2020	1/22/2021	Basement	Food Prep Sink	In kitchen first clockwise from entry door	WF-01222020-000541	2/7/2021	FT-FY21-012021-000541-A	<1	FT-FY21-012021-000541-B	<1
WS- 000543	1/22/2020	1/22/2021	Basement	Food Prep Sink	In kitchen second clockwise from entry door	WF-01222020-000543	2/7/2021	FT-FY21-012021-000543-A	<1	FT-FY21-012021-000543-B	<1