



Thomson ES Lead Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 000488	4/24/2019	4/24/2020	Ground Floor	Cooler	In hallway adjacent to room G02	High Left	WF-04242019-000488	11/4/2019	FT-FY20-102019-000488-A	<1	FT-FY20-102019-000488-B	<1
WS- 000489	4/24/2019	4/24/2020	Ground Floor	Cooler	In hallway adjacent to room G02	Low Right	WF-04242019-000489	11/4/2019	FT-FY20-102019-000489-A	<1	FT-FY20-102019-000489-B	<1
WS- 000491	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 123	Left	WF-09162019-000491	11/4/2019	FT-FY20-102019-000491-A	<1	FT-FY20-102019-000491-B	<1
WS- 000492	4/24/2019	4/24/2020	1	Combo Fountain	In classroom 123	Right	WF-04242019-000492	11/4/2019	FT-FY20-102019-000492-A	<1	FT-FY20-102019-000492-B	<1
WS- 000493	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 124	Left	WF-09162019-000493	11/4/2019	FT-FY20-102019-000493-A	2.2	FT-FY20-102019-000493-B	<1
WS- 000494	4/24/2019	4/24/2020	1	Combo Fountain	In classroom 124	Right	WF-04242019-000494	11/4/2019	FT-FY20-102019-000494-A	<1	FT-FY20-102019-000494-B	<1
WS- 000495	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 126	Left	WF-09162019-000495	11/4/2019	FT-FY20-102019-000495-A	1.3	FT-FY20-102019-000495-B	<1
WS- 000496	4/24/2019	4/24/2020	1	Combo Fountain	In classroom 126	Right	WF-04242019-000496	11/4/2019	FT-FY20-102019-000496-A	<1	FT-FY20-102019-000496-B	<1
WS- 000497	4/24/2019	4/24/2020	1	Combo Fountain	In classroom 127	Right	WF-04242019-000497	11/4/2019	FT-FY20-102019-000497-A	<1	FT-FY20-102019-000497-B	<1
WS- 000498	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 127	Left	WF-09162019-000498	11/4/2019	FT-FY20-102019-000498-A	1.8	FT-FY20-102019-000498-B	<1
WS- 000499	4/24/2019	4/24/2020	1	Cooler	In hallway adjacent to room 130	High Left	WF-04242019-000499	11/4/2019	FT-FY20-102019-000499-A	<1	FT-FY20-102019-000499-B	<1
WS- 000500	4/24/2019	4/24/2020	1	Cooler	In hallway adjacent to room 129	Low Right	WF-04242019-000500	11/4/2019	FT-FY20-102019-000500-A	<1	FT-FY20-102019-000500-B	<1
WS- 000501	4/24/2019	4/24/2020	1	Health Suite	In health suite in treatment room 110	Mid	WF-04242019-000501	11/4/2019	FT-FY20-102019-000501-A	<1	FT-FY20-102019-000501-B	<1
WS- 000502	4/24/2019	4/24/2020	1	Combo Fountain	In classroom 112	Right	WF-04242019-000502	11/4/2019	FT-FY20-102019-000502-A	<1	FT-FY20-102019-000502-B	<1
WS- 000503	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 112	Left	WF-09162019-000503	11/4/2019	FT-FY20-102019-000503-A	<1	FT-FY20-102019-000503-B	<1
WS- 000504	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 115	Left	WF-09162019-000504	11/4/2019	FT-FY20-102019-000504-A	<1	FT-FY20-102019-000504-B	<1
WS- 000505	4/24/2019	4/24/2020	1	Combo Fountain	In classroom 115	Right	WF-04242019-000505	11/4/2019	FT-FY20-102019-000505-A	<1	FT-FY20-102019-000505-B	<1
WS- 000506	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 114	Left	WF-09162019-000506	11/4/2019	FT-FY20-102019-000506-A	<1	FT-FY20-102019-000506-B	<1
WS- 000507	4/24/2019	4/24/2020	1	Combo Fountain	In classroom 114	Right	WF-04242019-000507	11/4/2019	FT-FY20-102019-000507-A	<1	FT-FY20-102019-000507-B	<1
WS- 000508	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 113	Left	WF-09162019-000508	11/4/2019	FT-FY20-102019-000508-A	<1	FT-FY20-102019-000508-B	<1
WS- 000510	4/24/2019	4/24/2020	1	Combo Fountain	In classroom 113	Right	WF-04242019-000510	11/4/2019	FT-FY20-102019-000510-A	<1	FT-FY20-102019-000510-B	<1
WS- 000511	4/24/2019	4/24/2020	2	Combo Fountain	In classroom 210	Right	WF-04242019-000511	11/4/2019	FT-FY20-102019-000511-A	<1	FT-FY20-102019-000511-B	<1
WS- 000512	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 210	Left	WF-09162019-000512	11/4/2019	FT-FY20-102019-000512-A	<1	FT-FY20-102019-000512-B	<1
WS- 000513	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 209	Left	WF-09162019-000513	11/4/2019	FT-FY20-102019-000513-A	<1	FT-FY20-102019-000513-B	<1
WS- 000514	4/24/2019	4/24/2020	2	Combo Fountain	In classroom 209	Right	WF-04242019-000514	11/4/2019	FT-FY20-102019-000514-A	<1	FT-FY20-102019-000514-B	<1
WS- 000515	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 211	Left	WF-09162019-000515	11/4/2019	FT-FY20-102019-000515-A	<1	FT-FY20-102019-000515-B	<1
WS- 000516	4/24/2019	4/24/2020	2	Combo Fountain	In classroom 211	Right	WF-04242019-000516	11/4/2019	FT-FY20-102019-000516-A	<1	FT-FY20-102019-000516-B	<1
WS- 000517	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 208	Left	WF-09162019-000517	11/4/2019	FT-FY20-102019-000517-A	<1	FT-FY20-102019-000517-B	<1
WS- 000518	4/24/2019	4/24/2020	2	Combo Fountain	In classroom 208	Right	WF-04242019-000518	11/4/2019	FT-FY20-102019-000518-A	<1	FT-FY20-102019-000518-B	<1
WS- 000519	4/24/2019	4/24/2020	2	Cooler	In hallway adjacent to room 201	Low Left	WF-04242019-000519	11/4/2019	FT-FY20-102019-000519-A	<1	FT-FY20-102019-000519-B	<1
WS- 000520	4/24/2019	4/24/2020	2	Cooler	In hallway adjacent to room 201	High Right	WF-04242019-000520	11/4/2019	FT-FY20-102019-000520-A	<1	FT-FY20-102019-000520-B	<1
WS- 000521	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 223	Left	WF-09162019-000521	11/4/2019	FT-FY20-102019-000521-A	<1	FT-FY20-102019-000521-B	<1
WS- 000522	4/24/2019	4/24/2020	2	Combo Fountain	In classroom 223	Right	WF-04242019-000522	11/4/2019	FT-FY20-102019-000522-A	<1	FT-FY20-102019-000522-B	<1
WS- 000523	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 221	Left	WF-09162019-000523	11/4/2019	FT-FY20-102019-000523-A	<1	FT-FY20-102019-000523-B	<1
WS- 000524	4/24/2019	4/24/2020	2	Combo Fountain	In classroom 221	Right	WF-04242019-000524	11/4/2019	FT-FY20-102019-000524-A	<1	FT-FY20-102019-000524-B	<1

WS- 000525	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 220	Left	WF-09162019-000525	11/4/2019	FT-FY20-102019-000525-A	<1	FT-FY20-102019-000525-B	<1
WS- 000526	4/24/2019	4/24/2020	2	Combo Fountain	In classroom 220	Right	WF-04242019-000526	11/4/2019	FT-FY20-102019-000526-A	<1	FT-FY20-102019-000526-B	<1
WS- 000527	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 219	Left	WF-09162019-000527	11/4/2019	FT-FY20-102019-000527-A	2.4	FT-FY20-102019-000527-B	<1
WS- 000528	4/24/2019	4/24/2020	2	Combo Fountain	In classroom 219	Right	WF-04242019-000528	11/4/2019	FT-FY20-102019-000528-A	<1	FT-FY20-102019-000528-B	<1
WS- 000529	9/16/2019	9/16/2020	3	Combo Faucet	In classroom 309	Left	WF-09162019-000529	11/4/2019	FT-FY20-102019-000529-A	1.9	FT-FY20-102019-000529-B	<1
WS- 000530	4/24/2019	4/24/2020	3	Combo Fountain	In classroom 309	Right	WF-04242019-000530	11/4/2019	FT-FY20-102019-000530-A	<1	FT-FY20-102019-000530-B	<1
WS- 000531	9/16/2019	9/16/2020	3	Combo Faucet	In classroom 310	Left	WF-09162019-000531	11/4/2019	FT-FY20-102019-000531-A	<1	FT-FY20-102019-000531-B	<1
WS- 000532	4/24/2019	4/24/2020	3	Combo Fountain	In classroom 310	Right	WF-04242019-000532	11/4/2019	FT-FY20-102019-000532-A	<1	FT-FY20-102019-000532-B	<1
WS- 000534	4/24/2019	4/24/2020	3	Combo Fountain	In classroom 308	Right	WF-04242019-000534	11/4/2019	FT-FY20-102019-000534-A	<1	FT-FY20-102019-000534-B	<1
WS- 000535	9/16/2019	9/16/2020	3	Combo Faucet	In classroom 307	Left	WF-09162019-000535	11/4/2019	FT-FY20-102019-000535-A	<1	FT-FY20-102019-000535-B	<1
WS- 000536	4/24/2019	4/24/2020	3	Combo Fountain	In classroom 307	Right	WF-04242019-000536	11/4/2019	FT-FY20-102019-000536-A	<1	FT-FY20-102019-000536-B	<1
WS- 000537	4/24/2019	4/24/2020	3	Cooler	In hallway across from room 322	Low Right	WF-04242019-000537	11/4/2019	FT-FY20-102019-000537-A	<1	FT-FY20-102019-000537-B	<1
WS- 000538	4/24/2019	4/24/2020	3	Cooler	In hallway across from room 322	High Left	WF-04242019-000538	11/4/2019	FT-FY20-102019-000538-A	<1	FT-FY20-102019-000538-B	<1
WS- 000539	4/24/2019	4/24/2020	Basement	Cooler	In cafeteria	High Left	WF-04242019-000539	11/4/2019	FT-FY20-102019-000539-A	<1	FT-FY20-102019-000539-B	<1
WS- 000540	4/24/2019	4/24/2020	Basement	Cooler	In cafeteria	Low Right	WF-04242019-000540	11/4/2019	FT-FY20-102019-000540-A	<1	FT-FY20-102019-000540-B	<1
WS- 000546	4/24/2019	4/24/2020	2	Break Room	In staff lounge 218		WF-04242019-000546	11/4/2019	FT-FY20-102019-000546-A	<1	FT-FY20-102019-000546-B	<1
WS- 000571	4/30/2019	4/30/2020	3	Combo Fountain	In library in room 301 Reading / Learning / Circle Area		WF-04302019-000571	11/4/2019	FT-FY20-102019-000571-A	<1	FT-FY20-102019-000571-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000541	7/15/2019	7/15/2020	Basement	Food Prep Sink	In kitchen first clockwise from entry door	WF-07152019-000541	11/4/2019	FT-FY20-102019-000541-A	<1	FT-FY20-102019-000541-B	<1
WS- 000543	7/15/2019	7/15/2020	Basement	Food Prep Sink	In kitchen second clockwise from entry door	WF-07152019-000543	11/4/2019	FT-FY20-102019-000543-A	<1	FT-FY20-102019-000543-B	<1