



THOMSON ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location		1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	THOMSON ELEMENTARY SCHOOL	WS- 000488	8/14/2016	Ground Floor	Cooler	In hallway adjacent to room G02	High Left	FT-72016-000488-A	< 1	FT-72016-000488-B	< 1
2	THOMSON ELEMENTARY SCHOOL	WS- 000489	8/14/2016	Ground Floor	Cooler	In hallway adjacent to room G02	Low Right	FT-72016-000489-A	< 1	FT-72016-000489-B	< 1
3	THOMSON ELEMENTARY SCHOOL	WS- 000492	8/14/2016	1	Fountain	In classroom 123	Right	FT-72016-000492-A	< 1	FT-72016-000492-B	< 1
4	THOMSON ELEMENTARY SCHOOL	WS- 000494	8/14/2016	1	Fountain	In classroom 124	Right	FT-72016-000494-A	< 1	FT-72016-000494-B	< 1
5	THOMSON ELEMENTARY SCHOOL	WS- 000496	8/14/2016	1	Fountain	In classroom 126	Right	FT-72016-000496-A	< 1	FT-72016-000496-B	< 1
6	THOMSON ELEMENTARY SCHOOL	WS- 000497	8/14/2016	1	Fountain	In classroom 127	Right	FT-72016-000497-A	< 1	FT-72016-000497-B	< 1
7	THOMSON ELEMENTARY SCHOOL	WS- 000499	8/14/2016	1	Cooler	In hallway adjacent to room 130	High Left	FT-72016-000499-A	< 1	FT-72016-000499-B	< 1
8	THOMSON ELEMENTARY SCHOOL	WS- 000500	8/14/2016	1	Cooler	In hallway adjacent to room 129	Low Right	FT-72016-000500-A	< 1	FT-72016-000500-B	< 1
9	THOMSON ELEMENTARY SCHOOL	WS- 000501	8/14/2016	1	Health Suite	In treatment room 110 in health suite	Mid	FT-72016-000501-A	< 1	FT-72016-000501-B	< 1
10	THOMSON ELEMENTARY SCHOOL	WS- 000502	8/14/2016	1	Fountain	In classroom 112	Right	FT-72016-000502-A	< 1	FT-72016-000502-B	< 1
11	THOMSON ELEMENTARY SCHOOL	WS- 000505	8/14/2016	1	Fountain	In classroom 115	Right	FT-72016-000505-A	< 1	FT-72016-000505-B	< 1
12	THOMSON ELEMENTARY SCHOOL	WS- 000507	8/14/2016	1	Fountain	In classroom 114	Right	FT-72016-000507-A	< 1	FT-72016-000507-B	< 1
13	THOMSON ELEMENTARY SCHOOL	WS- 000510	8/14/2016	1	Fountain	In classroom 113	Right	FT-72016-000510-A	< 1	FT-72016-000510-B	< 1
14	THOMSON ELEMENTARY SCHOOL	WS- 000511	8/14/2016	2	Fountain	In classroom 210	Right	FT-72016-000511-A	< 1	FT-72016-000511-B	< 1
15	THOMSON ELEMENTARY SCHOOL	WS- 000514	8/14/2016	2	Fountain	In classroom 209	Right	FT-72016-000514-A	< 1	FT-72016-000514-B	1.4
			10/10/2016					Re-test A	< 1	Re-test B	< 1
16	THOMSON ELEMENTARY SCHOOL	WS- 000516	8/14/2016	2	Fountain	In classroom 211	Right	FT-72016-000516-A	< 1	FT-72016-000516-B	< 1
17	THOMSON ELEMENTARY SCHOOL	WS- 000518	8/14/2016	2	Fountain	In classroom 208	Right	FT-72016-000518-A	< 1	FT-72016-000518-B	< 1
18	THOMSON ELEMENTARY SCHOOL	WS- 000519	8/14/2016	2	Cooler	In hallway adjacent to room 201	Low Left	FT-72016-000519-A	< 1	FT-72016-000519-B	< 1
19	THOMSON ELEMENTARY SCHOOL	WS- 000520	8/14/2016	2	Cooler	In hallway adjacent to room 201	High Right	FT-72016-000520-A	< 1	FT-72016-000520-B	< 1
20	THOMSON ELEMENTARY SCHOOL	WS- 000522	8/14/2016	2	Fountain	In classroom 223	Right	FT-72016-000522-A	< 1	FT-72016-000522-B	< 1
21	THOMSON ELEMENTARY SCHOOL	WS- 000524	8/14/2016	2	Fountain	In classroom 221	Right	FT-72016-000524-A	< 1	FT-72016-000524-B	< 1
22	THOMSON ELEMENTARY SCHOOL	WS- 000526	8/14/2016	2	Fountain	In classroom 220	Right	FT-72016-000526-A	< 1	FT-72016-000526-B	< 1
23	THOMSON ELEMENTARY SCHOOL	WS- 000528	8/14/2016	2	Fountain	In classroom 219	Right	FT-72016-000528-A	< 1	FT-72016-000528-B	< 1
24	THOMSON ELEMENTARY SCHOOL	WS- 000530	8/14/2016	3	Fountain	In classroom 309	Right	FT-72016-000530-A	< 1	FT-72016-000530-B	< 1
25	THOMSON ELEMENTARY SCHOOL	WS- 000532	8/14/2016	3	Fountain	In classroom 310	Right	FT-72016-000532-A	< 1	FT-72016-000532-B	< 1
26	THOMSON ELEMENTARY SCHOOL	WS- 000534	8/15/2016	3	Fountain	In classroom 308	Right	FT-72016-000534-A	< 1	FT-72016-000534-B	< 1
27	THOMSON ELEMENTARY SCHOOL	WS- 000536	8/15/2016	3	Fountain	In classroom 307	Right	FT-72016-000536-A	< 1	FT-72016-000536-B	< 1
28	THOMSON ELEMENTARY SCHOOL	WS- 000537	8/15/2016	3	Cooler	In hallway across from room 322	Low Right	FT-72016-000537-A	< 1	FT-72016-000537-B	< 1
29	THOMSON ELEMENTARY SCHOOL	WS- 000538	8/15/2016	3	Cooler	In hallway across from room 322	High Left	FT-72016-000538-A	< 1	FT-72016-000538-B	< 1
30	THOMSON ELEMENTARY SCHOOL	WS- 000539	8/15/2016	Basement	Cooler	In cafeteria	High Left	FT-72016-000539-A	< 1	FT-72016-000539-B	< 1
31	THOMSON ELEMENTARY SCHOOL	WS- 000540	8/15/2016	Basement	Cooler	In cafeteria	Low Right	FT-72016-000540-A	< 1	FT-72016-000540-B	< 1
32	THOMSON ELEMENTARY SCHOOL	WS- 000543	8/15/2016	Basement	Food Prep Sink	In kitchen second clockwise from entry door		FT-72016-000543-A	< 1	FT-72016-000543-B	< 1