



Thomson ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000488	5/1/2018	5/1/2019	Ground Floor	Cooler	In hallway adjacent to room G02	High	Left	WF-05012018-000488	11/6/2018	FT-FY19-102018-000488-A	< 1	FT-FY19-102018-000488-B	< 1
WS- 000489	5/1/2018	5/1/2019	Ground Floor	Cooler	In hallway adjacent to room G02	Low	Right	WF-05012018-000489	11/6/2018	FT-FY19-102018-000489-A	< 1	FT-FY19-102018-000489-B	< 1
WS- 000491	9/26/2018	9/26/2019	1	Combo Faucet	In classroom 123		Left	WF-09262018-000491	11/6/2018	FT-FY19-102018-000491-A	< 1	FT-FY19-102018-000491-B	< 1
WS- 000492	5/1/2018	5/1/2019	1	Combo Fountain	In classroom 123		Right	WF-05012018-000492	11/6/2018	FT-FY19-102018-000492-A	< 1	FT-FY19-102018-000492-B	< 1
WS- 000493	9/26/2018	9/26/2019	1	Combo Faucet	In classroom 124		Left	WF-09262018-000493	11/6/2018	FT-FY19-102018-000493-A	< 1	FT-FY19-102018-000493-B	< 1
WS- 000494	5/1/2018	5/1/2019	1	Combo Fountain	In classroom 124		Right	WF-05012018-000494	11/6/2018	FT-FY19-102018-000494-A	< 1	FT-FY19-102018-000494-B	< 1
WS- 000495	9/26/2018	9/26/2019	1	Combo Faucet	In classroom 126		Left	WF-09262018-000495	11/6/2018	FT-FY19-102018-000495-A	< 1	FT-FY19-102018-000495-B	< 1
WS- 000496	5/1/2018	5/1/2019	1	Combo Fountain	In classroom 126		Right	WF-05012018-000496	11/6/2018	FT-FY19-102018-000496-A	< 1	FT-FY19-102018-000496-B	< 1
WS- 000497	5/1/2018	5/1/2019	1	Combo Fountain	In classroom 127		Right	WF-05012018-000497	11/6/2018	FT-FY19-102018-000497-A	< 1	FT-FY19-102018-000497-B	< 1
WS- 000498	9/26/2018	9/26/2019	1	Combo Faucet	In classroom 127		Left	WF-09262018-000498	11/6/2018	FT-FY19-102018-000498-A	< 1	FT-FY19-102018-000498-B	< 1
WS- 000499	5/1/2018	5/1/2019	1	Cooler	In hallway adjacent to room 130	High	Left	WF-05012018-000499	11/6/2018	FT-FY19-102018-000499-A	< 1	FT-FY19-102018-000499-B	< 1
WS- 000500	5/1/2018	5/1/2019	1	Cooler	In hallway adjacent to room 129	Low	Right	WF-05012018-000500	11/6/2018	FT-FY19-102018-000500-A	< 1	FT-FY19-102018-000500-B	< 1
WS- 000501	5/1/2018	5/1/2019	1	Health Suite	In health suite in treatment room 110		Mid	WF-05012018-000501	11/6/2018	FT-FY19-102018-000501-A	< 1	FT-FY19-102018-000501-B	< 1
WS- 000502	5/1/2018	5/1/2019	1	Combo Fountain	In classroom 112		Right	WF-05012018-000502	11/6/2018	FT-FY19-102018-000502-A	< 1	FT-FY19-102018-000502-B	< 1
WS- 000503	9/26/2018	9/26/2019	1	Combo Faucet	In classroom 112		Left	WF-09262018-000503	11/6/2018	FT-FY19-102018-000503-A	< 1	FT-FY19-102018-000503-B	< 1
WS- 000504	9/26/2018	9/26/2019	1	Combo Faucet	In classroom 115		Left	WF-09262018-000504	11/6/2018	FT-FY19-102018-000504-A	< 1	FT-FY19-102018-000504-B	< 1
WS- 000505	5/1/2018	5/1/2019	1	Combo Fountain	In classroom 115		Right	WF-05012018-000505	11/6/2018	FT-FY19-102018-000505-A	< 1	FT-FY19-102018-000505-B	< 1
WS- 000506	9/26/2018	9/26/2019	1	Combo Faucet	In classroom 114		Left	WF-09262018-000506	11/6/2018	FT-FY19-102018-000506-A	< 1	FT-FY19-102018-000506-B	< 1
WS- 000507	5/1/2018	5/1/2019	1	Combo Fountain	In classroom 114		Right	WF-05012018-000507	11/6/2018	FT-FY19-102018-000507-A	< 1	FT-FY19-102018-000507-B	< 1
WS- 000508	9/26/2018	9/26/2019	1	Combo Faucet	In classroom 113		Left	WF-09262018-000508	11/6/2018	FT-FY19-102018-000508-A	< 1	FT-FY19-102018-000508-B	< 1
WS- 000510	5/1/2018	5/1/2019	1	Combo Fountain	In classroom 113		Right	WF-05012018-000510	11/6/2018	FT-FY19-102018-000510-A	< 1	FT-FY19-102018-000510-B	< 1
WS- 000511	5/1/2018	5/1/2019	2	Combo Fountain	In classroom 210		Right	WF-05012018-000511	11/6/2018	FT-FY19-102018-000511-A	< 1	FT-FY19-102018-000511-B	< 1
WS- 000512	9/26/2018	9/26/2019	2	Combo Faucet	In classroom 210		Left	WF-09262018-000512	11/6/2018	FT-FY19-102018-000512-A	< 1	FT-FY19-102018-000512-B	< 1
WS- 000513	9/26/2018	9/26/2019	2	Combo Faucet	In classroom 209		Left	WF-09262018-000513	11/6/2018	FT-FY19-102018-000513-A	< 1	FT-FY19-102018-000513-B	< 1
WS- 000514	5/1/2018	5/1/2019	2	Combo Fountain	In classroom 209		Right	WF-05012018-000514	11/6/2018	FT-FY19-102018-000514-A	< 1	FT-FY19-102018-000514-B	< 1
WS- 000515	9/26/2018	9/26/2019	2	Combo Faucet	In classroom 211		Left	WF-09262018-000515	11/6/2018	FT-FY19-102018-000515-A	< 1	FT-FY19-102018-000515-B	< 1
WS- 000516	5/1/2018	5/1/2019	2	Combo Fountain	In classroom 211		Right	WF-05012018-000516	11/6/2018	FT-FY19-102018-000516-A	< 1	FT-FY19-102018-000516-B	< 1
WS- 000517	9/26/2018	9/26/2019	2	Combo Faucet	In classroom 208		Left	WF-09262018-000517	11/6/2018	FT-FY19-102018-000517-A	< 1	FT-FY19-102018-000517-B	< 1
WS- 000518	5/1/2018	5/1/2019	2	Combo Fountain	In classroom 208		Right	WF-05012018-000518	11/6/2018	FT-FY19-102018-000518-A	< 1	FT-FY19-102018-000518-B	< 1
WS- 000519	5/1/2018	5/1/2019	2	Cooler	In hallway adjacent to room 201	Low	Left	WF-05012018-000519	11/6/2018	FT-FY19-102018-000519-A	< 1	FT-FY19-102018-000519-B	< 1
WS- 000520	5/1/2018	5/1/2019	2	Cooler	In hallway adjacent to room 201	High	Right	WF-05012018-000520	11/6/2018	FT-FY19-102018-000520-A	< 1	FT-FY19-102018-000520-B	< 1
WS- 000521	9/26/2018	9/26/2019	2	Combo Faucet	In classroom 223		Left	WF-09262018-000521	11/6/2018	FT-FY19-102018-000521-A	< 1	FT-FY19-102018-000521-B	< 1
WS- 000522	5/1/2018	5/1/2019	2	Combo Fountain	In classroom 223		Right	WF-05012018-000522	11/6/2018	FT-FY19-102018-000522-A	< 1	FT-FY19-102018-000522-B	< 1
WS- 000523	9/26/2018	9/26/2019	2	Combo Faucet	In classroom 221		Left	WF-09262018-000523	11/6/2018	FT-FY19-102018-000523-A	< 1	FT-FY19-102018-000523-B	< 1

WS- 000524	5/1/2018	5/1/2019	2	Combo Fountain	In classroom 221	Right	WF-05012018-000524	11/6/2018	FT-FY19-102018-000524-A	< 1	FT-FY19-102018-000524-B	< 1
WS- 000525	9/26/2018	9/26/2019	2	Combo Faucet	In classroom 220	Left	WF-09262018-000525	11/6/2018	FT-FY19-102018-000525-A	< 1	FT-FY19-102018-000525-B	< 1
WS- 000526	5/1/2018	5/1/2019	2	Combo Fountain	In classroom 220	Right	WF-05012018-000526	11/6/2018	FT-FY19-102018-000526-A	< 1	FT-FY19-102018-000526-B	< 1
WS- 000527	9/26/2018	9/26/2019	2	Combo Faucet	In classroom 219	Left	WF-09262018-000527	11/6/2018	FT-FY19-102018-000527-A	< 1	FT-FY19-102018-000527-B	< 1
WS- 000528	5/1/2018	5/1/2019	2	Combo Fountain	In classroom 219	Right	WF-05012018-000528	11/6/2018	FT-FY19-102018-000528-A	< 1	FT-FY19-102018-000528-B	< 1
WS- 000529	9/26/2018	9/26/2019	3	Combo Faucet	In classroom 309	Left	WF-09262018-000529	11/6/2018	FT-FY19-102018-000529-A	< 1	FT-FY19-102018-000529-B	< 1
WS- 000530	5/1/2018	5/1/2019	3	Combo Fountain	In classroom 309	Right	WF-05012018-000530	11/6/2018	FT-FY19-102018-000530-A	< 1	FT-FY19-102018-000530-B	< 1
WS- 000531	9/26/2018	9/26/2019	3	Combo Faucet	In classroom 310	Left	WF-09262018-000531	11/6/2018	FT-FY19-102018-000531-A	< 1	FT-FY19-102018-000531-B	< 1
WS- 000532	5/1/2018	5/1/2019	3	Combo Fountain	In classroom 310	Right	WF-05012018-000532	11/6/2018	FT-FY19-102018-000532-A	< 1	FT-FY19-102018-000532-B	< 1
WS- 000534	5/1/2018	5/1/2019	3	Combo Fountain	In classroom 308	Right	WF-05012018-000534	11/6/2018	FT-FY19-102018-000534-A	< 1	FT-FY19-102018-000534-B	< 1
WS- 000535	9/26/2018	9/26/2019	3	Combo Faucet	In classroom 307	Left	WF-09262018-000535	11/6/2018	FT-FY19-102018-000535-A	< 1	FT-FY19-102018-000535-B	< 1
WS- 000536	5/1/2018	5/1/2019	3	Combo Fountain	In classroom 307	Right	WF-05012018-000536	11/6/2018	FT-FY19-102018-000536-A	< 1	FT-FY19-102018-000536-B	< 1
WS- 000537	5/1/2018	5/1/2019	3	Cooler	In hallway across from room 322	Low Right	WF-05012018-000537	11/6/2018	FT-FY19-102018-000537-A	< 1	FT-FY19-102018-000537-B	< 1
WS- 000538	5/1/2018	5/1/2019	3	Cooler	In hallway across from room 322	High Left	WF-05012018-000538	11/6/2018	FT-FY19-102018-000538-A	< 1	FT-FY19-102018-000538-B	< 1
WS- 000539	5/1/2018	5/1/2019	Basement	Cooler	In cafeteria	High Left	WF-05012018-000539	11/6/2018	FT-FY19-102018-000539-A	< 1	FT-FY19-102018-000539-B	< 1
WS- 000540	5/1/2018	5/1/2019	Basement	Cooler	In cafeteria	Low Right	WF-05012018-000540	11/6/2018	FT-FY19-102018-000540-A	< 1	FT-FY19-102018-000540-B	< 1
WS- 000546	5/1/2018	5/1/2019	2	Break Room	In staff lounge 218		WF-05012018-000546	11/6/2018	FT-FY19-102018-000546-A	< 1	FT-FY19-102018-000546-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation								
Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000543	Basement	Food Prep Sink	In kitchen second clockwise from entry door	11/6/2018	FT-FY19-102018-000543-A	< 1	FT-FY19-102018-000543-B	< 1